Bregman storage functions for microgrid control

C. De Persis and N. Monshizadeh

Abstract—In this paper we contribute a theoretical framework that sheds a new light on the problem of microgrid analysis and control. The starting point is an energy function comprising the "kinetic" energy associated with the elements that emulate the rotating machinery and terms taking into account the reactive power stored in the lines and dissipated on shunt elements. We then shape this energy function with the addition of an adjustable voltage-dependent term, and construct socalled Bregman storage functions satisfying suitable dissipation inequalities. Our choice of the voltage-dependent term depends on the voltage dynamics under investigation. Several microgrids dynamics that have similarities or coincide with dynamics already considered in the literature are captured in our incremental energy analysis framework. The twist with respect to existing results is that our incremental storage functions allow for a large signal analysis of the coupled microgrid obviating the need for simplifying linearization techniques and for the restrictive decoupling assumption in which the frequency dynamics is fully separated from the voltage one. A complete Lyapunov stability analysis of the various systems is carried out along with a discussion on their active and reactive power sharing properties.

I. INTRODUCTION

Microgrids have been envisioned as one of the leading technologies to increase the penetration of renewable energies in the power market. A thorough discussion of the technological, physical and control-theoretic aspects of microgrids is provided in many interesting comprehensive works, including [60], [59], [25], [4], [40].

Power electronics allows inverter in the microgrids to emulate desired dynamic behavior. This is an essential feature since when the microgrid is in grid forming mode, inverters have to inject active and reactive power in order to supply the loads in a shared manner and maintain the desired frequency and voltage values at the nodes. Hence, much work has focused on the design of dynamics for the inverters that achieve these desired properties and this effort has involved both practitioners and theorists, all providing a myriad of solutions, whose performance has been tested mainly numerically and experimentally.

The main obstacle however remains a systematic design of the microgrid controllers that achieve the desired properties in terms of frequency and voltage regulation with power sharing. The difficulty lies in the complex structure of these systems, comprising dynamical models of inverters and loads that are physically interconnected via exchange of active and reactive power. In quasi steady state working conditions, these quantities are sinusoidal terms depending on the voltage phasor relative phases. As a result, mathematical models of microgrids reduce to high-order oscillators interconnected via sinusoidal coupling, where the coupling weights depend on the voltage magnitudes obeying additional dynamics. The challenges with these models lie in the presence of highly nonlinear terms and the strict coupling between active and reactive power flow equations.

To deal with the aforementioned complexity of these dynamical models common remedies are to decouple frequency and voltage dynamics, and to linearize the power flow equations. While the former enables a separate analysis of the two dynamics ([42]), the latter permits the use of a small signal argument to infer stability results; see e.g. [46], [47].

Results that deal with the fully coupled system are also available [41], [54], [35]. In this case, the results mainly concern network-reduced models with primary control, namely stability rather than stabilization of the equilibrium solution. Furthermore, lossy transmission lines can also be studied [20], [54], [6], [54], [35], and also [15].

Main contribution. In spite of these many advances, what is still missing is a comprehensive approach to deal with the analysis and control design for microgrids. In this paper we provide a contribution in this direction. The starting point is the energy function associated with the system, a combination of kinetic and potential energy. Relying on an extended notion of incremental dissipativity, a number of so-called Bregman storage functions whose critical points have desired features are constructed. The construction is inspired by works in the control of networks in the presence of disturbances, which makes use of internal model controllers ([9], [34]) and incremental passivity ([49]). The storage functions that we design encompass several network-reduced versions of microgrid dynamics that have appeared in the literature, including the conventional droop controller [60], [41], the quadratic droop controller [46], and the reactive power consensus dynamics [42]. Our analysis, however, suggests suitable modifications such as an exponential scaling of the averaging reactive power dynamics of [42], and inspires new controllers, such as the socalled reactive current controller (we refer to [7] for a related controller). The approach we propose has two additional distinguishing features: we do not need to assume decoupled dynamics and we perform a large signal analysis.

Our contribution also expands the knowledge on the use of energy functions in the context of microgrids. Although historically energy functions have played a crucial role to deal with accurate models of power systems ([52], [16], [14]), our approach based on the incremental dissipativity notion sheds a new light into the construction of these energy functions, allows us to cover a wider range of microgrid dynamics, and paves the way for the design of dynamic controllers, following the combination of passivity techniques and internal model principles as in [9]. We refer the reader to e.g. [36], [19] for

C. De Persis and N. Monshizadeh are with ENTEG and the J.C. Willems Center for Systems and Control, University of Groningen, the Netherlands. E-mail: {c.de.persis, n.monshizadeh}@rug.nl.

seminal work on passivity-based control of power networks.

In this paper we focus on network reduced models of microgrids ([41], [54], [35], [47]). These models are typically criticized for not providing an explicit characterization of the loads ([46]). Focusing on network reduced models allows us to reduce the technical complexity of the arguments and to provide an elegant analysis. However, one of the advantages of the use of the energy functions is that they remain effective also with network preserved models ([52]). In fact, a preliminary investigation not reported in this manuscript for the sake of brevity shows that the presented results extend to the case of network preserved models. A full investigation of this case will be reported elsewhere.

The outline of the paper is as follows. In Section II, details on the model under consideration are provided. In Section III the design of Bregman storage functions is carried out and incremental dissipativity of various models of microgrids associated with different voltage dynamics is shown. A few technical conditions on these energy functions are discussed in Section IV, and a distributed test to check them is also provided. Based on the results of these sections, attractivity of the prescribed synchronous solution and voltage stability is presented in Section V, along with a discussion on power sharing properties of the proposed controllers (Subsection V-A). Power sharing in the presence of homogeneous lossy transmission lines is studied in Subsection V-B. The paper ends with concluding remarks in Section VI.

II. MICROGRID MODEL AND A SYNCHRONOUS SOLUTION

We consider a network-reduced model of a microgrid operating in islanded mode, that is disconnected from the main grid. This model is given by

$$\theta = \omega$$

$$T_P \dot{\omega} = -(\omega - \omega^*) - K_P (P - P^*) + u_P \qquad (1)$$

$$T_Q \dot{V} = f(V, Q, u_Q)$$

where $\theta \in \mathbb{T}^n$ is the vector of voltage angles, $\omega \in \mathbb{R}^n$ is the frequency, $P \in \mathbb{R}^n$ is the active power vector, $Q \in \mathbb{R}^n$ is the reactive power vector, and $V \in \mathbb{R}^n_{>0}$ is the vector of voltage magnitudes. The integer n equals the number of nodes in the microgrid and $\mathcal{I} := \{1, 2, ..., n\}$ is the set of indices associated with the nodes. The matrices T_P , T_V , and K_P are diagonal and positive definite. The vectors ω^* and P^* denote the frequency and active power setpoints, respectively. The vector P^* may also models active power loads at the buses (see Remark 2). The vector u_Q is an additional input. The function f accounts for the voltage dynamics/controller and is decided later.

The model (1) with an appropriate selection of f describes various models of network-reduced microgrids in the literature, including conventional droop controllers, quadratic droop controllers, and consensus based reactive power control schemes ([60], [45], [41], [46], [42]). However, while [45], [46], [43] consider network-preserved models of microgrids, in this paper network-reduced models are considered. We refer the reader to [43] for a compelling derivation of microgrid models from first principles.

Our goal here is to provide a unifying framework for analysis of the microgrid model (1) for different types of voltage controllers, and study frequency regulation, voltage stability, and active as well as reactive power sharing. A key

often restrictive premises such as the decoupling assumption and linear approximations. Active and reactive power. The active power P_i is given by

point of our approach is that it does not rely on simplifying and

$$P_i = \sum_{j \in \mathcal{N}_i} B_{ij} V_i V_j \sin \theta_{ij}, \quad \theta_{ij} := \theta_i - \theta_j$$
(2)

and the reactive power by

$$Q_i = B_{ii}V_i^2 - \sum_{j \in \mathcal{N}_i} B_{ij}V_iV_j \cos\theta_{ij}, \quad \theta_{ij} := \theta_i - \theta_j.$$
(3)

Note that here $B_{ii} = \hat{B}_{ii} + \sum_{j \in \mathcal{N}_i} B_{ij}$, where $B_{ij} = B_{ji} > 0$ is the negative of the susceptance at edge $\{i, j\}$ and $\hat{B}_{ii} \ge 0$ is the negative of the shunt susceptance at node i.¹ Hence, $B_{ii} \ge \sum_{j \in \mathcal{N}_i} B_{ij}$ for all i.

It is useful to have compact representations of both active and reactive power. Setting $\Gamma(V) = \text{diag}(\gamma_1(V), \ldots, \gamma_m(V))$, $\gamma_k(V) = V_i V_j B_{ij}$, with $k \in E := \{1, 2, \ldots, m\}$ being the index corresponding to the edge $\{i, j\}$ (in short, $k \sim \{i, j\}$), the vector of the active power at all the nodes writes as

$$P = D\Gamma(V)\mathbf{sin}(D^T\theta).$$

where $D = [d_{ik}]$ is the incidence matrix of the graph describing the interconnection structure of the network, and the vector $\sin(\cdot)$ is defined element-wise. Let us now introduce the vector $A_0 = \operatorname{col}(B_{11}, \ldots, B_{nn})$. Since $|d_{ik}| \cos(d_{ik}\theta_i + d_{jk}\theta_j) = \cos(\theta_i - \theta_j)$, for $k \sim \{i, j\}$, the vector of reactive power at the nodes takes the form

$$Q = [V][A_0]V - |D|\Gamma(V)\mathbf{cos}(D^T\theta),$$

where |D| is obtained by replacing each element d_{ij} of D with $|d_{ij}|^2$. Moreover, here and throughout the paper, the notation [v] represents the diagonal matrix associated with vector v.

Another compact representation is useful as well. To this end, introduce the symmetric matrix

$$\mathcal{A}(\cos(D^T\theta)) = \begin{bmatrix} B_{11} & -B_{12}\cos\theta_{12} & \dots & -B_{1n}\cos\theta_{1n} \\ -B_{21}\cos\theta_{21} & B_{22} & \dots & -B_{2n}\cos\theta_{2n} \\ \vdots & \vdots & \ddots & \vdots \\ -B_{n1}\cos\theta_{n1} & -B_{n2}\cos\theta_{n2} & \dots & B_{nn} \end{bmatrix}.$$

¹See Remark 2 for a discussion on the physical meaning of these shunt susceptances.

²In fact, denoted by η the vector $D^T \theta$, the entry ij of the matrix $|D|\Gamma(V)\cos(D^T\theta)$ writes as

$$[|D|\Gamma(V)\mathbf{cos}(D^T\theta)]_{ij} = \sum_{k=1}^{m} |d_{ik}|\gamma_k(V)\cos(\eta_k)$$

=
$$\sum_{k\sim\{i,j\}}^{k=1} |d_{ik}|V_iV_jB_{ij}\cos(d_{ik}\theta_i + d_{jk}\theta_j)$$

=
$$\sum_{j\in\mathcal{N}_i}^{k} V_iV_jB_{ij}\cos(\theta_i - \theta_j)$$

The vector Q becomes

$$Q = [V]\mathcal{A}(\cos(D^T\theta))V, \qquad (4)$$

where again we are exploiting the identity $\cos(d_{ik}\theta_i + d_{jk}\theta_j) = \cos\theta_{ij}$.

As a consequence of the condition $B_{ii} \geq \sum_{j \in \mathcal{N}_i} B_{ij}$ for all *i*, provided that at least one \hat{B}_{ii} is non-zero (which is the standing assumption throughout the paper), the symmetric matrix $\mathcal{A}(\cos(D^T\theta))$ has all strictly positive eigenvalues and hence is a positive definite matrix. Note that the matrix \mathcal{A} can be interpreted as a loopy Laplacian matrix of the graph.

Before proceeding further, we remark on the adopted model.

Remark 1. (Lossless and lossy network) The power lines are assumed to be *lossless* in (1). This is valid if the lines are dominantly inductive, a condition which can be fulfilled by tuning output impedances of the inverters; see e.g. [31]. As will be observed in Subsection V-B, the lossless assumption can be relaxed by considering *lossy*, yet *homogenous*, power lines.

Remark 2. (Loads) There are a few load scenarios that can be incorporated in the microgrid model (1). The first scenario accounts for purely inductive loads, see [42, Remark 1]. Whether these loads are collocated with inverters or appear as individual nodes, they will lead to nonzero shunt admittances at the nodes of the reduced network, where the latter follows from Kron reduction. The resulting shunt admittances constitute the nonzero shunt susceptance \hat{B}_{ii} introduced after (3), see also [47, Section V.A] and [42]. As for the active power loads, following [41, Remark 3.2], one can consider negative active power setpoints P_i^* for the inverter *i*, which corresponds to the inverter *i* connecting a storage device to the grid, in which case the device is acting as a frequency and voltage dependent load (see also [35, Section 2.4]). Another possibility is to consider constant active power loads collocated with the inverters by embedding the constant active power consumption in the term P_i^* . We remark that the controllers studied in the paper do not rely on the knowledge of P_i^* , and are therefore fully compatible with the case in which P_i^* are not completely known due to uncertainties in the loads. Finally, the extension of our analysis to the lossy lines in Subsection V-B allows us to accommodate loads as homogenous RL circuits. As an interesting special case of this, the forthcoming dissipativity/stability analysis carries over to the case of microgrids with (purely) resistive lines and loads. More details on this case are provided in Subsection V-B.

To pursue our analysis, we demonstrate an incremental cyclo-dissipativity property of the various microgrid models, with respect to a "synchronous solution". The notion of dissipativity adopted in this paper is introduced next, and synchronous solutions will be identified afterwards.

Definition 1. System $\dot{x} = f(x, u), y = h(x), x \in \mathcal{X}, \mathcal{X}$ the state space, $y, u \in \mathbb{R}^m$, is incrementally cyclo-dissipative with state-dependent supply rate s(x, u, y) and with respect to a given input-state-output triple $(\overline{u}, \overline{x}, \overline{y})$, if there exist a continuously differentiable function $S : \mathcal{X} \to \mathbb{R}$, and state-dependent

positive semi-definite³ matrices $W, R : \mathcal{X} \to \mathbb{R}^{m \times m}$, such that for all $x \in \mathcal{X}, u \in \mathbb{R}^m$ and $y = h(x), \overline{y} = h(\overline{x})^4$

$$\frac{\partial \mathcal{S}}{\partial x}f(x,u) + \frac{\partial \mathcal{S}}{\partial \overline{x}}f(\overline{x},\overline{u}) \le s(x,u-\overline{u},y-\overline{y})$$

with

$$s(x, u, y) = -y^T W(x)y + y^T R(x)u.$$
 (5)

We remark that at this point the function S is not required to be non-negative nor bounded from below and that the weight matrices W, R are allowed to be state dependent. The use of the qualifier "cyclo" in the definition above stresses the former feature [53, Def. 2].

Remark 3. In case the matrices W and R are state independent, some notable special cases of Definition 1 are obtained as follows:

- i) $W \ge 0$, R = I, $S \ge 0$ (incremental passivity)
- ii) W > 0, R = I, $S \ge 0$ (output-strict incremental passivity)
- iii) $W \ge 0$, R = I (cyclo-incremental passivity)
- iv) W > 0, R = I (output-strict cyclo-incremental passivity).

Synchronous solution. Given the constant vectors \overline{u}_P and \overline{u}_Q , a synchronous solution to (1) is defined as the triple

$$(\theta(t), \omega(t), V(t)) = (\overline{\theta}, \overline{\omega}, \overline{V}),$$

where $\overline{\theta} = \overline{\omega}t + \theta^0$, $\overline{\omega} = \mathbb{1}\omega^0$, the scalar ω^0 and the vectors θ^0 and $\overline{V} \in \mathbb{R}^n_{>0}$ are constant. In addition,

$$\begin{array}{rcl}
\mathbf{0} &=& -(\overline{\omega} - \omega^*) - K_P(\overline{P} - P^*) + \overline{u}_P \\
\mathbf{0} &=& f(\overline{V}, \overline{Q}, \overline{u}_Q),
\end{array}$$
(6)

where

$$\overline{P} = D\Gamma(\overline{V})\operatorname{sin}(D^T\overline{\theta}) = D\Gamma(\overline{V})\operatorname{sin}(D^T\theta^0),$$

$$\overline{Q} = [\overline{V}]\mathcal{A}(\operatorname{cos}(D^T\overline{\theta}))\overline{V} = [\overline{V}]\mathcal{A}(\operatorname{cos}(D^T\theta^0))\overline{V}.$$
(7)

Notice that the key feature of a synchronous solution is that the voltage phase angles are rotating with the same frequency, namely ω^0 , and the differences of these angles are thus constant. Another feature is that the voltage amplitudes are constant.

III. DESIGN OF BREGMAN STORAGE FUNCTIONS

A crucial step for the Lyapunov based analysis of the coupled nonlinear model (1) is constructing a storage function. To this end, we start off with the following classical energy-based function, e.g. [38]

$$U(\theta, \omega, V) = \frac{1}{2} \omega^T K_P^{-1} T_P \omega + \frac{1}{2} \mathbb{1}^T Q$$

$$= \frac{1}{2} \omega^T K_P^{-1} T_P \omega + \frac{1}{2} V^T \mathcal{A}(\cos(D^T \theta)) V,$$
(8)

³A state-dependent matrix $M : \mathcal{X} \to \mathbb{R}^{m \times m}$ is positive semi-definite if $y^T M(x)y \ge 0$ for all $x \in \mathcal{X}$ and for all $y \in \mathbb{R}^m$. If M is positive semi-definite and $y^T M(x)y = 0 \Leftrightarrow y = \mathbf{0}$ then M is called positive definite.

⁴We are slightly abusing the classical notion of incremental dissipativity [18], for we do not consider pairs of arbitrary input-state-output triples, but pairs in which one of the two triples is fixed. For additional work on incremental dissipativity we refer the reader to [48], [49].

where we have exploited (4) to write the second equality. Notice that the first term represents the kinetic "energy" (in quotes because the term has the units of power and it does not correspond to the physical inertia), and the second one the sum of the reactive power stored in the links and the power partly associated with the shunt components.

Next, we compute the gradient of the storage function as follows:

$$\begin{aligned} \frac{\partial U}{\partial \theta} &= P = D\Gamma(V) \sin(D^T \theta), \\ \frac{\partial U}{\partial V} &= [V]^{-1} Q = [A_0] V - [V]^{-1} |D| \Gamma(V) \cos(D^T \theta). \end{aligned}$$

In the equality above, we are implicitly assuming that each component of the voltage vector never crosses zero. In fact, we shall assume the following:

Assumption 1. There exists a subset \mathcal{X} of the state space $\mathbb{T}^n \times \mathbb{R}^n \times \mathbb{R}^n_{>0}$ that is forward invariant along the solutions to (1).

Conditions under which this assumption is fulfilled will be provided later in the paper.

Notice that the voltage dynamics identified by f has not yet been taken into account in the function U. Therefore, to cope with different voltage dynamics (or controllers) we add another component, namely H(V), and define

$$S(\theta, \omega, V) = U(\theta, \omega, V) + H(V).$$
(9)

We rest our analysis on the following foundational incremental storage function

$$S(\theta, \omega, V) = S(\theta, \omega, V) - S(\overline{\theta}, \overline{\omega}, \overline{V}) - \frac{\partial S}{\partial \theta} \Big|_{-}^{T} (\theta - \overline{\theta}) - \frac{\partial S}{\partial \omega} \Big|_{-}^{T} (\omega - \overline{\omega}) - \frac{\partial S}{\partial V} \Big|_{-}^{T} (V - \overline{V})$$
(10)

where we use the conventional notation

$$\frac{\partial F}{\partial x}\Big|_{-} = \frac{\partial F}{\partial x}(\overline{x}), \qquad \frac{\partial F}{\partial x}\Big|_{-}^{T} = (\frac{\partial F}{\partial x}(\overline{x}))^{T}$$

for a function $F : \mathcal{X} \to \mathbb{R}$. The storage function S, in fact, defines a "distance" between the value of S at point (θ, ω, V) and the value of a first-order Taylor expansion of S around $(\overline{\theta}, \overline{\omega}, \overline{V})$. This construction is referred to as *Bregman distance* or *Bregman divergence* following [8], and has found its applications in convex programming, clustering, proximal minimization, online learning, and proportional-integral stabilisation of nonlinear circuits; see e.g. [8], [3], [12], [55], [28]. In thermodynamics, the Bregman distance has its antecedents in the notion of availability function [30], [1], [56].

The function \mathcal{S} can be decomposed as

$$S = \mathcal{U} + \mathcal{H} \tag{11}$$

where

$$\mathcal{U}(\theta,\omega,V) = U(\theta,\omega,V) - U(\overline{\theta},\overline{\omega},\overline{V}) - \frac{\partial U}{\partial \theta}\Big|_{-}^{T}(\theta-\overline{\theta}) \\ - \frac{\partial U}{\partial \omega}\Big|_{-}^{T}(\omega-\overline{\omega}) - \frac{\partial U}{\partial V}\Big|_{-}^{T}(V-\overline{V})$$

and

$$\mathcal{H}(V) = H(V) - H(\overline{V}) - \frac{\partial H}{\partial V}\Big|_{-}^{T} (V - \overline{V}).$$

The above identities show that the critical points of S occur for $\omega = \overline{\omega}$ and $P = \overline{P}$ which is a desired property. The critical point of S with respect to the V coordinate is determined by the choice of H which depends on the voltage dynamics.

To establish a suitable incremental dissipativity property of the system with respect to a synchronous solution, we introduce the output variables

$$y = \operatorname{col}(y_P, \ y_Q) \tag{12}$$

with

$$y_P = T_P^{-1} \frac{\partial S}{\partial \omega} = K_P^{-1} \omega, \qquad y_Q = T_Q^{-1} \frac{\partial S}{\partial V}$$

and input variables

$$u = \operatorname{col}(u_P, \ u_Q). \tag{13}$$

In what follows, we differentiate among different voltage controllers and adjust the analysis accordingly by tuning H.

A. Conventional droop controller

The conventional droop controllers are obtained by setting f in (1) as

$$f(V, Q, u_Q) = -V - K_Q Q + u_Q$$
 (14)

where $K_Q = [k_Q]$ is a diagonal matrix with positive droop coefficients on its diagonal. Note that u_Q is added for the sake of generality and one can set $u_Q = \overline{u}_Q = K_Q Q^* + V^*$ for nominal constant vectors V^* and Q^* to obtain the well known expression of conventional droop controllers, see e.g. [13], [60]. For this choice of f, we pick the function H in (9) as ([41], [50])

$$H(V) = \mathbb{1}^T K_Q V - (\overline{Q} + K_Q^{-1} \overline{V})^T \ln(V), \qquad (15)$$

with $\overline{Q} + K_Q^{-1}\overline{V} = K_Q^{-1}\overline{u}_Q \in \mathbb{R}^n_{>0}$ and $\ln(V)$ defined element-wise. This term has two interesting features. First, it makes the incremental storage function S radially unbounded with respect to V on the positive orthant. Moreover, it shifts the critical points of S as desired. Noting that by (6)

$$0 = -\overline{V} - K_Q \overline{Q} + \overline{u}_Q,$$

straightforward calculations yields

$$T_Q \dot{V} = -K_Q [V] \frac{\partial S}{\partial V} + u_Q - \overline{u}_Q.$$
(16)

In the following subsections we will derive analogous identities and then use those for concluding incremental cyclodissipativity of the system.

B. Quadratic droop controller

Another voltage dynamics proposed in the literature is associated with the quadratic droop controllers of [46], which can be expressed as (1) with

$$f(V, Q, u_Q) = -K_Q Q - [V](V - u_Q),$$
(17)

where again $K_Q = [k_Q]$ collects the droop coefficients. The quadratic droop controllers in [46] is obtained by setting $u_Q = V^*$ for some constant vector V^* . Notice however the difference: while [46] focuses on a network preserved microgrid model in which the equation above models the inverter dynamics and are decoupled from the frequency dynamics, here a fully coupled network reduced model is considered.

Moreover, note that the scaling matrix [V] distinguishes this case from the conventional droop controller. For this case, we adapt the storage function S by setting

$$H(V) = \frac{1}{2} V^T K_Q^{-1} V.$$
(18)

Recall that S = U + H. Note that S is defined on the whole $\mathbb{T}^n \times \mathbb{R}^n \times \mathbb{R}^n$ and not on $\mathbb{T}^n \times \mathbb{R}^n \times \mathbb{R}^n_{>0}$. The resulting function S can be interpreted as a performance criterion in a similar vein as the cost function in [46]. Noting that

$$0 = -K_Q \overline{Q} - [\overline{V}](\overline{V} - \overline{u}_Q),$$

it is easy to verify that

$$T_Q \dot{V} = -K_Q [V] \frac{\partial S}{\partial V} + [V] (u_Q - \overline{u}_Q).$$
(19)

C. Reactive current controller

The frequency dynamics of the inverters in microgrids typically mimics that of the synchronous generators known as the *swing equation*. This facilitates the interface of inverters and generators in the grid. To enhance such interface, an idea is to mimic the voltage dynamics of the synchronous generators as well. Motivated by this, we consider the voltage dynamics identified by

$$f(V, Q, u_Q) = -[V]^{-1}Q + u_Q.$$
 (20)

This controller aims at regulating the ratio of reactive power over voltage amplitudes, which can be interpreted as "reactive current" ([32]). For this controller, we set

$$H = 0 \tag{21}$$

meaning that S = U and no adaption of the storage function is needed. It is easy to observe that

$$T_Q \dot{V} = -\frac{\partial S}{\partial V} + u_Q - \bar{u}_Q, \qquad (22)$$

where $\bar{u}_Q = [\overline{V}]^{-1}\overline{Q}$ is again the feedforward input guaranteeing the preservation of the steady state.

D. Exponentially-scaled averaging reactive power controller

In this subsection, we consider another controller which aims at achieving proportional reactive power sharing

$$f(V, Q, u_Q) = -[V]K_Q L_Q K_Q Q + [V]u_Q$$
(23)

where $K_Q = [k_Q]$ is a diagonal matrix and L_Q is the Laplacian matrix of a communication graph which is assumed to be undirected and connected. Compared with the controller in [42], here the the voltage dynamics is scaled by the voltages at the inverters, namely [V], the reactive power Q is not assumed to be independent of the phase variables θ , and an additional input u_Q is introduced. It is easy to see that the voltage dynamics in this case can be equivalently rewritten as

$$T_Q \dot{\chi} = -K_Q L_Q K_Q Q + u_Q$$

$$V = \exp(\chi)$$
(24)

where Q can be expressed in terms of χ as $[\exp(\chi)]\mathcal{A}(\cos(D^T\theta))\exp(\chi)$ with $\exp(\chi) = \operatorname{col}(e^{\chi_i})$. Hence, we refer to this controller as an *exponentially-scaled* averaging reactive power controller (E-ARP). Now, we choose H as

$$H(V) = -\overline{Q}^T \ln V, \qquad (25)$$

with \overline{Q} as in (7), and obtain

$$\frac{\partial S}{\partial V} = [V]^{-1} (Q - \overline{Q}). \tag{26}$$

Note that, in fact, our treatment here together with the above equality hints at the inclusion of the matrix [V] into the controller, or equivalently at an *exponential scaling* of the reactive power averaging dynamics (see (23), (24)). This, as will be observed, results in reactive power sharing for the fully coupled nonlinear model (1). By defining

$$\overline{u}_Q = K_Q L_Q K_Q \overline{Q},\tag{27}$$

the voltage dynamics can be rewritten as

$$\dot{V} = -[V]K_Q L_Q K_Q [V] \frac{\partial S}{\partial V} + [V](u_Q - \overline{u}_Q).$$
(28)

where we have set $T_Q = I$. Having unitary time constants is assumed for the sake of simplicity and could be relaxed. On the other hand, requiring them to be the same is a purely technical assumption, motivated by the difficulty of analysing the system without such condition.

E. Incremental dissipativity of microgrid models

In this subsection, we show how the candidate Bregman storage functions introduced before allow us to infer incremental dissipativity of the microgrids under the various controllers.

Theorem 1. Assume that the feasibility condition (6) admits a solution and let Assumption 1 hold. Then system (1) with output (12), input (13), and, respectively,

f(V,Q,u_Q) given by (14);
 f(V,Q,u_Q) given by (17);
 f(V,Q,u_Q) given by (20);

4) $f(V, Q, u_Q)$ given by (23);

is incrementally cyclo-dissipative with respect to a synchronous solution $(\overline{\theta}, \overline{\omega}, \overline{V})$, with

1) incremental storage function *S* defined by (8),(9),(10),(15) and supply rate (5) with weight matrices

$$W(V) = \begin{bmatrix} K_P & \mathbf{0} \\ \mathbf{0} & T_Q K_Q[V] \end{bmatrix}, \quad R = \begin{bmatrix} I & \mathbf{0} \\ \mathbf{0} & I \end{bmatrix};$$

2) incremental storage function *S* defined by (8),(9),(10),(18) and supply rate (5) with weight matrices

$$W(V) = \begin{bmatrix} K_P & \mathbf{0} \\ \mathbf{0} & T_Q K_Q[V] \end{bmatrix},$$
$$R(V) = \begin{bmatrix} I & \mathbf{0} \\ \mathbf{0} & [V] \end{bmatrix};$$

3) incremental storage function *S* defined by (8),(9),(10),(21) and supply rate (5) with weight matrices

$$W = \begin{bmatrix} K_P & \mathbf{0} \\ \mathbf{0} & T_Q \end{bmatrix}, \quad R = \begin{bmatrix} I & \mathbf{0} \\ \mathbf{0} & I \end{bmatrix};$$

4) incremental storage function *S* defined by (8),(9),(10),(25) and supply rate (5) with weight matrices

$$W(V) = \begin{bmatrix} K_P & \mathbf{0} \\ \mathbf{0} & [V] K_Q L_Q K_Q [V] \end{bmatrix}$$
$$R(V) = \begin{bmatrix} I & \mathbf{0} \\ \mathbf{0} & [V] \end{bmatrix}.$$

Proof: 1) Recall that

$$\frac{\partial S}{\partial \omega} = K_P^{-1} T_P(\omega - \overline{\omega}),$$
$$\frac{\partial S}{\partial \theta} = D\Gamma(V) \mathbf{sin}(D^T \theta) - D\Gamma(\overline{V}) \mathbf{sin}(D^T \theta^0) = (P - \overline{P}).$$
(29)

Then

$$\begin{split} &\frac{d}{dt}\mathcal{S} = (\omega - \overline{\omega})^T T_P K_P^{-1} \dot{\omega} \\ &+ (D\Gamma(V) \mathbf{sin}(D^T(\theta)) - D\Gamma(\overline{V}) \mathbf{sin}(D^T \theta^0))^T \dot{\theta} + (\frac{\partial \mathcal{S}}{\partial V})^T \dot{v} \\ &= (\omega - \overline{\omega})^T K_P^{-1} (-(\omega - \overline{\omega}) - K_P (P - \overline{P}) + (u_P - \overline{u}_P)) \\ &+ (D\Gamma(V) \mathbf{sin}(D^T \theta) - D\Gamma(\overline{V}) \mathbf{sin}(D^T \theta^0))^T (\omega - \overline{\omega}) \\ &+ (\frac{\partial \mathcal{S}}{\partial V})^T T_Q^{-1} (-K_Q [V] \frac{\partial \mathcal{S}}{\partial V} + u_Q - \overline{u}_Q) \\ &= (\omega - \overline{\omega})^T K_P^{-1} (-(\omega - \overline{\omega}) - K_P (P - \overline{P}) + (u_P - \overline{u}_P)) \\ &+ (P - \overline{P})^T (\omega - \overline{\omega}) - (\frac{\partial \mathcal{S}}{\partial V})^T T_Q^{-1} K_Q [V] \frac{\partial \mathcal{S}}{\partial V} \\ &+ (\frac{\partial \mathcal{S}}{\partial V})^T T_Q^{-1} (u_Q - \overline{u}_Q) \end{split}$$

where the chain of equalities hold because of the feasibility condition and (16). Hence

$$\frac{d}{dt}\mathcal{S} = -(\omega - \overline{\omega})^T K_P^{-1}(\omega - \overline{\omega}) + (\omega - \overline{\omega})^T K_P^{-1}(u_P - \overline{u}_P) - (\frac{\partial \mathcal{S}}{\partial V})^T T_Q^{-1} K_Q[V] \frac{\partial \mathcal{S}}{\partial V} + (\frac{\partial \mathcal{S}}{\partial V})^T T_Q^{-1}(u_Q - \overline{u}_Q).$$
(30)

Observe now that by definition

$$\frac{\partial S}{\partial V} = \frac{\partial S}{\partial V} - \left. \frac{\partial S}{\partial V} \right|_{-}$$

and that $\frac{\partial S}{\partial V}|_{-}$ represents the output component $\frac{\partial S}{\partial V}$ at a synchronous solution. Hence equality (31) at the top of the next page can be established.

We conclude incremental cyclo-dissipativity of system (1), (12), (13), (14) as claimed.

2) If in the chain of equalities defining $\frac{d}{dt}S$ above, we use (19) instead of (16), we obtain that

$$\frac{d}{dt}\mathcal{S} = -(\omega - \overline{\omega})^T K_P^{-1}(\omega - \overline{\omega}) + (\omega - \overline{\omega})^T K_P^{-1}(u_P - \overline{u}_P) - (\frac{\partial \mathcal{S}}{\partial V})^T T_Q^{-1} K_Q[V] \frac{\partial \mathcal{S}}{\partial V} + (\frac{\partial \mathcal{S}}{\partial V})^T T_Q^{-1}[V](u_Q - \overline{u}_Q)$$
(32)

which shows incremental cyclo-dissipativity of system (1), (12), (13), (17).

3) For this case, adopting the equality (22) results in the equality

$$\frac{d}{dt}\mathcal{S} = -(\omega - \overline{\omega})^T K_P^{-1}(\omega - \overline{\omega}) + (\omega - \overline{\omega})^T K_P^{-1}(u_P - \overline{u}_P) -(\frac{\partial \mathcal{S}}{\partial V})^T T_Q^{-1} \frac{\partial \mathcal{S}}{\partial V} + \frac{\partial \mathcal{S}}{\partial V}^T T_Q^{-1}(u_Q - \overline{u}_Q),$$
(33)

from which incremental cyclo-dissipativity of (1), (12), (13), (20) holds.

4) Finally, in view of (28),

$$\frac{d}{dt}\mathcal{S} = -(\omega - \overline{\omega})^T K_P^{-1}(\omega - \overline{\omega}) + (\omega - \overline{\omega})^T K_P^{-1}(u_P - \overline{u}_P) - (\frac{\partial \mathcal{S}}{\partial V})^T [V] K_Q L_Q K_Q [V] \frac{\partial \mathcal{S}}{\partial V} + (\frac{\partial \mathcal{S}}{\partial V})^T [V] (u_Q - \overline{u}_Q)$$
(34)

which implies incremental cyclo-dissipativity of (1), (12), (13), (23).

IV. FROM CYCLO-DISSIPATIVITY TO DISSIPATIVITY

The dissipation inequalities proven before can be exploited to study the stability of a synchronous solution. Recall that Theorem 1 has been established in terms of cyclo-dissipativity rather than dissipativity, i.e. without imposing lower boundedness of the storage function S. However, in order to conclude the attractivity of a synchronous solution we ask for incremental dissipativity of the system, and require the storage function to possess a strict minimum at the point of interest. To this end, we investigate conditions under which the Hessian of the storage function S is positive definite at the point of interest identified by a synchronous solution.

It is not difficult to observe that due to the rotational invariance of θ variable, the existence of a *strict* minimum for S cannot be anticipated. To clear this obstacle, we notice

$$\frac{d}{dt}\mathcal{S} = -\begin{bmatrix} (\omega - \overline{\omega})^T K_P^{-1} & (\frac{\partial S}{\partial V} - \frac{\partial S}{\partial V}\Big|_{-})^T T_Q^{-1} \end{bmatrix} \begin{bmatrix} K_P & \mathbf{0} \\ \mathbf{0} & T_Q K_Q [V] \end{bmatrix} \begin{bmatrix} K_P^{-1} (\omega - \overline{\omega}) \\ T_Q^{-1} (\frac{\partial S}{\partial V} - \frac{\partial S}{\partial V}\Big|_{-}) \end{bmatrix} + \begin{bmatrix} (\omega - \overline{\omega})^T K_P^{-1} & (\frac{\partial S}{\partial V} - \frac{\partial S}{\partial V}\Big|_{-})^T T_Q^{-1} \end{bmatrix} \begin{bmatrix} I & \mathbf{0} \\ \mathbf{0} & I \end{bmatrix} \begin{bmatrix} u_P - \overline{u}_P \\ u_Q - \overline{u}_Q \end{bmatrix}.$$
(31)

that the phase angles θ appear as relative terms, i.e. $D^T \theta$, in (8) and thus in S as well as S. Motivated by this observation, we introduce the new variables [57]

$$\varphi_i = \theta_i - \theta_n, \quad i = 1, 2, \dots, n - 1. \tag{35}$$

These can be also written as

$$\begin{bmatrix} \varphi_1 \\ \vdots \\ \varphi_{n-1} \\ 0 \end{bmatrix} = \begin{bmatrix} \theta_1 \\ \vdots \\ \theta_{n-1} \\ \theta_n \end{bmatrix} - \mathbb{1}\theta_n$$

Let us partition D accordingly as $D = col(D_1, D_2)$, with D_1 an $(n-1) \times m$ matrix and D_2 a $1 \times m$ matrix. Notice that D_1 is the reduced incidence matrix corresponding to the node of index n taken as reference. Then

$$D^{T} \begin{bmatrix} \varphi_{1} \\ \vdots \\ \varphi_{n-1} \\ 0 \end{bmatrix} = D_{1}^{T} \varphi, \text{with } \varphi := \begin{bmatrix} \varphi_{1} \\ \vdots \\ \varphi_{n-1} \end{bmatrix}$$

and therefore

$$D^T \theta = D_1^T \varphi.$$

More explicitly, given $\theta \in \mathbb{R}^n$, we can define $\varphi \in \mathbb{R}^{n-1}$ from θ as in (35), and the equality $D^T \theta = D_1^T \varphi$ holds. Hence,

$$U(\theta, \omega, V) = \frac{1}{2}\omega^T K_P^{-1} T_P \omega + \frac{1}{2} V^T \mathcal{A}(\cos(D^T \theta)) V$$
$$= \frac{1}{2}\omega^T K_P^{-1} T_P \omega + \frac{1}{2} V^T \mathcal{A}(\cos(D_1^T \varphi)) V$$

and we set, by an abuse of notation,

$$U(\varphi,\omega,V) := \frac{1}{2}\omega^T K_P^{-1} T_P \omega + \frac{1}{2} V^T \mathcal{A}(\cos(D_1^T \varphi)) V.$$

Furthermore, we can define

$$\mathcal{U}(\varphi,\omega,V) = U(\varphi,\omega,V) - U(\overline{\varphi},\overline{\omega},\overline{V}) - \frac{\partial U}{\partial \varphi}\Big|_{-}^{T}(\varphi-\overline{\varphi}) - \frac{\partial U}{\partial \omega}\Big|_{-}^{T}(\omega-\overline{\omega}) - \frac{\partial U}{\partial V}\Big|_{-}^{T}(V-\overline{V})$$
(36)

where, $\overline{\varphi}_i := \overline{\theta}_i - \overline{\theta}_n$, i = 1, 2, ..., n - 1, (hence $D^T \overline{\overline{\theta}} = D_1^T \overline{\varphi}$), and

$$\mathcal{S}(\varphi, \omega, V) = \mathcal{U}(\varphi, \omega, V) + \mathcal{H}(V)$$
(37)

to have

$$\mathcal{S}(\theta, \omega, V) = \mathcal{S}(\varphi, \omega, V). \tag{38}$$

A. Strict convexity of Bregman storage functions

Observe that $(\overline{\varphi}, \overline{\omega}, \overline{V})$ is a critical point of S. Next, we compute the Hessian as

$$\frac{\partial^2 S}{\partial(\varphi, \omega, V)^2} = \begin{bmatrix} D_1 \Gamma(V) [\cos(D_1^T \varphi)] D_1^T & \mathbf{0} & * \\ \mathbf{0} & K_P^{-1} T_P & \mathbf{0} \\ D_1 [V]^{-1} |D| \Gamma(V) [\sin(D_1^T \varphi)] & \mathbf{0} & \mathcal{A}(\cos(D_1^T \varphi)) + \frac{\partial^2 H}{\partial V^2} \end{bmatrix}$$
(39)

Notice that in all the previously studied cases, the matrix $\frac{\partial^2 H}{\partial V^2}$ is diagonal. In particular,

$$\frac{\partial^2 H}{\partial V^2} = K_Q + [V]^{-2} [\overline{Q} + K_Q^{-1} \overline{V}], \quad \frac{\partial^2 H}{\partial V^2} = K_Q^{-1},$$
$$\frac{\partial^2 H}{\partial V^2} = 0, \qquad \qquad \frac{\partial^2 H}{\partial V^2} = [V]^{-2} [\overline{Q}],$$
(40)

for conventional droop, quadratic droop, reactive current controller, and exponentially-scaled averaging reactive power controller, respectively. Now, let

$$[h(V)] := \frac{\partial^2 H}{\partial V^2},\tag{41}$$

and $h(V) = col(h_i(V_i))$. Then, the following result, which establishes distributed conditions for checking the positive definiteness of the Hessian, and hence strict convexity of the Bregman storage function, can be proven:

Proposition 1. Let $\overline{\eta} := D^T \theta^0 = D_1^T \overline{\varphi} \in (-\frac{\pi}{2}, \frac{\pi}{2})^m$, $\overline{V} \in \mathbb{R}^n_{>0}$, and

$$n_{ii} := \hat{B}_{ii} + \sum_{k \sim \{i,\ell\} \in E} B_{i\ell} \left(1 - \frac{\overline{V}_{\ell}}{\overline{V}_i} \frac{\sin^2(\overline{\eta}_k)}{\cos(\overline{\eta}_k)} \right) + h_i(\overline{V}_i).$$

Then the inequality

$$\left. \frac{\partial^2 S}{\partial (\varphi, \omega, V)^2} \right|_{-} > 0 \tag{42}$$

holds if

γ

$$m_{ii} > \sum_{k \sim \{i,\ell\} \in E} B_{i\ell} \operatorname{sec}(\overline{\eta}_k) \tag{43}$$

for all i = 1, 2, ..., n.

Proof: The proof is given in the appendix.

Remark 4. (Isolated minima) The result shows that the condition (43) for positive definiteness are met provided that at the point $(\overline{\varphi}, \overline{\omega}, \overline{V})$ the relative voltage phase angles are small enough and the voltages magnitudes are approximately the same. This is a remarkable property, stating that if the equilibria of interest are characterized by small relative voltage

phases and similar voltage magnitudes, then they are minima of the incremental storage function $S(\theta, \omega, V)$, and equivalently *isolated* minima of $S(\varphi, \omega, V)$.

Remark 5. (Hessian) The Hessian of energy functions has always played an important role in stability studies of power networks (see e.g. [52], and [41] for a microgrid stability investigation). Conditions for assessing the positive definiteness of the Hessian of an energy function associated to power networks have been reported in the literature since [52], and used even recently to study e.g. the convexity of the energy function ([24]). Our conditions however are different and hold for more general energy functions.

B. An instability condition

Conversely, one can characterize an instability condition that shows how, for a given vector of voltage values, equilibria with "large" relative phase angles are unstable. To this end, first observe that a negative eigenvalue of the Hessian matrix implies instability of the equilibrium $(\overline{\varphi}, \overline{\omega}, \overline{V})$ of system (1), with $f(V, Q, u_Q)$ given by (14), (17), (20), expressed in the φ coordinates and with $u_P = \overline{u}_P$, $u_Q = \overline{u}_Q$:

Lemma 1. Suppose that the Hessian

$$\left.\frac{\partial^2 S}{\partial(\varphi,\omega,V)^2}\right|_{-}$$

has a negative eigenvalue. Then the equilibrium $(\overline{\varphi}, \overline{\omega}, \overline{V})$ is unstable.

Proof: The proof is given in the appendix. Before providing sufficient conditions under which the Hessian in Lemma 1 has a negative eigenvalue, we first provide conditions under which the matrix at the center of the product in (44), denoted as M when evaluated at $(\overline{\varphi}, \overline{\omega}, \overline{V})$, has a negative eigenvalue. M is symmetric and as such diagonalizable. Using the diagonal form, it is immediate to notice that if there exists a vector $v = (v^{(1)}, v^{(2)}) \neq 0$ such that $v^T M v < 0$, then the matrix M has a negative eigenvalue.

A characterization of the condition $v^T M v < 0$, or equivalently the existence of a negative eigenvalue of the matrix M, is now studied. To this end, it is instrumental to introduce a class of cut-sets of the graph, as in the following definition:

Definition 2. A cut-set $K \subset E$ is said to have non-incident edges if for each $k \sim \{i, j\} \in K$ and $k \sim \{i', j'\} \in K$, with $k \neq k'$, all the indices i, j, i', j' are different from each other. The class of cut-sets with non-incident edges is denoted by \mathcal{K} .

In words, the property amounts to the following: given any two edges in the cut-set, the two pairs of end-points associated with the two edges are different from each other. The set of graphs for which these cuts exists is not empty and includes trees, rings and lattices. Complete graphs do not admit this class of cuts.

The following holds:

Lemma 2. Let $\overline{V} \in \mathbb{R}^n_{>0}$. If there exists a cut-set K in the class K such that, for all $k \sim \{i, j\} \in K$,

$$\sin(\overline{\eta}_k)^2 > \beta_k(\overline{V}_i, \overline{V}_j) \cos(\overline{\eta}_k), \tag{45}$$

where $\overline{\eta} = D_1^T \overline{\varphi}$ and

$$\beta_k(\overline{V}_i, \overline{V}_j) = 2 \max\{\frac{(B_{ii} + h_i(\overline{V}_i))\overline{V}_i}{B_{ij}\overline{V}_j}, \frac{(B_{jj} + h_j(\overline{V}_j))\overline{V}_j}{B_{ij}\overline{V}_i}\},\$$

and h_i is defined in (40), (41), then the matrix M at the center of the product in (44) evaluated at $\overline{\varphi}, \overline{V}$ has a negative eigenvalue.

Proof: The proof is given in the appendix. The two lemma above lead to the following conclusion:

Proposition 2. An equilibrium $(\overline{\varphi}, \overline{\omega}, \overline{V})$, with $\overline{V} \in \mathbb{R}^n_{>0}$, is unstable if there exists a cut-set K in the class K such that the inequality (45) holds for all $k \sim \{i, j\} \in K$.

Proof: The proof is given in the appendix. From the relation above, we see that for equilibria for which the components of \overline{V} have comparable values, inequality (45) is likely to be fulfilled as η_k diverges from 0, thus showing that equilibria with large relative phase angles are likely to be unstable.

Remark 6. (Plastic coupling strength) It is interesting to establish a connection with existing studies on oscillator synchronization arising in different contexts. Once again, this connection leverages the use of the energy function. If the coupling between any pair of nodes i, j is represented by a single variable v_{ij} , modeling e.g. a dynamic coupling, instead of the product of the voltage variables V_iV_j , then a different model arises. To obtain this, we focus for the sake of simplicity on oscillators without inertia, and replace the previous energy function (8) with

$$U(\theta, v) = -\frac{1}{2} \sum_{i=1}^{n} \sum_{j \in \mathcal{N}_i} v_{ij} B_{ij} \cos(\theta_j - \theta_i) + \frac{1}{2} \sum_{\{i,j\} \in E} v_{ij}^2.$$

Then

$$\frac{\partial U}{\partial v_{ij}} = -B_{ij}\cos(\theta_j - \theta_i) + v_{ij},$$

and the resulting (gradient) system becomes

$$\dot{\theta}_i = \sum_{j \in \mathcal{N}_i} v_{ij} B_{ij} \sin(\theta_j - \theta_i), \quad i = 1, 2, \dots, n \dot{v}_{ij} = B_{ij} \cos(\theta_j - \theta_i) - v_{ij}, \quad \{i, j\} \in E,$$

which arises in oscillator networks with so-called plastic coupling strength ([39], [27], [33]) and in the context of flocking with state dependent sensing ([39], [23], [44]). Although stability analysis of equilibria have been carried out for these systems, the investigation of the methods proposed in this paper in those contexts is still unexplored and deserves attention.

V. FREQUENCY CONTROL WITH POWER SHARING

In this section, we establish the attractivity of a synchronous solution, which amounts to the frequency regulation ($\overline{\omega} = \omega^*$) with optimal properties. Moreover, we investigate voltage stability and reactive power sharing in the aforementioned voltage controllers.

Recall from (6) that for a synchronous solution we have

$$0 = -K_P(D\Gamma(V)\mathbf{sin}(D^T\theta^0) - P^*) + \overline{u}_P.$$
(46)

$$\begin{bmatrix} D_{1}\Gamma(V)[\mathbf{cos}(D_{1}^{T}\varphi)]D_{1}^{T} & [\mathbf{sin}(D_{1}^{T}\varphi)]\Gamma(V)|D|^{T}[V]^{-1}D_{1}^{T} \\ D_{1}[V]^{-1}|D|\Gamma(V)[\mathbf{sin}(D_{1}^{T}\varphi)] & \mathcal{A}(\mathbf{cos}(D_{1}^{T}\varphi)) + \frac{\partial^{2}H}{\partial V^{2}} \end{bmatrix}$$

$$= \begin{bmatrix} D_{1} & \mathbf{0} \\ \mathbf{0} & I \end{bmatrix} \begin{bmatrix} \Gamma(V)[\mathbf{cos}(D_{1}^{T}\varphi)] & [\mathbf{sin}(D_{1}^{T}\varphi)]\Gamma(V)|D|^{T}[V]^{-1} \\ [V]^{-1}|D|\Gamma(V)[\mathbf{sin}(D_{1}^{T}\varphi)] & \mathcal{A}(\mathbf{cos}(D_{1}^{T}\varphi)) + \frac{\partial^{2}H}{\partial V^{2}} \end{bmatrix} \begin{bmatrix} D_{1}^{T} & \mathbf{0} \\ \mathbf{0} & I \end{bmatrix} > 0.$$

$$(44)$$

Among all possible vectors \overline{u}_P satisfying the above, we look for the one that minimizes the quadratic cost function

$$C(\overline{u}_P) = \frac{1}{2} \overline{u}_P^T K_P^{-1} \overline{u}_P.$$
(47)

This choice is explicitly computed as [2], [22], [51]

$$\overline{u}_P = -\mathbb{1}\frac{\mathbb{1}^T P^*}{\mathbb{1}^T K_P^{-1} \mathbb{1}}.$$
(48)

Note that in (47) any positive diagonal matrix, say Σ , could be used instead of K_P^{-1} . However, the choice $\Sigma = K_P^{-1}$ yields more compact expressions, and results in proportional sharing of the active power according the droop coefficients $k_{P,i}$, see Subsection V-A.

Replacing \overline{u}_P in (6) with its expression in (48), and replacing \overline{Q} with its explicit definition via the loopy Laplacian, the feasibility condition (6) can be restated as follows:

Assumption 2. There exist constant vectors $\overline{V} \in \mathbb{R}^n$ and $\theta^0 \in \mathbb{T}^n$ such that

$$D\Gamma(\overline{V})\mathbf{sin}(D^{T}\theta^{0}) = (I - K_{P}^{-1}\frac{\mathbb{1}\mathbb{1}^{T}}{\mathbb{1}^{T}K_{P}^{-1}\mathbb{1}})P^{*}$$
(49)

and

$$0 = f(\overline{V}, [\overline{V}]\mathcal{A}(\cos(D^T\theta^0))\overline{V}, \overline{u}_Q).$$
(50)

Remark 7. Similar to [51, Remark 5] it can be shown that if the assumption above is satisfied then necessarily $\overline{V} \in \mathbb{R}_{>0}^n$. Furthermore, in case the network is a tree, it is easy to observe that (49) is satisfied if and only if there exists $\overline{V} \in \mathbb{R}_{>0}^n$ such that

$$\|\Gamma(\overline{V})^{-1}D^{\dagger}(I - K_{P}^{-1}\frac{\mathbb{1}\mathbb{1}^{T}}{\mathbb{1}^{T}K_{P}^{-1}\mathbb{1}})P^{*}\|_{\infty} < 1,$$

with D^{\dagger} denoting the left inverse of D. In the case of the quadratic voltage droop and reactive current controllers, explicit expressions of the voltage vector \overline{V} can be given (see Subsection V-A), in which case the condition above becomes dependent on the voltage phase vector θ^0 only.

To achieve the optimal input (48), we consider the following distributed active power controller ([45], [22], [10])

$$\dot{\xi} = -L_P \xi + K_P^{-1}(\omega^* - \omega)$$

$$u_P = \xi$$
(51)

where the matrix L_P is the Laplacian matrix of an undirected and connected communication graph. Here, the term $\omega^* - \omega$ attempts to regulate the frequency to the nominal one whereas the consensus based algorithm $-L_P\xi$ steers the input to the optimal one given by (48) at steady-state. For the choice of the voltage/reactive power control u_Q , we set $u_Q = \overline{u}_Q$ where \overline{u}_Q is a constant vector enforcing the setpoint for the voltage dynamics. The role of this setpoint will be made clear in Subsection V-A. Then, the main result of this section is as follows:

Theorem 2. Suppose that the vectors $\theta^0 \in \mathbb{T}^n$ and $\overline{V} \in \mathbb{R}^n$ are such that Assumption 2 and condition (42), with $\overline{\omega} = \omega^*$, hold. Let u_P be given by (51), $u_Q = \overline{u}_Q \in \mathbb{R}^n$, and \overline{u}_P the optimal input (48). Then, the following statements hold:

- (i) The vector (D^Tθ, ω, V, ξ) with (θ, ω, V, ξ) being a solution to (1), (51), with the conventional droop controller (14), quadratic droop controller (17), or reactive current controller (20), locally⁵ converges to the point (D^Tθ⁰, ω, V, ξ).
- (ii) The vector (D^Tθ, ω, V, ξ) with (θ, ω, V, ξ) being a solution to (1), (51), with the E-ARP controller (23), locally converges to a point in the set

$$\{ (D^T \theta, \omega, V, \xi) \mid \omega = \omega^*, \xi = \overline{u}_P, \\ P = \overline{P}, L_Q K_Q Q = K_Q^{-1} \overline{u}_Q \}$$

Moreover, for all $t \geq 0$ *,*

$$\mathbb{1}^{T}K_{Q}^{-1}\ln(V(t)) = \mathbb{1}^{T}K_{Q}^{-1}\ln(V(0)).$$

Proof: First recall that $\varphi = E^T \theta$, $\overline{\varphi} = E^T \overline{\theta}$, and $D_1^T \overline{\varphi} = D^T \overline{\theta} = D^T \theta^0$ with $E^T = [I_{n-1} - \mathbb{1}_{n-1}]$ and noting that $ED_1 = D$. By the compatibility property of the induced matrix norms, we have $\|\varphi(0) - \overline{\varphi}\| \leq \|E^T\| \|\theta(0) - \overline{\theta}(0)\|$, thus showing that a choice of $\theta(0)$ sufficiently close to $\theta^0 = \theta(0)$, returns an initial condition $\varphi(0)$ sufficiently close to $\overline{\varphi}$. We then consider a solution (θ, ω, V, ξ) to the closed-loop system and express the solution into the new coordinates as $(\varphi, \omega, V, \xi)$. Define the incremental storage function

$$\mathcal{C}(\xi) = \frac{1}{2} (\xi - \overline{\xi})^T (\xi - \overline{\xi}).$$
(52)

Notice that $\overline{\xi} \in \operatorname{im} \mathbb{1}$. Then

$$\frac{d}{dt}\mathcal{C} = -(\xi - \overline{\xi})^T L_P(\xi - \overline{\xi}) - (\xi - \overline{\xi})^T K_P^{-1}(\omega - \overline{\omega})$$
$$= -(\xi - \overline{\xi})^T L_P(\xi - \overline{\xi}) - (u_P - \overline{u}_P)^T K_P^{-1}(\omega - \overline{\omega}).$$

⁵"locally" refers to the fact that the solutions are initialized in a suitable neighborhood of $(\overline{\theta}, \overline{\omega}, \overline{V}, \overline{\xi})$.

By (38), the time derivative of $S(\theta, \omega, V)$ is equal to that of $\mathcal{S}(\varphi, \omega, V)$, with φ obtained from (35), namely (with (38)) in mind)

$$\frac{d}{dt}\mathcal{S}(\theta,\omega,V) = \frac{d}{dt}\mathcal{S}(\varphi,\omega,V).$$
(53)

Hence, from the proof of Theorem 1 we infer that

$$= \frac{\frac{d}{dt}\mathcal{S}(\varphi,\omega,V)}{-(\omega-\overline{\omega})^T K_P^{-1}(\omega-\overline{\omega}) + (\omega-\overline{\omega})^T K_P^{-1}(u_P-\overline{u}_P)} - (\frac{\partial \mathcal{S}}{\partial V})^T X(V) \frac{\partial \mathcal{S}}{\partial V} + (\frac{\partial \mathcal{S}}{\partial V})^T Y(V)(u_Q-\overline{u}_Q),$$
(54)

where $X(V) = T_Q^{-1}K_Q[V], T_Q^{-1}$ or $[V]K_QL_QK_Q[V]$ and $Y(V) = T_Q^{-1}, T_Q^{-1}[V], [V]$ depending on the voltage controller adopted.

Observe that, by setting $u_Q = \overline{u}_Q$ and bearing in mind (54), the equalities (30), (32), (33), and (34) can be written in a unified manner as

$$\frac{d}{dt}\mathcal{S}(\varphi,\omega,V) = -(\omega-\overline{\omega})^T K_P^{-1}(\omega-\overline{\omega}) -\left(\frac{\partial\mathcal{S}}{\partial V}\right)^T X(V)\frac{\partial\mathcal{S}}{\partial V} + (\omega-\overline{\omega})^T K_P^{-1}(u_P-\overline{u}_P)$$

where X is a positive (semi)-definite matrix defined above. Now taking S + C as the Lyapunov function, we have

$$\frac{d}{dt}\mathcal{S} + \frac{d}{dt}\mathcal{C} = -(\omega - \overline{\omega})^T K_P^{-1}(\omega - \overline{\omega}) - \left(\frac{\partial \mathcal{S}}{\partial V}\right)^T X(V) \frac{\partial \mathcal{S}}{\partial V} - (\xi - \overline{\xi})^T L_P(\xi - \overline{\xi}).$$
(55)

By local strict convexity of S + C (thanks to (42)), we can construct a forward invariant compact level set Ω around $(\overline{\varphi}, \overline{\omega}, \overline{V}, \overline{\xi})$ and apply LaSalle's invariance principle. Notice in particular that on this forward invariant set $V(t) \in \mathbb{R}^n_{>0}$ for all $t \ge 0$. Then the solutions are guaranteed to converge to the largest invariant set where

$$\omega = \overline{\omega}$$

$$0 = L_P(\xi - \overline{\xi})$$

$$0 = \left(\frac{\partial S}{\partial V}\right)^T X(V) \frac{\partial S}{\partial V}$$
(56)

The first equality yields $\frac{\partial S}{\partial \omega} = 0$ on the invariant set. Recall that $\overline{\xi} \in \operatorname{im} \mathbb{1}$. Hence, on the invariant set, $L_P \xi = 0$ and thus $\xi = \gamma \mathbb{1}$ for some $\gamma \in \mathbb{R}$. Note that, by (51), γ has to be constant given the fact that $\omega = \omega^*$ and $L_P \xi = 0$. Also note that

$$u_P = K_P(D\Gamma(V)\mathbf{sin}(D^T\theta^0) - P^*)$$

on the invariant set. Multiplying both sides of the above equality by $\mathbb{1}^T K_P^{-1}$ yields $\gamma \mathbb{1}^T K_P^{-1} \mathbb{1} = -\mathbb{1}^T P^*$. Therefore, $\xi = -\frac{\mathbb{1}\mathbb{1}^T P^*}{\mathbb{1}^T K_P^{-1} \mathbb{1}}$, and on the invariant set, u_P is equal to the optimal input \overline{u}_P given by (48). This also means that $\frac{\partial C}{\partial \xi} = 0$. Notice that any solution $(\varphi, \omega, V, \xi)$ on the invariant set

satisfies

$$0 = -T_P^{-1} K_P E \frac{\partial S}{\partial \varphi} - T_P^{-2} K_P \frac{\partial S}{\partial \omega} + T_P^{-1} \frac{\partial C}{\partial \xi}$$

Hence, evaluating the dynamics above on the invariant set yields $\frac{\partial S}{\partial a} = 0$ noting that the matrix E has full column rank. Furthermore, by (30), (32), and (33), the matrix X(V)

is positive definite for the droop controller, quadratic droop controller, and the reactive current controller. Hence, the third equality in (56) yields $\frac{\partial S}{\partial V} = 0$ on the invariant set.

Therefore, the partial derivatives of S + C vanish on the invariant set. Now, as the solution is evolving in a neighborhood where there is only one isolated minimum $(\overline{\varphi}, \overline{\omega}, \overline{V}, \overline{\xi})$ of S + C, then the invariant set only comprises such a minimum, and therefore convergence to the latter is guaranteed. This verifies the first statement of the theorem noting that the convergence of φ to $\overline{\varphi}$ implies that of $D^T \theta$ to $D^T \theta^0$ by continuity and the equality $ED_1 = D$.

For the E-ARP controller, we have X(V)= $[V]K_QL_QK_Q[V]$ as evident from (34). Hence, by (26) and the third equality in (56), on the invariant set we obtain that

$$L_Q K_Q Q = L_Q K_Q Q. (57)$$

By (27) and (57), the vector Q satisfies on the invariant set

$$L_Q K_Q Q = K_Q^{-1} \overline{u}_Q. (58)$$

Notice that, for the E-ARP controller, we have so far shown that the solutions $(\varphi, \omega, V, \xi)$ converge to the set

$$\mathcal{Q} := \{ (\varphi, \omega, V, \xi) \in \Omega \mid \omega = \omega^*, \xi = \overline{u}_P, \\ P = \overline{P}, L_Q K_Q Q = K_Q^{-1} \overline{u}_Q \}.$$

Next, we establish the convergence of trajectories to a point in Q. To this end, we take the forward invariant set Ω sufficiently small such that

$$\frac{\partial^2 (\mathcal{S} + \mathcal{C})}{\partial (\varphi, \omega, V, \xi)^2} > 0 \tag{59}$$

for every $(\varphi, \omega, V, \xi) \in \mathcal{Q}$. Note that this is always possible by (42) and continuity. Observe that any solution $(\varphi, \omega, V, \xi)$ satisfies

$$\begin{aligned} \dot{\varphi} &= E^T K_P T_P^{-1} \frac{\partial S}{\partial \omega} \\ \dot{\omega} &= -T_P^{-1} K_P E \frac{\partial S}{\partial \varphi} - T_P^{-2} K_P \frac{\partial S}{\partial \omega} + T_P^{-1} \frac{\partial C}{\partial \xi} \\ \dot{V} &= -T_Q^{-1} X(V) \frac{\partial S}{\partial V} \\ \dot{\xi} &= -L_C \frac{\partial C}{\partial \xi} - K_P T_P^{-1} \frac{\partial S}{\partial \omega}. \end{aligned}$$

It is easy to see that every point of Q is an equilibrium of the system above, and by (59) is Lyapunov stable. In fact, by (59), the incremental storage function S + C can be analogously defined with respect to any point in Q to establish Lyapunov stability by the inequality $\dot{S} + \dot{C} \leq 0$. Therefore, the positive limit set associated with any solution issuing from a point in Ω contains a Lyapunov stable equilibrium. It then follows by [29, Proposition 4.7]⁶ that this positive limit set is a singleton which proves the convergence to a point in Q. This proves the claim in the second statement of the theorem given the relationship between θ and φ variables exploited before.

⁶For the corrected version, see the errata and addenda in http://soliton.ae.gatech.edu/people/whaddad/journal/Errata.pdf

Finally, by (27), the E-ARP controller can be written as

$$\dot{V} = -[V]K_Q L_Q K_Q (Q - \overline{Q}).$$

Hence, we have

$$\frac{d}{dt}(\mathbb{1}^T K_Q^{-1} \ln V) = \mathbb{1}^T K_Q^{-1}[V]^{-1}[V] K_Q L_Q K_Q(Q - \overline{Q}) = 0$$

as $\mathbb{1}^T L_Q = 0$, which proves that $\mathbb{1}^T K_Q^{-1} \ln(V)$ is a conserved quantity.

Remark 8. (Stability under feedforward control) When the input u_P is set to the optimal feedforward input \overline{u}_P , rather than being generated by the feedback controller (51), the closed-loop system takes the form

$$\begin{aligned} \dot{\varphi} &= E^T K_P T_P^{-1} \frac{\partial S}{\partial \omega} \\ \dot{\omega} &= -T_P^{-1} K_P E \frac{\partial S}{\partial \varphi} - T_P^{-2} K_P \frac{\partial S}{\partial \omega} \\ \dot{V} &= -T_Q^{-1} X(V) \frac{\partial S}{\partial V}. \end{aligned}$$

The same arguments as in the proof above then show that solutions to this closed-loop system locally converge to the equilibrium point $(\overline{\varphi}, \overline{\omega}, \overline{V})$. Hence, the stability of this equilibrium is an intrinsic property of the closed-loop system obtained setting $u_P = \overline{u}_P$, $u_Q = \overline{u}_Q$. The adoption of the distributed integral controller (51) is required to overcome the lack of knowledge of \overline{u}_P , which depends on global parameters.

A. Power sharing

Theorem 2 portrays the asymptotic behavior of the microgrid models discussed in this paper, namely *frequency* regulation and voltage stability. In addition, optimal active power sharing for the coupled nonlinear microgrid model (1) is achieved if the droop coefficients K_P are suitably chosen. In fact, substituting (48) into (46) yields

$$\overline{P} = P^* - K_P^{-1} \mathbb{1} \frac{\mathbb{1}^T P^*}{\mathbb{1}^T K_P^{-1} \mathbb{1}},$$

or, component-wise,

$$\overline{P}_i = P_i^* - (k_P)_i^{-1} \frac{\mathbb{1}^T P^*}{\mathbb{1}^T K_P^{-1} \mathbb{1}^T}$$

where $K_P = [k_P]$. In case droop coefficients are selected proportionally ([45], [22], [2], [10], [51]), i.e.

$$(k_P)_i P_i^* = (k_P)_j P_j^*,$$

for all i, j, we conclude that

$$(k_P)_i P_i = (k_P)_j P_j,$$

which accounts for the desired proportional active power sharing based on the diagonal elements of K_P as expected.

Next, we take a closer look at other consequences and implications of Theorem 2 for different voltage dynamics.

1) Conventional droop controller: The vectors of voltages and reactive powers converge to \overline{V} and \overline{Q} satisfying

$$K_Q \overline{Q} + \overline{V} = \overline{u}_Q \tag{60}$$

which yields

$$\frac{(k_Q)_i \overline{Q}_i + \overline{V}_i}{(k_Q)_j \overline{Q}_j + \overline{V}_j} = \frac{(\overline{u}_Q)_i}{(\overline{u}_Q)_j}.$$
(61)

This results in partial voltage regulation and reactive power sharing for the droop controlled inverters. In fact, for small values of k_Q , \overline{u}_Q regulates the voltages following (60). On the other hand, if the elements of k_Q are sufficiently large, reactive power is shared according to the elements of \overline{u}_Q as given by (61). This tunable tradeoff between voltage regulation and reactive power sharing is consistent with the findings of [47].

2) Quadratic droop controller: The vector of voltages and reactive power converge to \overline{V} and \overline{Q} with

$$K_Q[\overline{V}]^{-1}\overline{Q} + \overline{V} = \overline{u}_Q$$

This implies that

$$\frac{(k_Q)_i \overline{Q}_i + \overline{V}_i^2}{(k_Q)_j \overline{Q}_j + \overline{V}_j^2} = \frac{(\overline{u}_Q)_i}{(\overline{u}_Q)_j}$$

which again results in a partial voltage regulation and reactive power sharing by an appropriate choice of k_Q and \overline{u}_Q . Moreover, in this case, the voltage variables at steady-state are explicitly given by

$$\overline{V} = (I + K_Q \mathcal{A}(\cos(D^T \theta^0)))^{-1} \overline{u}_Q$$

3) Reactive current controller: In this case, we have

$$[\overline{V}]^{-1}\overline{Q} = \overline{u}_Q$$

which results in

$$\frac{\overline{Q_i}}{\overline{V_i}}_{\overline{Q_j}} = \frac{(\overline{u}_Q)_i}{(\overline{u}_Q)_j} = (\frac{\overline{V}_j}{\overline{V}_i}) \ (\frac{\overline{Q}_i}{\overline{Q}_j}).$$

The first equality provides the exact reactive current sharing, whereas the second equality can be interpreted as a mixed voltage and reactive power sharing condition. Moreover, the voltage variables at steady-state are given by

$$\overline{V} = \mathcal{A}^{-1}(\cos(D^T \theta^0))\overline{u}_Q.$$

4) Exponentially-scaled averaging reactive power controller: In this case, the exact reactive power sharing can be achieved as evident from the second statement of Theorem 2, with $\overline{u}_Q =$ 0. In particular, by equality (58) with $\overline{u}_Q = 0$ we obtain that

$$Q = \alpha K_O^{-1} \mathbf{1}$$

for some $\alpha \in \mathbb{R}$. Multiplying both sides of the above equality by $\mathbb{1}^T$ yields

$$\alpha = \frac{\mathbb{1}^T Q}{\mathbb{1}^T K_Q^{-1} \mathbb{1}}.$$

Clearly, $\alpha > 0$, by definition of Q and as the matrix \mathcal{A} is positive definite. Therefore, as a consequence of Theorem 2, the vector of reactive power converges to a constant vector $\widetilde{Q} \in \mathbb{R}^{n}_{>0}$ where

$$(k_Q)_i \widetilde{Q}_i = (k_Q)_j \widetilde{Q}_j, \tag{62}$$

which guarantees proportional reactive power sharing according to the elements of k_Q as desired. Notice that the quantity $\mathbb{1}^T K_Q^{-1} \ln V$ is a conserved quantity in this case. Hence, the point of convergence for the voltage variables is primarily determined by the initialization V(0).

B. Lossy lines

Under appropriate conditions, the stability of the system dynamics under the various controllers are preserved in the presence of lossy transmission lines that are homogeneous, namely whose impedences Z_{ij} equal $|Z_{ij}|e^{\sqrt{-1}\phi}$, with $\phi \in [0, \frac{\pi}{2}]$. Consistently, shunt components at the buses that are a series interconnection of a resistor and an inductor whose impedance is $\hat{r}_{ii} + \sqrt{-1}\hat{x}_{ii}$ are considered. Assuming homogeneity of the shunt elements, i.e. $\hat{r}_{ii} + \sqrt{-1}\hat{x}_{ii} = \sqrt{\hat{r}_{ii}^2 + \hat{x}_{ii}^2}e^{\sqrt{-1}\arctan\frac{\hat{x}_{ii}}{\hat{r}_{ii}}} = |Z_{ii}|e^{\sqrt{-1}\arctan\phi}$, where $\phi = \arctan\frac{\hat{x}_{ii}}{\hat{r}_{ii}}$ for all *i*, routine derivations (see e.g. [60], [35]) show that the total active and reactive power P_i^{ℓ}, Q_i^{ℓ} "exchanged" by the inverter *i* in the lossy network is equal to

 $\begin{bmatrix} P_i^\ell \\ Q_i^\ell \end{bmatrix} = \Phi(\phi) \begin{bmatrix} P_i \\ Q_i \end{bmatrix}$ (63)

where

$$\Phi(\phi) = \begin{bmatrix} \sin \phi & \cos \phi \\ -\cos \phi & \sin \phi \end{bmatrix},$$

and P_i , Q_i , have the same expressions as in (2) and (3). Hence, the matrix $\Phi(\phi)$ will modify the expressions of the active and reactive power exploited previously, and thus the frequency and voltage dynamics of the inverters will be changed accordingly, disrupting the convergence of the solutions. A natural way to counteract this modification is to exploit the inverse of $\Phi(\phi)$ and use $P^{\ell} \sin \phi - Q^{\ell} \cos \phi$ and $P^{\ell} \cos \phi + Q^{\ell} \sin \phi$, with $P^{\ell} = \operatorname{col}(P_i^{\ell})$ and $Q^{\ell} = \operatorname{col}(Q_i^{\ell})$, in (1) instead of P and Q, respectively. In this way, the *lossless* expressions of P_i and Q_i as in (2) and (3) will be recovered. Notice that, however, the implementation of these controllers requires the knowledge of the parameter ϕ which is assumed to be available. An interesting special case is obtained for $\phi = 0$ meaning that the network is purely resistive. In that case, in (1) P should be replaced by $-Q^{\ell}$, and Q by P^{ℓ} , which is consistent with the use of droop controllers in resistive networks (see e.g. [7, Sec. II.A]).

As a result of the adaptation above, the same conclusions⁷ as in Theorem 2 holds for the lossy network with modified inverter dynamics. Notice, however, that the actual active power P^{ℓ} will no longer be optimally shared in a lossy network with the conventional droop controller (14), quadratic droop controller (17), or the reactive current controller (20). Remarkably, in the case of the E-ARP controller, one can additionally prove that both active as well as reactive power sharing continues to hold. Because of its importance, the result is formalized below.

Proposition 3. Suppose that Assumption 2 with $f(V,Q,u_Q) = -[V]K_QL_QK_QQ$ and condition (42),

with $\overline{\omega} = \omega^*$ and \hat{B}_{ii}, B_{ij} replaced by $|\hat{Z}_{ii}|^{-1}, |Z_{ij}|^{-1}$, respectively, hold. Then the vector $(D^T\theta, \omega, V, \xi)$ with (θ, ω, V, ξ) a solution of

$$\begin{aligned}
\dot{\theta} &= \omega \\
T_P \dot{\omega} &= -(\omega - \omega^*) - K_P (P^\ell \sin \phi - Q^\ell \cos \phi - P^*) + u_P \\
\dot{V} &= -[V] K_Q L_Q K_Q (P^\ell \cos \phi + Q^\ell \sin \phi)
\end{aligned}$$
(64)

and u_P given by (51), locally converges to a point in the set

$$\{(D^T\theta, \omega, V, \xi) \mid \omega = \omega^*, \xi = \overline{u}_P, \\ P = \overline{P}, L_Q K_Q Q = \mathbf{0}\}$$

Moreover, $\mathbb{1}^T K_Q^{-1} \ln(V(t)) = \mathbb{1}^T K_Q^{-1} \ln(V(0))$, for all $t \geq 0$. Finally, P^{ℓ}, Q^{ℓ} converge to constant vectors $\overline{P}^{\ell}, \overline{Q}^{\ell}$ that satisfy

$$(k_P)_i \overline{P}_i^{\ell} = (k_P)_j \overline{P}_j^{\ell} (k_Q)_i \overline{Q}_i^{\ell} = (k_Q)_j \overline{Q}_j^{\ell},$$

$$(65)$$

provided that

$$\frac{(k_P)_i}{(k_P)_j} = \frac{(k_Q)_i}{(k_Q)_j}, \quad \forall i, j.$$
(66)

Proof: As remarked above, the convergence of the solutions is an immediate consequence of Theorem 2. Thus, we only focus on the power sharing property.

By condition (66) and relation (63) at steady state,

$$\overline{P}_i^{\ell} = \overline{P}_i \sin \phi + \widetilde{Q}_i \cos \phi = \frac{(k_P)_j}{(k_P)_i} \overline{P}_j \sin \phi + \frac{(k_Q)_j}{(k_Q)_i} \widetilde{Q}_j \cos \phi = \frac{(k_P)_j}{(k_P)_i} \overline{P}_j^{\ell}.$$

Similarly, for the reactive power

$$\begin{aligned} \overline{Q}_i^{\ell} &= -\overline{P}_i \cos \phi + \widetilde{Q}_i \sin \phi \\ &= -\frac{(k_P)_j}{(k_P)_i} \overline{P}_j \cos \phi + \frac{(k_Q)_j}{(k_Q)_i} \widetilde{Q}_j \sin \phi \\ &= \frac{(k_Q)_j}{(k_Q)_i} (-\overline{P}_j \cos \phi + \widetilde{Q}_j \sin \phi) \\ &= \frac{(k_Q)_j}{(k_Q)_i} \overline{Q}_j^{\ell}. \end{aligned}$$

C. Dynamic extension

Another interesting feature is that thanks to the incremental passivity property the static controller $u_Q = \overline{u}_Q$ can be extended to a dynamic controller. By Theorem 1 and keeping in mind Definition 1 together with (12) and (13), the incremental input-output pair of the voltage dynamics appears in the time derivative of the storage function S as

$$\left(\frac{\partial S}{\partial V} - \left.\frac{\partial S}{\partial V}\right|_{-}\right)^{T} T_{Q}^{-1} R_{2} (u_{Q} - \overline{u}_{Q}) \tag{67}$$

where R_2 is the lower diagonal block of R in Theorem 1. Clearly this cross term is vanished by applying the feedforward

⁷In these conditions, whenever relevant, the negative of the susceptances \hat{B}_{ii}, B_{ij} should be replaced by $|\hat{Z}_{ii}|^{-1}, |Z_{ij}|^{-1}$.

input $u_Q = \overline{u}_Q$. But an alternative way to compensate for this term is to introduce the dynamic controller

$$T_Q \dot{\lambda} = -R_2 \frac{\partial S}{\partial V}$$

$$u_Q = K_\lambda \lambda$$
(68)

for some positive definite matrix K_{λ} . Notice that that the controller above is decentralized for a diagonal matrix K_{λ} . Then, denoting the steady state value of λ by $\overline{\lambda}$, the incremental storage function $C_Q(\lambda) = \frac{1}{2}(\lambda - \overline{\lambda})^T K_{\lambda}(\lambda - \overline{\lambda})$ satisfies

$$\frac{d}{dt}C_Q = -(u_Q - \overline{u}_Q)^T T_Q^{-1} R_2 \frac{\partial S}{\partial V}$$
(69)

Note that

$$\frac{\partial S}{\partial V} = \frac{\partial S}{\partial V} - \left. \frac{\partial S}{\partial V} \right|_{-}$$

Therefore, (69) coincides with the negative of (67), and thus the same convergence analysis as before can be constructed based on the storage function $S + C + C_Q$. Consequently, the result of Theorem 2 extends to the case of dynamic voltage/reactive power controller (68). For illustration purposes, below we provide the exact expression of the controller above in case of the conventional droop controller:

$$T_Q \dot{\lambda} = -[V]^{-1} K_Q^{-1} (K_Q (Q - \overline{Q}) + V - \overline{V})$$

$$u_Q = K_\lambda \lambda$$

which by setting $K_{\lambda} = K_Q$ reduces to

$$T_Q \dot{u}_Q = -[V]^{-1} (K_Q (Q - \overline{Q}) + V - \overline{V})$$

Note that here the constant vectors \overline{V} and \overline{Q} are interpreted as the setpoints of the dynamic controller. It is easy to see that this controller rejects any unknown constant disturbance entering the voltage dynamics (14). Other possible advantages of these dynamic controllers require further investigation, which is postponed to a future research.

VI. CONCLUSIONS

We have presented a systematic design of incremental Lyapunov functions for the analysis and the design of networkreduced models of microgrids. Our results encompass existing ones and lift restrictive conditions, thus providing a powerful framework where microgrid control problems can be naturally cast. The method deals with the fully nonlinear model of microgrids and no linearization is carried out.

Two major extensions can be envisioned. The first one is the investigation of similar techniques for network-preserved models of microgrids. Early results show that this is feasible and will be further expanded in a follow-up publication. The second one is how to use the obtained incremental passivity property to interconnect the microgrid with dynamic controllers and obtain a better understanding of voltage control. Examples of these controllers are discussed in [47] but many others can be proposed and investigated.

A more general question is how the set-up we have proposed can be extended to deal with other control problems that are formulated in the microgrid literature. Furthermore, the proposed controllers exchange information over a communication network and would be interesting to assess the impact of the communication layer on the results. In that regard, the use of Lyapunov functions is instrumental in advancing such research, since powerful Lyapunov-based techniques for the design of complex networked cyber-physical systems are already available (see e.g. [17]).

APPENDIX

Proof of Proposition 1. For the sake of notational simplicity, in this proof we omit the bar from all V, φ . Clearly, the Hessian (39) is positive definite if and only if (44) holds. The latter is true if and only the matrix M below

$$\Gamma(V)[\cos(D_1^T\varphi)] \qquad [\sin(D_1^T\varphi)]\Gamma(V)|D|^T[V]^{-1} \\ [V]^{-1}|D|\Gamma(V)[\sin(D_1^T\varphi)] \qquad \mathcal{A}(\cos(D_1^T\varphi)) + \frac{\partial^2 H}{\partial V^2}$$

is positive definite. In fact recall that the matrix in (44) can be written as the product

$$\begin{bmatrix} D_1 & \mathbf{0} \\ \mathbf{0} & I \end{bmatrix} M \begin{bmatrix} D_1^T & \mathbf{0} \\ \mathbf{0} & I \end{bmatrix},$$

and our claim descends from $D_1 D_1^T$ being nonsingular, the latter holding for $D_1 D_1^T$ is the principal submatrix of the Laplacian of a connected graph. Furthermore, note that by assumption $\Gamma(V)[\cos(D_1^T\varphi)]$ is nonsingular. Then the Hessian is positive definite, or equivalently (44) holds, if and only if $\Gamma(V)[\cos(D_1^T\varphi)]$ and

$$\begin{split} \Psi(D_1^T\varphi, V) &:= \mathcal{A}(\cos(D_1^T\varphi)) + [h(V)] - [V]^{-1}|D|\Gamma(V)\\ [\sin(D_1^T\varphi)]^2 [\cos(D_1^T\varphi)]^{-1}|D|^T[V]^{-1} > 0. \end{split}$$

Introduce the diagonal weight matrix, where $\eta = D_1^T \varphi$,

$$W(V,\eta) := \Gamma(V)[\sin(\eta)]^2[\cos(\eta)]^{-1}.$$

For each $k \sim \{i, j\} \in E$, its kth diagonal element is

$$W_k(V_i, V_j, \eta_k) := B_{ij} V_i V_j \frac{\sin^2(\eta_k)}{\cos(\eta_k)}$$

Furthermore, it can be verified that

$$\begin{split} \big[|D|\Gamma(V)[\sin(\eta)]^2[\cos(\eta)]^{-1} |D|^T]_{ij} \\ &= \begin{cases} \sum_{k \sim \{i,\ell\} \in E} B_{i\ell} V_i V_\ell \frac{\sin^2(\eta_k)}{\cos(\eta_k)} & \text{if} \quad i=j\\ B_{ij} V_i V_j \frac{\sin^2(\eta_k)}{\cos(\eta_k)} & \text{if} \quad i\neq j, \end{cases} \end{split}$$

from which

$$\begin{bmatrix} [V]^{-1}|D|\Gamma(V)[\sin(\eta)]^2[\cos(\eta)]^{-1}|D|^T[V]^{-1}]_{ij} \\ = \begin{cases} \sum_{k\sim\{i,\ell\}\in E} B_{i\ell} \frac{V_\ell}{V_i} \frac{\sin^2(\eta_k)}{\cos(\eta_k)} & \text{if } i=j \\ B_{ij} \frac{\sin^2(\eta_k)}{\cos(\eta_k)} & \text{if } i\neq j. \end{cases}$$

On the other hand,

$$\begin{aligned} \left[\mathcal{A}(\cos(\eta)) + [h(V)]\right]_{ij} \\ &= \begin{cases} \hat{B}_{ii} + \sum_{\substack{k \sim \{i,\ell\} \in E \\ -B_{ij}\cos(\eta_m),}} B_{i\ell} + h_i(V_i), & \text{if } i = j \end{cases} \end{aligned}$$

with $m \sim \{i, j\} \in E$, $i \neq j$. Suppose that each diagonal entry v of matrix $\Psi(\eta, V)$ is positive, that is for each i = 1, 2, ..., n,

$$m_{ii} = \hat{B}_{ii} + \sum_{\ell=1,\ell\neq i}^{n} B_{i\ell} + h_i(V_i) - \sum_{k\sim\{i,\ell\}\in E} B_{i\ell} \frac{V_\ell}{V_i} \frac{\sin^2(\eta_k)}{\cos(\eta_k)}$$

= $\hat{B}_{ii} + \sum_{k\sim\{i,\ell\}\in E} B_{i\ell} \left(1 - \frac{V_\ell}{V_i} \frac{\sin^2(\eta_k)}{\cos(\eta_k)}\right) + h_i(V_i) > 0.$

Notice that this holds true because of condition (43). Assume also that, for each i = 1, 2, ..., n,

$$m_{ii} > \sum_{\substack{k \sim \{i,\ell\} \in E}} B_{i\ell} \left| \cos(\eta_k) + \frac{\sin^2(\eta_k)}{\cos(\eta_k)} \right|$$
$$= \sum_{\substack{k \sim \{i,\ell\} \in E}} B_{i\ell} \sec(\overline{\eta}_k),$$

which is condition (43). Then by Gershgorin theorem all the eigenvalues of the matrix $\Psi(\eta, V)$ have strictly positive real parts and the Hessian is positive definite.

Proof of Lemma 1. An incremental model of the dynamical system (1) with respect to a synchronous solution can be written as follows

$$\frac{d}{dt}(\theta - \overline{\theta}) = (\omega - \overline{\omega})$$

$$T_P \frac{d}{dt}(\omega - \overline{\omega}) = -(\omega - \overline{\omega}) - K_P(P - \overline{P}) + (u_P - \overline{u}_P)$$

$$T_Q \frac{d}{dt}(V - \overline{V}) = f(V, Q, u_Q) - f(\overline{V}, \overline{Q}, \overline{u}_Q).$$
(70)

Recalling the equalities (16), (19), (22) and (38), the system in the φ variables rewrites as

0.0

$$\dot{\varphi} = E^T T_P^{-1} K_P \frac{\partial S}{\partial \omega}$$

$$\dot{\omega} = -T_P^{-2} K_P \frac{\partial S}{\partial \omega} - T_P^{-1} K_P E \frac{\partial S}{\partial \varphi} + T_P^{-1} (u_P - \overline{u}_P)$$

$$\dot{V} = -T_Q^{-1} X(V) \frac{\partial S}{\partial V} + Y(V) (u_Q - \overline{u}_Q)$$
(71)

where

$$E = \begin{bmatrix} I_{n-1} \\ -\mathbb{1}_{n-1}^T \end{bmatrix}$$

and X and Y depend on the voltage dynamics, and are equal to the lower diagonal block of W and R in Theorem 1, respectively. The Jacobian of the right-hand side at steadystate with $u_P = \overline{u}_P$, $u_Q = \overline{u}_Q$ is

$$\begin{bmatrix} 0 & E^T T_P^{-1} K_P \frac{\partial^2 S}{\partial \omega^2} & 0 \\ -T_P^{-1} K_P E \frac{\partial^2 S}{\partial \varphi^2} & -T_P^{-2} K_P \frac{\partial^2 S}{\partial \omega^2} & -T_P^{-1} K_P D \frac{\partial^2 S}{\partial V \partial \varphi} \\ -T_Q^{-1} X(V) \frac{\partial^2 S}{\partial \varphi \partial V} & 0 & -T_Q^{-1} X(V) \frac{\partial^2 S}{\partial V^2} \end{bmatrix}$$

where we have used the fact that $\frac{\partial S}{\partial V}$ vanishes at steady state. The matrix above, denoted by \mathcal{F} , can be decomposed in the port-Hamiltonian form as

$$\mathcal{F} = \left(\mathcal{J} - \mathcal{R}(V)\right) \left. \frac{\partial^2 S}{\partial (\varphi, \omega, V)^2} \right|_{-1}$$

where

$$\mathcal{J} = \begin{bmatrix} 0 & E^T T_P^{-1} K_P & 0 \\ -K_P T_P^{-1} E & 0 & 0 \\ 0 & 0 & 0 \end{bmatrix}$$
(72)

and

$$\mathcal{R}(V) = \begin{bmatrix} 0 & 0 & 0\\ 0 & -T_P^{-2}K_P & 0\\ 0 & 0 & -T_Q^{-1}X(V) \end{bmatrix}.$$
 (73)

It is not difficult to observe that the matrix $\mathcal{J} - \mathcal{R}(V)$ is nonsingular and then by leveraging inertia theorems for matrices, [11], [37], it follows that the matrix \mathcal{F} possesses an eigenvalue in the open right half plane, and thus the equilibrium $(\overline{\varphi}, \overline{\omega}, \overline{V})$ is unstable.

Proof of Lemma 2. As before, we omit the bar from the variables. First observe that if $\overline{\eta} = D_1^T \overline{\varphi} \notin (-\frac{\pi}{2}, \frac{\pi}{2})^m$ then the top-left block of M, namely $\Gamma(V)[\cos(D_1^T \varphi)]$, has a negative eigenvalue, and this implies the existence of a vector $v \neq 0$ such that $v^T M v < 0$, thus showing that M has a negative eigenvalue. Thus, in the remaining of the proof we let $\overline{\eta} \in (-\frac{\pi}{2}, \frac{\pi}{2})^m$. We write the quadratic form as

$$\begin{aligned} v^T M v &= (v^{(1)})^T \Gamma(V) [\cos(\eta)] v^{(1)} + \\ &\quad 2 (v^{(2)})^T [V]^{-1} |D| \Gamma(V) [\sin(\eta)] v^{(1)} + \\ &\quad (v^{(2)})^T (\mathcal{A}(\cos(\eta)) + \frac{\partial^2 H}{\partial V^2}) v^{(2)}, \end{aligned}$$

where again $\eta = D_1^T \varphi$. Expanding the first term on the righthand side above, it is obtained

$$= \sum_{k \in E}^{(v^{(1)})^T} \Gamma(V) [\cos(\eta)] v^{(1)}$$

having used $\gamma_k(V) = V_i V_j B_{ij}, k \sim \{i, j\}$. The second term can be written as

$$= 2(v^{(2)})^{T}[V]^{-1}|D|\Gamma(V)[\sin(\eta)]v^{(1)}$$

=
$$2\sum_{i\in\mathcal{I}}v_{m+i}V_{i}^{-1}\sum_{k\in E}|d_{ik}|v_{k}\gamma_{k}(V)\sin(\eta_{k})$$

=
$$2\sum_{k\in E,k\sim\{i,j\}}B_{ij}\sin(\eta_{k})(v_{m+i}V_{j}+v_{m+j}V_{i})v_{k},$$

whereas the third term becomes

$$(v^{(2)})^{T} (\mathcal{A}(\cos(\eta)) + \frac{\partial^{2}H}{\partial V^{2}}) v^{(2)} = \\ \sum_{i \in \mathcal{I}} ((B_{ii} + h_{i}(V_{i}))v_{m+i}^{2} - \sum_{j \in \mathcal{I}, j \neq i, k \sim \{i, j\}} B_{ij} \cos(\eta_{k})v_{m+i}v_{m+j}) = \\ \sum_{i \in \mathcal{I}} (B_{ii} + h_{i}(V_{i}))v_{m+i}^{2} - 2\sum_{k \in E, k \sim \{i, j\}} B_{ij} \cos(\eta_{k})v_{m+i}v_{m+j}.$$

Overall we have

$$v^{T}Mv = \sum_{k \in E, k \sim \{i,j\}} B_{ij}(v_{k}^{2}V_{i}V_{j}\cos(\eta_{k}) + 2\sin(\eta_{k})(v_{m+i}V_{j} + v_{m+j}V_{i})v_{k} - 2\cos(\eta_{k})v_{m+i}v_{m+j}) + \sum_{i \in \mathcal{I}} (B_{ii} + h_{i}(V_{i}))v_{m+i}^{2}$$

To prove the existence of a negative eigenvalue of the matrix M, we look for a vector v such that $v^T M v < 0$. The candidate $v = \operatorname{col}(v^{(1)}, v^{(2)})$ is a vector whose first subvector $v^{(1)} \in \mathbb{R}^m$ is associated to the cut-set, i.e. $v_k^{(1)} = \pm 1$ if $k \in K$ and 0

otherwise, and whose second subvector $v^{(2)} \in \mathbb{R}^n$ satisfies $v_i^{(2)} \neq 0$ if and only if $i \in \mathcal{I}$ and node i is adjacent to an edge k in the cut-set K, i.e. $k \sim \{i, j\} \in K$. Bearing in mind the quadratic form derived above, the inequality $v^T M v < 0$ writes as

$$v^{T}Mv = \sum_{\substack{k \in K, k \sim \{i, j\} \\ \cdot (v_{m+i}V_j + v_{m+j}V_i)v_k - 2\cos(\eta_k)v_{m+i}v_{m+j}) +} \sum_{i \in \mathcal{I}: k \sim \{i, j\}, k \in K} (B_{ii} + h_i(V_i))v_{m+i}^2 < 0.$$

For any $k \sim \{i, j\} \in K$, if one chooses

$$v_{m+i} = V_i v_k \overline{v}_{m+i}, \quad v_{m+j} = V_j v_k \overline{v}_{m+j}$$

with $\overline{v}_{m+i}, \overline{v}_{m+j}$ to be designed later, the previous inequality is equivalent to

$$\sum_{\substack{k \in K, k \sim \{i,j\}\\ 2\cos(\eta_k)\overline{v}_{m+i}\overline{v}_{m+j} + 2\sin(\eta_k)(\overline{v}_{m+i} + \overline{v}_{m+j})) + } \sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_iV_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_iV_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_iV_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_iV_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_iV_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_iV_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_iV_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_iV_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_iV_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_iV_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_iV_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_iV_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) - \frac{1}{2}\sum_{\substack{k \in K, k \sim \{i,j\}\\ m+i}} B_{ij}V_j(\cos(\eta_k) -$$

$$\sum_{i\in\mathcal{I}:k\sim\{i,j\},k\in K} (B_{ii}+h_i(V_i))V_i^2\overline{v}_{m+i}^2 < 0.$$

Notice now that for any pair i, j such that $k \sim \{i, j\}$ with $k \in K$,

$$(B_{ii} + h_i(V_i))V_i^2 + (B_{jj} + h_j(V_j))V_j^2 \le \beta_k(V_i, V_j)B_{ij}V_iV_j,$$

which returns, by setting $\overline{v}_{m+i} = \overline{v}_{m+j} = \overline{v}_k$,

$$\sum_{k \sim \{i,j\} \in K} B_{ij} V_i V_j(\cos(\eta_k) + 2\sin(\eta_k)\overline{v}_k + \beta_k(V_i, V_j)\overline{v}_k^2) < 0,$$

where we have exploited the fact that $-2\cos(\eta_k)\overline{v}_{m+i}\overline{v}_{m+j} = -2\cos(\eta_k)\overline{v}_k^2 < 0$ for all k since $\eta_k \in (-\frac{\pi}{2}, \frac{\pi}{2})$. Hence, there exist \overline{v}_k 's such that the inequality is satisfied if the discriminants are positive, i.e. $\sin(\eta_k)^2 - \beta_k(V_i, V_j)\cos(\eta_k) > 0$ for all $k \in K$. This ends the proof.

Proof of Proposition 2. Under the given assumptions, by Lemma 2 there exists a vector $v = (v^{(1)}, v^{(2)}) \neq 0$ such that $v^T M v < 0$, where $v^{(1)}$ is the vector associated to the cut-set. Hence, it belongs to the cut-space, namely the column space of D^T or equivalently to the one of D_1^T . As a result, bearing in mind (39), (44), the inequality $v^T M v < 0$ implies $w^T \frac{\partial^2 S}{\partial (\varphi, \omega, V)^2} \Big|_{-} w < 0$ for some $w \neq 0$. In view of the symmetry of the Hessian, this in turn implies that the Hessian has a negative eigenvalue, thus proving the instability of $(\overline{\varphi}, \overline{\omega}, \overline{V})$ by Lemma 1.

REFERENCES

- A. A. Alonso, B.E. Ydstie. Stabilization of distributed systems using irreversible thermodynamics. *Automatica*, 37, 1739–1755, 2001.
- [2] M. Andreasson, D.V. Dimarogonas, H. Sandberg, K.H. Johansson. Distributed PI-control with applications to power systems frequency control. *Proceedings of the 2014 American Control Conference*, 3183– 3188, 2014.
- [3] A. Banerjee, S. Meregu, I. S. Dhilon, J. Ghosh. Clustering with Bregman divergences. JMLR, 6, 17051749, 2005.
- [4] A. Bidram, F. L. Lewis, A. Davoudi. Distributed control systems for small-scale power networks: Using multiagent cooperative control theory. *IEEE Control Systems Magazine*, 34, 6, 56–77, 2014.

- [5] S. Bolognani, S. Zampieri. A distributed control strategy for reactive power compensation in smart microgrids. *IEEE Transactions on Automatic Control*, 58, 11, 2818–2833, 2013.
- [6] H. Bouattour, J.W. Simpson-Porco, F. Dörfler, F. Bullo. Further results on distributed secondary control in microgrids. *Proceedings of the 52nd IEEE Conference on Decision and Control*, 1514–1519, 2013.
- [7] K. D. Brabandere, B. Bolsens, J. Van den Keybus, A. Woyte, J. Driesen, R. Belmans. A voltage and frequency droop control method for parallel inverters. *IEEE Transactions on Power Electronics*, 22(4), 1107–1115. 2007.
- [8] L.M. Bregman, The relaxation method of finding the common point of convex sets and its application to the solution of problems in convex programming, USSR Computational Matheematics and Mathematical Physics, 7, 3, 200-217, 1967.
- [9] M. Bürger, C. De Persis. Dynamic coupling design for nonlinear output agreement and time-varying flow control. *Automatica*, 51 (1), 210–222, 2015.
- [10] M. Bürger, C. De Persis, S. Trip. An internal model approach to (optimal) frequency regulation in power grids. In Proc. of the 21st International Symposium on Mathematical Theory of Networks and Systems (MTNS), Groningen, the Netherlands, 577–583, 2014.
- [11] D. Carlson, H. Schneider. Inertia theorems for matrices: The semidefinite case. Journal of Mathematical Analysis and Applications, 6, 3, 430–446, 1963.
- [12] Y. Censor, SA. Zenios. Parallel optimization: Theory, algorithms, and applications. Oxford University Press, USA, 1997.
- [13] M. Chandorkar, D. Divan, R. Adapa. Control of parallel connected inverters in standalone AC supply systems. *IEEE Transactions on Industry Applications*, 29, 136–143, 1993.
- [14] H.-D. Chiang, C.-C. Chu, G. Cauley. Direct stability analysis of electric power systems using energy functions: theory, applications, and perspective. *Proceedings of the IEEE*, 83, 11, 1497–1529, 1995.
- [15] N. Chopra, M.W. Spong. On exponential synchronization of Kuramoto oscillators. *IEEE Transactions on Automatic Control*, 54, 353–357, 2009.
- [16] C.-C. Chu, H.-D. Chiang. Constructing analytical energy functions for lossless network-reduction power system models: framework and new developments. *Circuits, Systems and Signal Processing*, 18, 1, 1–16, 1999.
- [17] C. De Persis, R. Postoyan. A Lyapunov redesign of coordination algorithms for cyberphysical systems. *IEEE Transactions on Automatic Control*, in press, doi 10.1109/TAC.2016.2565062.
- [18] C.A. Desoer, M. Vidyasagar. Feedback Systems: Input-Output Properties. Academic Press, New York, 1975.
- [19] W. Dib, R. Ortega, A. Barabanov, F. Lamnabhi-Lagarrigue. A "globally" convergent controller for multi-machine power systems using structurepreserving models. *IEEE Transactions on Automatic Control*, 54, 9, 2179–2185, 2009.
- [20] F. Dörfler, F. Bullo. Synchronization and transient stability in power networks and non-uniform Kuramoto oscillators. *SIAM Journal on Control and Optimization*, 50, 3, 1616–1642, 2012.
- [21] F. Dörfler, F. Bullo. Synchronization in complex networks of phase oscillators: A survey. *Automatica*, 50, 1539–1564, 2014.
- [22] F. Dörfler, J. W. Simpson-Porco, F. Bullo. Breaking the hierarchy: Distributed control & economic optimality in micro-grids. *IEEE Transactions on Control of Network Systems*, arXiv:1401.1767, 2014.
- [23] E.W. Justh, P.S. Krishnaprasad. Equilibria and steering laws for planar formations. Systems & Control Letters, 52, 1, 25–38, 2004.
- [24] K. Dvijotham, S. Low, M. Chertkov. Convexity of energy-like functions: theoretical results and applications to power system operations. arXiv:1501.04052v3, 2015.
- [25] T. Green, M. Prodanovic. "Control of inverter-based micro-grids". Electric Power Systems Research, 77, 9, 1204–1213, 2007.
- [26] J.M. Guerrero, M. Chandorkar, T. Lee, P. C. Loh. "Advanced control architectures for intelligent microgrids – Part I: Decentralized and hierarchical control". *IEEE Transactions on Industrial Electronics*, 60, 4, 1254–1262, 2013.
- [27] A. Gushchin, E. Mallada, A. Tang. Synchronization of phase-coupled oscillators with plastic coupling strength. Information Theory and Applications Workshop (ITA), 2015.
- [28] B. Jayawardhana, R. Ortega, E. Garcia-Canseco, F. Castanos. Passivity of nonlinear incremental systems: application to PI stabilization of nonlinear RLC circuits. *Systems & Control Letters*, 56 (9), 618-622, 2007.
- [29] W.M. Haddad, V.S. Chellaboina. Nonlinear dynamical systems and control: a Lyapunov-based approach, Princeton University Press, 2008.
- [30] J. H. Keenan. Availability and irreversibility in thermodynamics. British Journal of Applied Physics, 2, 183, 1951.

- [31] Y.W. Li, C.-N. Kao. An accurate power control strategy for powerelectronics-interfaced distributed generation units operating in a lowvoltage multibus microgrid. *IEEE Transactions on Power Electronics*, 24 (12), 2977–2988, 2009.
- [32] J. Machowski, J. Bialek, D.J. Bumby. Power System Dynamics: Stability and Control. 2nd ed. Wiley, 2008.
- [33] E. Mallada, A. Tang. Synchronization of weakly coupled oscillators: coupling, delay and topology. Journal of Physics A: Mathematical and Theoretical, vol. 46, no. 505101, 2013.
- [34] N. Monshizadeh, C. De Persis. Output agreement in networks with unmatched disturbances and algebraic constraints. *Proceedings 54th IEEE Conference on Decision and Control*, Osaka, Japan, arXiv: 1504.03609, 2015.
- [35] U. Münz, M. Metzger. Voltage and angle stability reserve of power systems with renewable generation. *Proceedings of the 19th IFAC World Congress*, 9075–9080, Cape Town, South Africa, 2014.
- [36] R. Ortega, M. Galaz, A. Astolfi, Y. Sun, T. Shen. Transient stabilization of multimachine power systems with nontrivial transfer conductances. *IEEE Transactions on Automatic Control*, 50, 1, 60–75, 2005.
- [37] A. Ostrowski, H. Schneider. Some theorems on the inertia of general matrices. *Journal of Mathematical analysis and applications*, 4, 1, 72– 84, 1962.
- [38] M.A. Pai. Power system stability: analysis by the direct method of Lyapunov. North-Holland Publishing Company, 1981.
- [39] L. Scardovi. Clustering and synchronization in phase models with state dependent coupling. In *Proc. IEEE Conference on Decision and Control*, Atalanta, GA, 628–632, 2010.
- [40] J. Schiffer. Stability and power sharing in microgrids. PhD thesis, TU Berlin, 2015.
- [41] J. Schiffer, R. Ortega, A. Astolfi, J. Raisch, T. Sezi. Conditions for stability of droop–controlled inverter–based microgrids. *Automatica*, 50(10):2457–2469, 2014.
- [42] J. Schiffer, T. Seel, J. Raisch, T. Sezi. Voltage stability and reactive power sharing in inverter-based microgrids with consensus-based distributed voltage control. *IEEE Transactions on Control Systems Technology*, 2015. To appear.
- [43] J. Schiffer, D. Zonetti, R. Ortega, A. Stanković, T. Sezi, J. Raisch. Modelling of microgrids – from fundamental physics and voltage sources. arXiv:1505.00136v1, 2015.
- [44] R. Sepulchre, D. Paley, N. Leonard. Stabilization of planar collective motion: All-to-all communication. *IEEE Transactions on Automatic Control*, 52, 5, 811–824, 2007.
- [45] J.W. Simpson-Porco, F. Dörfler, F. Bullo. Synchronization and power sharing for droop-controlled inverters in islanded microgrids. *Automatica*, 49, 9, 2603–2611, 2013.
- [46] J.W. Simpson-Porco, F. Dörfler, F. Bullo. Voltage stabilization in microgrids via quadratic droop control. arXiv: 1507.00431, 2015.
- [47] J.W. Simpson-Porco, Q. Shafiee, F. Dörfler, J.C. Vasquez, J.M. Guerrero, F. Bullo. Secondary frequency and voltage control in islanded microgrids via distributed averaging. *IEEE Transactions on Industrial Electronics*, to appear, doi: 10.1109/TIE.2015.2436879, 2015.
- [48] A. Pavlov, L. Marconi. Incremental passivity and output regulation. Systems & Control Letters, 57, 400–409, 2008.
- [49] G. Stan, R. Sepulchre. Analysis of interconnected oscillators by dissipativity theory. *IEEE Transactions on Automatic Control*, 52, 2, 256–270, 2007.
- [50] S. Trip, M. Bürger, C. De Persis. An internal model approach to frequency regulation in inverter-based microgrids with time-varying voltages. *Proceedings of the IEEE 53nd Conference on Decision and Control (CDC)*, 223-228, Los Angeles, CA, 2014.
- [51] S. Trip, M. Bürger, C. De Persis. An internal model approach to (optimal) frequency regulation in power grids. *Automatica*, 64, 240–253, 2016.
- [52] N.A. Tsolas, A. Arapostathis, P.V. Varaiya. A structure preserving energy function for power system transient stability analysis. *IEEE Transactions* on Circuits and Systems, 32, 10, 1041–1049, 1985.
- [53] J.C. Willems, Dissipative dynamical systems. European Journal of Control, 13(2), 134-151, 2007.
- [54] Z. Wang, M. Xia, M. Lemmon. Voltage stability of weak power distribution networks with inverter connected sources. In *Proceedings* 2013 American Control Conference, Washington, DC, USA, 6577–6582, 2013.
- [55] M.K. Warmuth. Online learning and Bregman divergences. *Tutorial at the Machine Learning Summer School*, 2006.
- [56] J.C. Willems. Dissipative dynamical systems. Part I: general theory. Archive for Rational Mechanics and Analysis, 45, 5, 321–351, 1972.

- [57] J.L. Willems. DIrect methods for transient stability studies in power system analysis. *IEEE Transactions on Automatic Control*, AC-16, 4, 332–341, 1971.
- [58] C. Zhao, E. Mallada, F. Dörfler. Distributed frequency control for stability and economic dispatch in power networks. In *Proceedings of the 2015 American Control Conference*, Chicago, IL, USA, 2359–2364, 2015.
- [59] Q.-C. Zhong. "Robust droop controller for accurate proportional load sharing among inverters operated in parallel". *IEEE Transactions on Industrial Electronics*, 60, 4, 1281–1290, 2013.
- [60] Q.-C. Zhong, T. Hornik. Control of power inverters in renewable energy and smart grid integration. John Wiley & Sons, 2012.