
DESIGN OF A SUPERVISORY CONTROL SYSTEM FOR AUTONOMOUS OPERATION OF ADVANCED REACTORS

Akshay J. Dave

Nuclear Science and Engineering
Argonne National Laboratory
Lemont, IL 60439
ajd@anl.gov

Taeseung Lee

Nuclear Science and Engineering
Argonne National Laboratory
Lemont, IL 60439

Roberto Poncioli

Nuclear Science and Engineering
Argonne National Laboratory
Lemont, IL 60439

Richard B. Vilim

Nuclear Science and Engineering
Argonne National Laboratory
Lemont, IL 60439

ABSTRACT

Advanced reactors deployed in the coming decades will face deregulated energy markets, and may adopt flexible operation to boost profitability. To aid in the transition from baseload to flexible operation paradigm, autonomous operation is sought. This work focuses on the control aspect of autonomous operation. Specifically, a hierarchical control system is designed to support constraint enforcement during routine operational transients. Within the system, data-driven modeling, physics-based state observation, and classical control algorithms are integrated to provide an adaptable and robust solution. A 320 MW Fluoride-cooled High-temperature Pebble-bed Reactor is the design basis for demonstrating the proposed control system.

The hierarchical control system consists of a supervisory layer and low-level layer. The supervisory layer receives *requests* to change the system's operating conditions (e.g., the current reactor power to meet a load-follow), and accepts or rejects them based on constraints that have been assigned. Constraints are issued to keep the plant within an optimal operating region. The low-level layer interfaces with the actuators of the system to fulfill requested changes, while maintaining tracking and regulation duties. To accept requests at the supervisory layer, the Reference Governor algorithm was adopted. To model the dynamics of the reactor, a system identification algorithm, Dynamic Mode Decomposition, was utilized. To estimate the evolution of process variables that cannot be directly measured (e.g., the propagation of delayed neutron precursors), the Unscented Kalman Filter was adopted, incorporating a nonlinear model of nuclear dynamics. The composition of these algorithms led to a numerical demonstration of constraint enforcement during a 40% power drop transient (at a rate of 5%/min). Uncontrolled secondary-side temperatures were successfully constrained. Adaptability of the proposed system was demonstrated by modifying the constraint values, and enforcing them during the transient. Robustness was also demonstrated by enforcing constraints under noisy environments.

Keywords Autonomous Operation · Constraint enforcement · Hierarchical control system design
Advanced Reactors

1 Introduction

Advanced reactors deployed in the coming decades will be operated in a grid with a greater mix of intermittent energy sources. In the United States, renewable energy is projected to compose 20% of the energy production mix by 2050 [1], a significant rise from 5% in 2010, and 10% currently. The production from nuclear power plants (NPP) is expected to stay roughly flat or decline. Besides the well-know high upfront capital costs, a reason of this trend might stem from the profitability issues that currently operated Light Water Reactors have been facing in the last years. One late 2018 study found that more than one-third of units is unprofitable or scheduled to close [2]. It has been projected that flexible operation, as opposed to the current baseload operation paradigm, in a grid with significant intermittent sources, will reduce operating costs of NPPs and make nuclear energy a more competitive source [3]. When operated in flexible mode, the plant is expected to routinely undergo load-follow transients to meet the load demand fluctuations. During these transients, the thermal-hydraulic and neutronic conditions of the NPP will change and require operators to adapt and carefully steer the plant. To relieve human operators from this burden autonomous operation of advanced NPPs is sought.

The safe and reliable operation of an NPP requires effective teamwork, i.e., the collaboration between the operators in the Main Control Room and the on-site technicians is the best way to produce power with fewer errors, events, and improved performance. Similarly, implementation of the “autonomous operation” paradigm requires a tight integration of modules performing control, diagnostics and decision-making tasks. The diagnostics module is tasked with processing sensor data and inferring the health and the performance of components, sensors and actuators. The decision-making module is tasked with assigning high-level reference setpoints for the plant, e.g., changing the current reactor power to meet a demand variation. The control module is tasked with steering the plant, coordinating control actions for all major actuators to address the setpoints that have been assigned, while meeting the constraints that have been assigned by the diagnostics module. This work is focused on the design of a supervisory control system addressing the objectives of the control module.




Figure 1: Graphical abstract of the application of a supervisory controller during a load-follow transient. The supervisory controller steers the plant within the optimal operating region to meet high-level demands, while enforcing assigned constraints.

Supervisory control architectures have been proposed in the past [4, 5]. In this work, a supervisory control system consists of a two-tier hierarchy: the supervisory layer and the low-level layer. The supervisory layer is tasked with accepting or rejecting changes in high-level reference setpoints from a decision-making algorithm or human operator, e.g., a change in reactor power during a load-follow transient. The acceptance or rejection is based on a quantitative trade-off of addressing requested changes to the system, while meeting the imposed constraints. The output of the supervisory layer is sent to the low-level layer. The low-level layer is constituted by controllers that operate in tracking or regulation mode. Tracking controllers always accept changes in setpoints from the supervisory layer, e.g., a proportional-integral-derivative (PID) controller to decrease reactor power via reactivity insertion. Regulation controllers maintain setpoints, e.g., PID control of a pump to maintain core inlet temperature via pump head manipulation. The supervisory concept of accepting or rejecting changes in power during operational transients is visualized in Fig. 1. It is envisioned that a NPP would be requested to reduce its power output in the morning when solar photovoltaic sources peak. During this transient, the state and dynamics of the system change as the power is reduced. NPPs are under-actuated systems, i.e., the number of available actuators is lower than the number of process variables to be controlled. Thus, there may be process variables that cannot be controlled directly, e.g., temperatures in the secondary-side, that would

deviate from their full-power values. To reduce thermo-mechanical stresses and limit wear & tear, excessive variations of these process variables should be avoided. An optimal operation region must be provided to the supervisory controller. It quantitatively defines the bounds by which the supervisory controller can accept or reject changes to the high-level setpoints, such that constraints are not violated. In Fig. 1, a decrease from 100 % to 60 % load is requested. However, due to an assigned constraint(s), power is not decreased below 65 %. The supervisory controller intervenes to avoid violating a constraint that has been issued by the operators, and the plant remains in the optimal operation region. The intent of the supervisory layer is not to be a replacement for safety related interventions (conditions where the plant protection system (PPS) will trip the plant, i.e., outside of the yellow region in Fig. 1), but rather optimizing dynamics within the normal operation region.

The **objective** of this work is to design and demonstrate a supervisory control system that allows constraint enforcement during the load-follow transient for an advanced NPP. In Section 2, performance of an advanced NPP under classic

control is presented. To address the shortcomings of classic control, a supervisory control system with constraint enforcement capability is designed. In order to develop the constraint enforcement capability envisioned, two major components are needed. First, a forward dynamics model to accurately propagate the state of the system given a set of control actions. Second, a method to quantitatively assign the admissible region given a set of constraints. The methods that form the supervisory control system are presented in Section 3. In Section 4, performance of the plant under supervisory control is presented. Lastly, concluding remarks and future work is described in Section 5.

2 Classic Control of an Advanced Reactor

To demonstrate the need for a supervisory control layer, the performance of an advanced reactor under classical control methods is presented. In this work, the Fluoride-cooled High-Temperature pebble-bed Reactor (FHR) design is chosen (it is also the design basis for Kairos Power [6], an advanced NPP developer). Significant efforts at Argonne National Laboratory [7, 8] have been directed at developing a generic FHR (gFHR) model to foster the design and safety analyses of the FHR concept. To simulate the response of the selected design during operational transients, a high-fidelity model was developed by adopting the System Analysis Module (SAM) [9] system code. SAM is developed to provide best-estimate system-level models for Sodium-cooled Fast Reactors, Molten Salt Reactors, Fluoride-cooled High-temperature Reactors, and Lead-cooled Fast Reactors. The gFHR is a hypothetical 320 MWth reactor with a flibe primary loop, and a solar salt intermediate loop. The reactor core and plant design choices are detailed in [8, §3]. A Reactor Cavity Cooling System (RCCS) is incorporated in the model. The RCCS system has tall chimneys exposed to the environment (air) to aid buoyancy driven passive cooling of the reactor vessel in case of an accident. In Fig. 2, the piping and instrumentation diagram (P&ID) for the gFHR model is presented. Currently, SAM does not support modeling of the Rankine cycle components. To mimic the presence of an energy conversion cycle, a pipe with a fixed heat transfer coefficient is present between the intermediate heat exchanger and the intermediate salt pump.




Figure 2: Overview of the gFHR SAM model. Left: Piping and instrumentation diagram for the gFHR model. States that are required by the supervisory algorithm are identified in purple and actuators that are used to control the plant are identified in red. The control strategy and selection of states is discussed in Sections 2.1 and 3.3, respectively. Right: A list of full power values corresponding to the labels in the left-hand side diagram.

2.1 Control Strategy for Load-follow

Advanced nuclear power plants are expected to routinely undergo load-follow transients on a daily, even hourly, basis. These transients can be challenging from a thermal stress management perspective. Undergoing cyclical changes in baseload power, on the order of tens to hundreds of Mega Watts, would result in thermal stresses on components throughout the primary circuit. To demonstrate the feasibility of flexible operation paradigm and reduce O&M costs, these cyclical stresses must be minimized. At the extremes, we want to mitigate the possibility of thermal-fatigue induced failure leading to outages or accidents [10].

In this work, we have designed a control strategy that mitigates thermal cycling during load-follow. The quantitative objective of the control strategy will be to regulate core inlet and outlet temperatures during load-follow. In order to

manipulate the reactor power, external reactivity insertion will be used to address requests in load increase/decrease. Pumps on both primary and secondary sides will then be used to manage heat transfer rates across the primary heat exchanger. The pairings of the Control Variables (CVs) to Manipulated Variables (MVs) were chosen to maximize the effects of the performed control actions and to minimize cross-talk. Pairings are tabulated in Table 1.

1. The reactor power (\dot{Q}_{RX}) is controlled by external reactivity insertion (ρ_{ext}).
2. The core outlet temperature ($T_{c,out}$) is controlled by the primary pump head (ΔP_p).
3. The core inlet temperature ($T_{c,in}$) is controlled by the solar salt pump head (ΔP_s).

Once the appropriate pairing option is selected, three PID controllers were designed, i.e., two PID controllers regulate the core outlet and inlet temperatures, and a PID controller tracks the reactor power. The PID controllers were manually tuned, first by following the Ziegler-Nichols [11] guidance for PI controllers, followed by fine-tuning via a grid search of the proportional and integral gains. The derivative term is nullified for all controllers.

Table 1: Pairing of control variables (CV) to manipulated variables (MV) to address objectives of the control strategy.

CVs	MVs
ρ_{ext}	\dot{Q}_{RX}
ΔP_p	$T_{c,out}$
ΔP_s	$T_{c,in}$

A requirement for applying the proposed supervisory control system is defining constraints to be applied to both input and output variables. Any number of constraints may be applied, and they may be constant or time-dependent. The latter is a powerful capability in the perspective of developing an Autonomous Operation architecture. If the control system is coupled to a diagnostics/prognostics system, constraints may be updated, e.g., due to degradation of the component performance (e.g., leaks in a pump or fouling of a heat exchanger). The proposed control strategy foresees three major actuators to govern the thermal and the nuclear aspects of the primary loop. However, the secondary side of the plant is not directly controlled. In Fig. 3, the bottom row shows that the secondary inlet and outlet temperatures ($T_{s,in}$ and $T_{s,out}$), reach new equilibrium values after the transient is completed. Experimental studies show that corrosion of metals in contact with salt is strongly dependent on temperature [12, 13], and that optimal operating temperatures to mitigate weight loss exist. Thus, issuing constraints to avoid excessive temperature variations would be a practical application of the supervisory control system. Two constraints are adopted on the secondary side: a minimum temperature constraint on the heat-exchanger inlet and a maximum temperature constraint on the heat-exchanger outlet. The results from enforcing these constraints using the supervisory layer will be presented in Section 4.2.

2.2 Plant Performance during Load Follow

In this section, the performance of the gFHR during the load-follow transient, *without a supervisory layer*, is discussed. Throughout all cases studied, the rate at which power drops is 5%/min. As discussed in the previous subsection, three PID controllers are implemented to adjust the reactor power while maintaining the core outlet and inlet temperatures close to the full power values to preserve the thermal conditions in the reactor core.

In Fig. 3, the plant response is presented for multiple transients, ranging from a 5% to 40% drop in nominal power. As the reactor power drops (Fig. 3A), there is a large reactivity insertion due to the moderator density feedback (Fig. 3C) and a lesser coolant density feedback (Fig. 3D). At the peak of the 40% power drop, almost -0.18 \$ of external reactivity insertion (Fig. 3B) is required. The peak total reactivity ($\rho_{\Sigma} = \rho_{ext} + \rho_m + \rho_c$, Fig. 3E) is approximately -1.65 \$. As reactor power drops, two PID controllers decrease the head supplied by the primary and secondary pumps (Fig. 3G and J, respectively), decreasing the primary and secondary mass flow rates (Fig. 3H and K, respectively). Despite the initial undershoots, the response of core outlet and core inlet temperature (Fig. 3F and I, respectively) remains within 1 °C. However, there are no active controllers to keep the secondary-side temperatures constant during the transient. The inlet and outlet temperatures at the secondary-side heat exchanger (Fig. 3L and M, respectively) reach a new equilibrium value once the transient is complete. For a 40% power drop, $T_{s,in}$ decreases by approximately 2.2 °C, and $T_{s,out}$ increases by approximately 6.0 °C. Since the gFHR system is underactuated, i.e., the available actuators are fewer than the process variables that we would like to control, a *supervisory layer is necessary* to constrain the variations of $T_{s,in}$ or $T_{s,out}$.




Figure 3: Dynamic response of the gFHR model for 5% to 40% power drops. Subplots A to E: controlled response of the reactor power along with the reactivity components (external reactivity insertion, moderator feedback, coolant feedback, and total reactivity). Subplots F to K: controlled response of core inlet and outlet temperatures through primary and secondary circuit pump actuation. Subplots L and M: uncontrolled response of secondary-side heat exchanger inlet and outlet temperatures. Subplots that are outputs of PID controllers are annotated with a “PID(-) Output”.

3 Methods

To address the objectives of this work, several algorithms were integrated. First, the algorithm chosen to enforce constraints, the Reference Governor, is described in Section 3.1. The algorithm to identify the state-space representation matrices, Dynamic Mode Decomposition with Control, is described in Section 3.2. The feature selection algorithm utilized to define the constituents of the dynamics model, Sequential Feature Selection, is described in Section 3.3. The feature selection procedure indicated that some unobserved variables (e.g., delayed neutron precursor concentrations) were optimal candidates for the dynamics model. Thus, a non-linear Kalman Filter, the Unscented Kalman Filter, was implemented, discussed further in Section 3.4. Finally, the composition of the supervisory control system architecture is outlined in Section 3.5.

3.1 Constraint Enforcement

The Reference Governor (RG) [14] is the constraint enforcement algorithm utilized in this work. The RG is an *add-on* control scheme that enforces *point-wise in time* constraints. The terminology *add-on* reflects the nature of its intended use: the algorithm is applied to a system that already has an existing closed-loop feedback system (e.g., PID controllers for regulation). The add-on feature is important as an operator may choose to manually override the RG, while maintaining controllability to maneuver the plant manually. The terminology *point-wise in time* reflects the capability to update constraint bounds at each discrete time-step. This feature allows addressing process drift scenarios, e.g., degradation phenomena. The application of the RG is visualized in Fig. 4. The RG algorithm is described in detail in the rest of the section. Garone et al. [15] provide a full review of the RG algorithm family (and contrast the RG to Model Predictive Control in [15, §6.1]). In general terms, the RG acts as an agent that checks whether the requested setpoint variation violates pre-defined constraint(s) on the system. The RG accomplishes this quantitatively by utilizing a surrogate model of the system, and propagating it forward in time.




Figure 4: Block diagram visualizing the topology of the proposed supervisory control system. The placement of the supervisory and low-level layers is highlighted. Direct access to the underlying closed-loop system is always available by bypassing the supervisory layer.

To gain some intuition, the basic form of the RG algorithm, the Scalar RG (SRG) is explained. At each time-step $k \in \mathbb{Z}_+$, the SRG receives a reference input, $r_k \in \mathbb{R}^m$, where m is the number of inputs. Depending on the current state of the system, expected evolution, and user-defined constraints, an admissible input $v_k \in \mathbb{R}^m$,

$$v_k = v_{k-1} + \kappa_k (r_k - v_{k-1}), \quad (1)$$

is sent to the low-level controllers. In Eq. (1), $\kappa_k \in [0, 1]$ is a *scalar* that governs admissible changes to the inputs, such that a complete rejection, $v_k = v_{k-1}$, acceptance, $v_k = r_k$, or an intermediate change, $v_{k-1} \leq v_k \leq r_k$, is possible. After determining κ_k , the output of the RG, v_k is sent to the existing controllers. For example, a PID controller would receive a component of v_k as a reference set-point for its manipulated variable (MV), and according to its paired MV's current value, issue a control action u_k to the control variable (CV).

Next, the steps to evaluate κ_k are summarized. The RG relies on a state-space representation,

$$x_{k+1} = Ax_k + Bu_k, \quad (2)$$

$$y_k = Cx_k + Du_k, \quad (3)$$

where $x_k \in \mathbb{R}^n$, $u_k \in \mathbb{R}^m$, and $y_k \in \mathbb{R}^p$ are vectors at step k representing states, inputs, and outputs, respectively. The matrix $A \in \mathbb{R}^{n \times n}$ accounts for the state dynamics. The matrix $B \in \mathbb{R}^{n \times m}$ is the input matrix. The matrix $C \in \mathbb{R}^{p \times n}$ is the output matrix. The matrix $D \in \mathbb{R}^{p \times m}$ is the control pass-through matrix. Using the system model defined in Eqs. (2) and (3), constraints are imposed on the output variables, $y_k \in Y$, where Y is defined by a set of linear

inequalities. Constraints may be imposed on x_k , or u_k . To ensure constraints are not violated, we define the maximal output admissible set (MOAS), or admissible region. The admissible region is the set of all x_k , and constant input \tilde{v} , such that,

$$O_\infty = (x_k, \tilde{v}) : y_{t+k} \in Y, v_{t+k} = \tilde{v}, \forall k \in \mathbb{Z}^+ . \quad (4)$$

The $k \rightarrow \infty$ assumption of O_∞ is generally relaxed to a suitably large finite horizon, T . Thus, at each time-step k , the SRG algorithm determines the admissible \tilde{v} , and therefore κ_k , such that the system remains in O_∞ . The O_∞ is constructed by evaluating Eqs. (2) and (3) for each $k = 0, 1 \dots T$ time steps. In Fig. 1, the optimal operating region was qualitatively introduced to constrain the plant dynamics during operational transients. Now, the optimal operating region can be quantitatively represented by the admissible region.

The RG formulation can also account for process and output disturbances. To account for these disturbances, Eqs. (2) and (3) are modified,

$$x_{k+1} = Ax_k + Bu_k + B_w w_k , \quad (5)$$

$$y_k = Cx_k + Du_k + D_w w_k , \quad (6)$$

where B_w and D_w are process and output disturbance matrices. Additionally, w_k , is a scalar representing a bounded disturbance, $w_k \in W$, where W is a compact set containing the origin, e.g., $W = [-1, 1]$. The definition of the admissible region in Eq. (4) is modified such that,

$$O_\infty = (x_k, \tilde{v}) : \tilde{y}_{t+k} \subseteq Y, v_{t+k} = \tilde{v}, \forall k \in \mathbb{Z}^+ , \quad (7)$$

where \tilde{y}_k is a set-valued prediction of the output accounting for all possible disturbances. Because Eqs. (5) and (6) are linear, the set of inequalities imposed (Y) are modified to account for these disturbances [15, §2.2].

A drawback of the SRG formulation is that κ_k is a scalar. Therefore, if $v_k - r_k$ is multi-dimensional and $\kappa_k < 1$, input variation in all dimensions is bounded. In [16], constraint enforcement for multiple inputs was demonstrated for a molten salt loop, using the Command Governor, a variant of the RG which selects v_k by solving a quadratic program. In this work, as the high-level input is a scalar, the SRG is sufficient.

3.2 System Identification

To predict system response and detect potential violation of imposed constraints, the RG algorithm needs a state-space representation of the system. In this work, Dynamic Mode Decomposition with Control (DMDc) [17] is the system identification algorithm that is used to define the A and B matrices in Eq. (2). DMDc is an extension of Dynamic Mode Decomposition (DMD), a method that originated in the fluids community to extract spatial-temporal coherent structures from experimental data. Qualitatively, the DMDc methodology combines Singular Value Decomposition (dimensionality reduction) with a Fourier transform (finding dominant patterns in time). DMDc is a data-driven method relying on a temporal sequence of data, of length L . The history of states is grouped into matrices,

$$X' = \begin{bmatrix} | & | & \cdots & | \\ x_1 & x_2 & & x_L \\ | & | & & | \end{bmatrix} , \quad (8)$$

$$X = \begin{bmatrix} | & | & \cdots & | \\ x_0 & x_1 & & x_{L-1} \\ | & | & & | \end{bmatrix} , \quad (9)$$

and the history of inputs into matrix,

$$\Upsilon = \begin{bmatrix} | & | & \cdots & | \\ u_0 & u_1 & & u_{L-1} \\ | & | & & | \end{bmatrix} . \quad (10)$$

Each transient was 2000 s long with a time-step of 0.2 s. The evolution of the system is represented by,

$$X' = AX + B\Upsilon , \text{ or,} \quad (11)$$

$$X' = G\Omega , \quad (12)$$

where $G = [A \ B]$ and $\Omega = [X^\top \Upsilon^\top]^\top$. To find the reduced order approximations of matrices A and B [17, §3.3], solve for G ,

$$G = X'\Omega^\dagger , \quad (13)$$

where the superscript \dagger represents the psuedoinverse of a matrix.

3.3 State Selection

The RG algorithm requires that Eq. (2) accurately represents the dynamics of the system. To correctly model the dynamics of the system, optimally selecting the composition of states, \mathbf{x}_k , is critical. However, with 102 process variables to choose from, a systematic feature selection algorithm is necessary. In this work, the Sequential Forward Floating Selection (SFFS) feature selection algorithm [18] is used. The pseudocode for the SFFS algorithm is listed in Algorithm 1. First, the set of state variables, H , that must always be included are defined. Next, the set of all possible supplemental states, Y , is defined. There were a total of 8 states defined in H , therefore there were a total of 94 supplemental states to choose from. The candidate process variables were mass flow rates, temperature and pressure measurements, delayed neutron precursor concentration (discussed further in the next section), heat transfer rates across heat exchanger and steam generator (\dot{Q}_{HX} and \dot{Q}_{SG}), pump heads, and PID controller components. After defining H and Y , the set of supplemental candidates, X_k , is incrementally expanded until the maximum number of variables, k_T , is reached. The optimal candidate at each iteration, k , is determined by assessing the objective function,

$$J(X_k) = \frac{1}{N} \sum_n^N \left(\frac{1}{2} r_{tr}(x_i) + \frac{1}{2} r_{te}(x_i) \right), \quad (14)$$

where $x_i \in H + X_k$, r is a residual function that is assessed on training (r_{tr}) and test (r_{te}) data, and N is the total number of unique trajectories used for evaluating r . The mean square error and coefficient of determination (R^2) were used as candidate residual functions to quantify the accuracy of DMDc vs. SAM data. Due to the significant variation in scales (e.g., pressure vs. temperature), the mean square residual components were normalized individually. However, the coefficient of determination metric still provided superior results.

Algorithm 1 Sequential Forward Floating Selection

Inputs:

$$H = \{h_1, h_2, \dots, h_d\}$$

$$Y = \{y_1, y_2, \dots, y_e\}$$

$$k_T$$

Initialize:

$$k \leftarrow 1$$

$$X_0 \leftarrow \emptyset$$

while $k \neq k_T$ **do**

$$x^+ \leftarrow \operatorname{argmin}_x J(H + X_k + x), \text{ where } x \in Y - X_k$$

$$X_{k+1} \leftarrow X_k + x^+$$

$$k \leftarrow k + 1$$

if floating **then**

$$x^- \leftarrow \operatorname{argmin}_x J(H + X_k - x), \text{ where } x \in X_k$$

if $J(X_k - x) > J(X_k)$ **then**

$$X_{k-1} \leftarrow X_k - x^-$$

$$k \leftarrow k - 1$$

end if

end if

end while

The results from applying the the SFFS algorithm are discussed next. The 8 state variables in H were \dot{m}_p , \dot{m}_s , $T_{c,in}$, $T_{c,out}$, $P_{c,in}$, $P_{c,out}$, $T_{s,in}$, and $T_{s,out}$ (identified in Fig. 2). A total of 22 unique trajectories were generated for training. On each SFFS iteration, the DMDc algorithm is applied to the training data, and then the objective function is calculated, Eq. (14). The maximum objective function value at each SFFS iteration, and its spread across cross-validation sets, is presented in Fig. 5. The objective function increases drastically after introducing two delayed neutron precursor groups (C_1 and C_3), and climaxes once the heat transfer rate across the heat-exchanger (\dot{Q}_{HX}) is added. Increasing X_k beyond $k = 6$ results in deteriorating performance, with very high variance across cross-validation datasets. These results indicate that there is a quantitatively optimal point achieved at $k = 4$. However, at $k = 5$, addition of the heat transfer rate across the heat-exchanger (\dot{Q}_{SG}) led to more conservative predictions of temperatures, with similar regression performance. Therefore, C_1 , C_2 , C_3 , \dot{Q}_{HX} , and \dot{Q}_{SG} were chosen as the complimentary state variables to H .

3.4 State Observer

The variables that were added to H included unobserved (or latent) variables, such as the delayed neutron precursor (DNP) group concentration. These variables cannot be directly measured. To retrieve their values, state observers such




Figure 5: To determine the optimal composition of X_k , the SFFS algorithm (Algorithm 1) is used. For each size of X_k , the maximum achievable objective value, J_{X_k} (Eq. (14)), is presented. The shaded regions indicate one standard deviation across 3 cross-validation sets. Inset is the performance for sets $X_k : k \in \{2, 3, \dots, 6\}$. Below the inset, the optimal composition for each X_k is presented.

as the Kalman Filter (KF) must be used. Recent work by Bhatt et al. [19] studied the experimental observation of reactivity using the Extended Kalman Filter (EKF). While the KF is restricted to linear dynamical systems, the EKF observes non-linear dynamical systems. The major disadvantage of the EKF is that it requires explicit definition of Jacobians. Instead, in this work, the Unscented Kalman Filter (UKF) is adopted [20]. The UKF samples the non-linear process model, and approximates the Jacobians. Therefore, in order to use the UKF, a non-linear process model representing the nuclear reactor dynamics is required.

The non-linear dynamical model used by SAM to simulate nuclear reactor dynamics is presented next. The 6-group point kinetics equation (PKE) is defined by,

$$\frac{dn}{dt} = \frac{\rho - \beta}{\Lambda} n + \sum_{i=1}^6 \lambda_i C_i, \quad (15)$$

$$\frac{dC_i}{dt} = \frac{\beta_i}{\Lambda} n - \lambda_i C_i, \quad (16)$$

where n is the reactor power, ρ is the reactivity, β is the total DNP fraction ($\beta = \sum_{i=1}^6 \beta_i$), Λ is the prompt neutron generation time, λ_i is the i -th DNP group decay constant, and C_i is the i -th delayer neutron precursor group concentration. In Eqs. (15) and (16), β_i , λ_i , and Λ are constants determined a priori via high-fidelity neutronics models (e.g., Monte Carlo neutron transport) and depend on the reactor design. To model reactivity, a first order power series [21] is chosen,

$$\rho = \alpha + \omega t, \quad (17)$$

where α represents an instantaneous increase in ρ , and ω represents the slope of reactivity increase. Eqs. (15) to (17) can be written in the state space form,

$$\frac{d\mathbf{x}}{dt} = \mathbf{A}\mathbf{x} + \mathbf{B}, \quad (18)$$

where,

$$\mathbf{A} = \begin{bmatrix} -\beta/\Lambda & \lambda_1 & \lambda_2 & \lambda_3 & \lambda_4 & \lambda_5 & \lambda_6 & 0 & 0 \\ -\beta_1/\Lambda & -\lambda_1 & 0 & 0 & 0 & 0 & 0 & 0 & 0 \\ -\beta_2/\Lambda & 0 & -\lambda_2 & 0 & 0 & 0 & 0 & 0 & 0 \\ -\beta_3/\Lambda & 0 & 0 & -\lambda_3 & 0 & 0 & 0 & 0 & 0 \\ -\beta_4/\Lambda & 0 & 0 & 0 & -\lambda_4 & 0 & 0 & 0 & 0 \\ -\beta_5/\Lambda & 0 & 0 & 0 & 0 & -\lambda_5 & 0 & 0 & 0 \\ -\beta_6/\Lambda & 0 & 0 & 0 & 0 & 0 & -\lambda_6 & 0 & 0 \\ 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 1 \\ 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 \end{bmatrix}, \text{ and,} \quad (19)$$

$$\mathbf{B} = \left[\frac{\rho n}{\Lambda} \quad 0 \right]^T. \quad (20)$$

To proceed with the implementation, Eq. (18) must be transformed from the continuous to the discrete space. We use the integral approximation method to discretize the continuous equations, and assume a zero-order hold for the constants in between the sampling period. The resulting equations are,

$$\mathbf{x}_{k+1} = e^{\mathbf{A}\Delta t} \mathbf{x}_k + \int_0^{\Delta t} e^{\mathbf{A}t} \mathbf{B} dt, \quad (21)$$

where \mathbf{x}_k is the state at time-step k , and Δt is the size of the discrete time-step. To use the UKF, Eqs. (19) to (21) are provided as the discrete state transition function. The measurement function returns n to the filter (in an operating reactor, this measurement would come from ex-vessel neutron detectors). Van der Merwe's algorithm [22] was used to generate Sigma Points (with parameters $\alpha = 0.001$, $\beta = 2.0$, $\kappa = 0$).

The application of the UKF algorithm during operational transients is discussed next. In Fig. 7, a transient featuring a reduction to 82.5% of nominal power, following an increase back to 95% power is presented. The agreement between the UKF estimates and the true values for all DNP groups (Fig. 7B to G) and the total reactivity insertion (Fig. 7H) is satisfactory, as quantified by the mean-square error. To assess the performance in noisy environments, white gaussian noise with $\sigma = 0.001$ was added to the measurements of n . In Fig. 8, the UKF estimates during the same transient, except with noise, are presented. While the error in predicting the DNP remains consistently low (Fig. 8B to G), there is a significantly larger error in predicting the total reactivity insertion (Fig. 8H). This result indicates that while DNP group concentration would be a good candidate for state variables, in noisy environments, the total reactivity feedback would be a poor choice or would require further denoising.

3.5 Proposed Control System Architecture

The selection of state variables indicated that the inclusion of DNPs is important for an accurate DMDC model of the gFHR. To infer DNPs evolution, the non-linear state observer must be embedded. To incorporate the UKF into the control system, the configuration proposed in Fig. 4 needs to be modified to that in Fig. 6. The UKF will require a single output from the plant, i.e., the power measurement. A subset of the UKF predictions chosen by the feature selection algorithm, $C_{1 \rightarrow 3}$, will update their respective value in the overall state of the plant. The notation x_k represents the entire set of state variables, whereas \hat{x}_k represents a subset predicted by the UKF. An additional block, "SGF", is upstream of the RG block. The Savitzky-Golay Filter (SGF) is a denoising filter that will be introduced further in Section 4.3.




Figure 6: Block diagram visualizing the topology of the Reference Governor (RG) in conjunction with the Unscented Kalman Filter (UKF). A partial subset of the full state set, x_k , is predicted by the UKF algorithm, \hat{x}_k . Under the presence of noise, all outputs are denoised using the Savitzky-Golay filter (SGF).




Figure 7: Application of the UKF algorithm for estimating unobserved variables in the non-linear 6-group PKE.




Figure 8: Application of the UKF algorithm with white noise added to the power measurement.

4 Supervisory Control of an Advanced Reactor

This section will focus on applying the supervisory control system to the 100 % to 60 % load-follow transient, the most aggressive drop in power considered.

4.1 Accuracy of DMDc Models

First, the accuracy of the forward dynamics model, the DMDc model, is discussed. In Fig. 9, the responses of the state variables predicted by the DMDc model are presented. Quantitatively, there is a very low mean square error in prediction of almost all variables. The only variables where the quantitative and qualitative propagation could potentially improve are the core inlet and outlet temperatures (Fig. 9C and D, respectively). There is a physical reason




Figure 9: Assessment of the DMDc model accuracy during the 40 % load-follow transient. Gray box presents the reference input that is shared between all results in this section. Remaining plots display contrast of the propagation of states between the SAM model and the DMDc model. The mean square error, ϵ_{MSE} , is inset in the subplot of each state.

that can explain why these variables are more difficult to model by adopting a linear system, i.e., Eq. (2). As noted in Section 2, the gFHR model includes RCCS. The RCCS system is passively driven by buoyancy, which is directly impacted by the heat loss through the reactor vessel. The relationships between power generated, reactor vessel heat loss, and RCCS are not linear, and so is the heat transfer rates out of the reactor vessel during load-follow operation.

The non-linearity would impact temperature propagation in the primary side, i.e., $T_{c,in}$ and $T_{c,out}$. The secondary side temperatures (Fig. 9G and H) are also impacted, but to a much lesser extent.

For the present purposes, the DMDc model provides a good approximation of the plant dynamics. Thus, the RG algorithm can use the system identified using the DMDc algorithm to enforce constraints. It is important to note that while the RG algorithm uses the DMDc model to approximate O_∞ , the resulting control signal (v_k in Fig. 6) is sent to the SAM model. In other words, while a linear surrogate is used to approximate the bounds of the admissible region in Fig. 1, the final control action is sent to a non-linear, high-fidelity model of the FHR. Therefore, the proceeding results are all outputs from SAM – not the DMDc model.

4.2 Application of the Supervisory Layer

The application of the supervisory layer to enforce constraints is presented next. The selected state variables (Section 3.3), the reference input to the RG, and the constrained variables are tabulated in Table 2. The state values, x_k , are used as

Table 2: State, input and constrained variables assigned to the RG algorithm.

States – x_k	Inputs – r_k	Constrained Variables
$\dot{m}_p, \dot{m}_s,$ $T_{c,in}, T_{c,out},$ $P_{c,in}, P_{c,out},$ $T_{s,in}, T_{s,out},$ $C_1, C_2, C_3,$ $\dot{Q}_{HX}, \dot{Q}_{SG}$	$\dot{Q}_{RX,Ref}$	$T_{s,out} \leq T_{s,out}^{\max}$ $T_{s,in} \geq T_{s,in}^{\min}$ $\delta v_{\dot{Q}_{RX}} \leq \delta v_{\dot{Q}_{RX}}^{\max}$

an initial condition at each time step k by the RG to determine if a constraint would be violated due to a change in the reference input r_k . Note that the reference input, r_k , only consists of the reactor power ($\dot{Q}_{RX,Ref}$), as both pumps are used for regulation only. In the control strategy (Section 2.1), it was decided that $T_{s,in}$ and $T_{s,out}$ are appropriate candidates to constrain during load-follow. Thus, the constraints applied are,

$$T_{s,in}^{\min} = \begin{cases} 428.23 \text{ }^\circ\text{C}, & t \leq 700 \text{ s} \\ 427.98 \text{ }^\circ\text{C}, & t > 700 \text{ s} \end{cases}$$

and $T_{s,out}^{\max} = 474.43 \text{ }^\circ\text{C}$. The value for $T_{s,in}^{\min}$ is time-dependent to assess the adaptability of the supervisory layer. Additionally, a constraint is applied to the rate of variation of reactor power between timesteps, $\delta v_{\dot{Q}_{RX}}$. The maximum value is set to $\delta v_{\dot{Q}_{RX}}^{\max} = 16 \text{ MW/min}$ (or 5% nominal power per minute). This constraint is imposed to prevent large reactivity insertions.

The results of applying the supervisory layer during the load-follow transient are presented in Fig. 10. Throughout the transient, the constraint applied to $T_{s,out}$ (Fig. 10H) is not active. Thus, the following discussions will focus on $T_{s,in}$ (Fig. 10G). In the Inputs subplot (Fig. 10N), it is shown that the admitted change in setpoint sent to the low-level controllers varies from the reference trajectory. An intervention preventing the reactor power from further decreasing occurs at approximately 347 s. In the $T_{s,in}$ subplot, the point at which this occurs is annotated as ‘‘First RG Intervention’’, and it occurs before the constraint threshold is violated. However, as time progresses, the state of the system continues to evolve and eventually $T_{s,in} \approx T_{s,in}^{\min}$. Therefore, there is a lag between the first intervention in change of reactor power occurring and the value of the constrained process variable settling around the constraint value. Physically, there is a transport lag between changes in the reactor power and changes in temperature measurements in the secondary-side of the plant. This delay is accurately captured by the DMDc model and aids in enforcing the constraint via the RG.

In Section 3.1, the point-wise in time capability of the RG was outlined. During the transient, the $T_{s,in}^{\min}$ constraint is updated at 700 s to be 0.25 $^\circ\text{C}$ lower. The RG algorithm immediately takes advantage of this additional region available to decrease the reactor power further to meet the reference setpoint, while adhering to the $\delta v_{\dot{Q}_{RX}} \leq \delta v_{\dot{Q}_{RX}}^{\max}$ constraint. A second RG intervention occurs afterwards. Again, there is a delay in the intervention occurring and the $T_{s,in}$ state value settling around $T_{s,in}^{\min}$. The capability of updating constraints during transients is important when the control system is coupled to other modules (e.g., updating constraints due to a diagnosis algorithm). The resulting supervisory control system is adaptable, as it allows addressing constraint updates from auxiliary algorithms.




Figure 10: Application of the supervisory layer to enforce constraints on the heat-exchanger secondary-side inlet and outlet temperatures. Gray box contrasts the reference requested input value (“Ref.”) against the admitted input value (“RG”). Remaining plots display changes in state propagation as the constraints on $T_{s,in}$ and $T_{s,out}$ are enforced by the RG. Plots of $T_{s,in}$ and $T_{s,out}$ display the constraints provided to the RG algorithm.

4.3 Accommodating Sensor Noise

The RG formulation accommodates process and output disturbances. The former may be utilized when there is uncertainty in the definition of the dynamics model, Eq. (2); the latter may be utilized when there is noise in the measurements of outputs, Eq. (3). Both equations are modified, Eqs. (5) and (6), to account for disturbances. The RG addressing these disturbances is known as “Robust RG”. In this section, the capability to account for output noise is exclusively explored. The capability is incorporated due to a pragmatic need – ultimately, the proposed control system would be applied to physical systems that are monitored with sensors subject to aleatoric noise. To simulate output disturbances, Gaussian white noise is added to all outputs, tabulated in Table 3. The output disturbances are assigned to the matrix D_w in Eq. (6). Noise is also added to n sent to the UKF, as in Fig. 8, indirectly adding noise to $\hat{C}_{1 \rightarrow 3}$. All noisy measurements are processed by the Savitzky-Golay filter (SGF) [23], with a 299 step window length, a third order polynomial fit, and derivatives disabled. The final configuration of the supervisory control system was presented in Fig. 6. The UKF provides a prediction for $\hat{C}_{1 \rightarrow 3}$ and sends the prediction to the SGF. The measured state variables

Table 3: Gaussian white noise added to output measurements during the load-follow transient.

Output	3σ disturbance
\dot{m}_p, \dot{m}_s	15 kg/s
$T_{c,in}, T_{c,out}, T_{s,in}, T_{s,out}$	0.5 °C
$P_{c,in}, P_{c,out}$	0.1 kPa
$\dot{Q}_{HX}, \dot{Q}_{SG}$	1.0 kW
n (Eq. (15))	0.003

are directly sent to the SGF. The SGF output (denoised state estimates) is then used by the RG algorithm to determine the admissible changes in input value.

The results of applying the robust RG algorithm with noisy output measurements is discussed next. In Fig. 11, the raw




Figure 11: Application of the supervisory control system under the presence of sensor noise. Gray box contrasts the reference input value (“Ref.”) against the admitted input value without noise (“RG”), and the admitted input value under sensor noise (“Robust RG”). Remaining plots display evolution of state variables for the case without noise (“RG”) and the case with noise (“Robust RG”). The unfiltered noisy data is also presented for each state (“Raw noisy data”).

noisy output measurements sent to the UKF and SGF is presented for each x_k . First, the differences in admissible input

(Fig. 11N) is discussed. The Robust RG input is more conservative than the previous results. The reason for why the admissible changes are more conservative is apparent in inspection of the $T_{s,in}$ plot (Fig. 11G). Due to the additional conservatism, even the raw noisy output measurements of $T_{s,in}$ meet the constraint $T_{s,in} \leq T_{s,in}^{\min}$. What this implies is that if the system designer would want the RG algorithm to be conservative, i.e., only trust the sensor measurements, the admissible region will severely contract. On the other hand, if there is high confidence in the filtered output signals, the admissible region would be larger. The visualization of the quantitative change in admissible region is discussed in the next section.

4.4 Quantitative Representation of the Admissible Region

In the Introduction, the problem of assigning a quantitative feasible region during transients was qualitatively visualized in Fig. 1. The objective of this work was to develop and demonstrate a supervisory control system that allows constraint enforcement during operational transient for an advanced NPP. Given the state-space representation model of the studied system and a set of constraints expressed as linear inequalities, the RG allows quantifying the admissible region and predicting the occurrence of constraint violations, Eqs. (4) and (7). In Fig. 12, the evolution of the admissible region during the 40 % power drop load-follow transient is presented. The noise-free case is discussed first. At the beginning of the transient, there is a large margin between the bounds of the admissible region, and the reference setpoint (r_k). In other words, if the supervisory controller allows the requested change in the high-level system input ($v_k = r_k$), no violation of constraint will occur as $t \rightarrow \infty$. At approximately 347 s, the first RG intervention occurs, annotated in Fig. 12. At this point, the reference setpoint intersects the boundary of the admissible region. The RG algorithm intervenes and does not admit further changes in v_k . As shown in Fig. 10, although this intervention occurs before the $T_{s,in} \geq T_{s,in}^{\min}$ constraint, as time progresses the equilibrium value of $T_{s,in} \approx T_{s,in}^{\min}$. At 700 s, the value of $T_{s,in}^{\min}$ is decreased, and an expansion of the admissible region is realized, allowing further reduction in v_k .




Figure 12: Quantitative evolution of the admissible region (O_∞) during the load-follow transient. Left: Evolution of O_∞ during the load-follow transient under noise-free output measurements. The occurrence of the first RG intervention and constraint update is annotated. Right: Evolution of O_∞ during the load-follow transient under the presence of output noise. There is a significant contraction in the admissible region as the constraints are applied to the raw (noisy) output signals.

The changes in evolution of the admissible region under the presence of output noise is discussed next. In Fig. 12, it is apparent that the presence of noise results in a more chaotic evolution of the feasible region. To quantify the admissible region, O_∞ , the current state of the system, x_k , is required (Eq. (7)). In the robust RG application, the output measurements are sent to the SGF before the RG block (Fig. 6). Some of the noise that is artificially added to the raw output is still present in the denoised state value (Fig. 11). This noise cause the O_∞ boundary itself to be noisy. Thus, there are two major outcomes from introducing noise in the output measurements. First, there is a significant contraction in the feasible region as the RG is tasked to enforce $T_{s,in} \geq T_{s,in}^{\min} + 3\sigma_T$ (where σ_T is the standard deviation of the Gaussian noise added to temperature measurements, Table 3). Second, the evolution of the O_∞ is noisy as further decreases in v_k is only admitted once the noisy state of the system, x_k , permits further changes.

4.5 Advantages & Drawbacks of Proposed Framework

The following are advantages of the proposed framework:

- **Adaptable constraint enforcement:** The admissible region is defined from the dynamics of the system and the constraints assigned. The RG algorithm allows a point-wise in time enforcement of these constraints. Thus, the imposed limits can be updated during operation, either manually by an operator or by a diagnostics module. The admissible region will then be updated, and the RG will modify the high-level reference setpoints. This capability was demonstrated in Section 4.2 and visualized in Section 4.4. The ability to enforce time-dependent constraints makes the overall control system adaptable to changing system dynamics and sensor & actuator performance.
- **Noise handling:** The RG formulation allows for an explicit assignment of output and process disturbances to quantitatively contract or expand the admissible region. This capability was demonstrated in Section 4.3. The ability to account for disturbances is a significant advantage of the RG algorithm. Additionally, the anticipated output disturbance that is assigned in Eq. (5) can also be updated. For example, if a diagnostics module detects that a thermocouple has degraded, the admissible region would be updated to account for the additional uncertainty in measurements.
- **Hierarchical control:** The proposed architecture is constituted by a supervisory layer and a low-level controller layer (Fig. 4). The former is tasked with admitting changes to high-level reference setpoints, whereas the latter has tracking and regulation duties. This separation allows the low-level controllers to be tuned and optimized independently. In the event that manual operation is desired, the supervisory layer can be bypassed. This is a significant benefit over end-to-end control paradigms, e.g., model predictive control, where the high-level inputs and low-level actuation are handled by a single algorithm.

Additionally, the following are drawbacks of the proposed control system:

- **Static system matrices:** Currently, the matrices identified by the DMDc algorithm are used by the RG algorithm via Eqs. (2) and (4). The matrices are not updated during the load-follow transient. This modeling choice implies that a *constant* linear approximation is used to describe the dynamics of the gFHR. This is valid on short time-scales, but it might be inaccurate for larger time-scales (weeks to months) as the dynamics of a physical plant might change, e.g., due to fuel burnup or accumulation of fouling. A dedicated procedure for updating the state-space matrices must be incorporated.

5 Concluding Remarks

To make advanced reactors more competitive in deregulated power markets characterized by a significant presence of intermittent energy sources, flexible operation is sought. Autonomous control during routine power transients will relieve plant operators from repetitive, error-prone task and might help them determining the optimal course of action. In this work, the operation of a 320 MW Pebble-bed Fluoride-cooled High-temperature reactor is studied. The reactor is modeled using the best-estimate system-code SAM. During the load-follow transient, several process variables are carefully controlled to ensure thermal hydraulic and neutronic conditions in the primary circuit. However, there are several uncontrolled process variables that deviate significantly from their steady-state 100 % load values.

In this work, a supervisory control system to constrain load changes that might cause excessive variations of uncontrolled process variables is designed. To achieve this objective, several algorithms were integrated. The RG algorithm was used as the supervisory layer to quantify the admissible region given a set of constraints, and accept or reject changes in high-level inputs. The DMDc algorithm was used as a data-driven approach to system identification. The SFFS algorithm was used to identify the appropriate set of process variables to be modeled by the DMDc algorithm. The UKF algorithm was used to infer unobserved DNP values using the non-linear 6-group PKE model. The SGF was used to denoise signals. The integration of these algorithms successfully realized the abstract objective in Fig. 1 to a quantitative result in Fig. 12. The supervisory control system was able to intervene during the 40% power drop load-follow transient to avoid violation of temperature constraints assigned to the secondary loop. The constraints were also updated during the transient to demonstrate adaptability. Under the presence of sensor noise, the robustness of the control system was demonstrated as well. Advantages of the proposed control system are summarized in Section 4.5.

There are other tasks towards achieving autonomous operation for advanced reactors. There are auxiliary tasks that can be incorporated into the overall autonomous operation framework. For example, diagnosing the degradation of an actuator (e.g., pumps or valves), or component (e.g., heat exchanger) performance can inform the supervisory layer on constraints that need to be updated or added. Additionally, the application of the supervisory control system to a physical system is necessary to assess its capabilities. A large concern would have been the impact of sensor noise,

which has been mitigated with the demonstration of the robust RG. Finally, as elaborated in Section 4.5, a procedure to update the state-space representation over long time-scales, must be explored.

Acknowledgements

This work is supported by U.S. Department of Energy Advanced Research Projects Agency–Energy Project 2174-1556, and U.S. Department of Energy Nuclear Energy Enabling Technologies Project 20-19321.

References

- [1] Bipartisan Policy Center. Annual energy outlook 2022. *Energy Information Administration, Washington, DC*, 2022.
- [2] Steve Clemmer, Jeremy Richardosn, Sandra Sattler, and Dave Lochbaum. The nuclear power dilemma. *Union of Concerned Scientists*, 2018.
- [3] Jesse D Jenkins, Zhi Zhou, Roberto Ponciroli, Richard B. Vilim, Francesco Ganda, Fernando de Sisternes, and Audun Botterud. The benefits of nuclear flexibility in power system operations with renewable energy. *Applied energy*, 222:872–884, 2018.
- [4] PJ Otaduy, CR Brittain, LA Rovere, and NB Gove. A distributed hierarchical architecture of expert systems for supervisory control of multimodular nuclear reactors. Technical report, Oak Ridge National Laboratory, 1991.
- [5] Sacit M Cetiner, Michael D Muhlheim, Askin Guler Yigitoglu, Randall Randy J Belles, Michael Scott Greenwood, Thomas Jay Harrison, Richard S Denning, Christopher A Bonebrake, Gerges Dib, David Grabaskas, et al. Supervisory control system for multi-modular advanced reactors. Technical report, Oak Ridge National Laboratory, 2016.
- [6] Edward Blandford, Kyle Brumback, Lambert Fick, Craig Gerardi, Brandon Haugh, Elizabeth Hillstrom, Kevin Johnson, Per F Peterson, Floren Rubio, Fatih S Sarikurt, et al. Kairos power thermal hydraulics research and development. *Nuclear Engineering and Design*, 364:110636, 2020.
- [7] Guojun Hu, Daniel O’Grady, Ling Zou, and Rui Hu. Development of a reference model for molten-salt-cooled pebble-bed reactor using sam. Technical Report ANL/NSE-20/31, Argonne National Laboratory, 2020.
- [8] Daniel O’Grady, Travis Mui, Alvin Lee, Ling Zou, Guojun Hu, and Rui Hu. Sam code enhancement, validation, and reference model development for fluoride-salt-cooled high-temperature reactors. Technical Report ANL/NSE-21/15, Argonne National Laboratory, 2021.
- [9] Rui Hu, Ling Zou, Guojun Hu, Daniel Nunez, Travis Mui, and Tingzhou Fei. SAM Theory Manual. Technical Report ANL/NSE-17/4, Argonne National Laboratory, 2017.
- [10] Klaus J. Metzner and U Wilke. European therfat project—thermal fatigue evaluation of piping system “tee”-connections. *Nuclear Engineering and Design*, 235(2-4):473–484, 2005.
- [11] Chang C Hang, Karl Johan Åström, and Weng Khuen Ho. Refinements of the ziegler–nichols tuning formula. In *IEE Proceedings D (Control Theory and Applications)*, volume 138, pages 111–118. IET, 1991.
- [12] Piyush Sabharwall, Denis Clark, Michael Glazoff, Guiqiu Zheng, Kumar Sridharan, and Mark Anderson. Advanced heat exchanger development for molten salts. *Nuclear Engineering and Design*, 280:42–56, 2014.
- [13] Guiqiu Zheng, Brian Kelleher, Guoping Cao, Mark Anderson, Todd Allen, and Kumar Sridharan. Corrosion of 316 stainless steel in high temperature molten Li_2BeF_4 (flibe) salt. *Journal of Nuclear Materials*, 461:143–150, 2015.
- [14] Alberto Bemporad and Edoardo Mosca. Constraint fulfillment in control systems via predictive reference management. *Proceedings of the IEEE Conference on Decision and Control*, 3:3017–3022, 1994. ISSN 01912216. doi:10.1109/CDC.1994.411327.
- [15] Emanuele Garone, Stefano Di Cairano, and Ilya Kolmanovsky. Reference and command governors for systems with constraints. *Automatica*, 75:306–328, 2017. ISSN 00051098. doi:10.1016/j.automatica.2016.08.013.
- [16] Akshay J. Dave, Haoyu Wang, Roberto Ponciroli, and Richard B. Vilim. Numerical Demonstration of Multiple Actuator Constraint Enforcement Algorithm for a Molten Salt Loop. *American Nuclear Society Annual Meeting 2022*, 2022. doi:10.48550/ARXIV.2202.02094.
- [17] Joshua L. Proctor, Steven L. Brunton, and J. Nathan Kutz. Dynamic mode decomposition with control. *SIAM Journal on Applied Dynamical Systems*, 15(1):142–161, 2016. ISSN 15360040. doi:10.1137/15M1013857.

- [18] Pavel Pudil, Jana Novovičová, and Josef Kittler. Floating search methods in feature selection. *Pattern recognition letters*, 15(11):1119–1125, 1994.
- [19] T. U. Bhatt, S. R. Shimjith, A. P. Tiwari, K. P. Singh, S. K. Singh, Kanchhi Singh, and R. K. Patil. Estimation of sub-criticality using extended Kalman filtering technique. *Annals of Nuclear Energy*, 60:98–105, oct 2013. ISSN 0306-4549. doi:10.1016/J.ANUCENE.2013.04.028.
- [20] Simon J Julier and Jeffrey K Uhlmann. New extension of the kalman filter to nonlinear systems. In *Signal processing, sensor fusion, and target recognition VI*, volume 3068, pages 182–193. International Society for Optics and Photonics, 1997.
- [21] Joseph C. Venerus and Thomas E. Bullock. Estimation of the dynamic reactivity using digital kalman filtering. *Nuclear Science and Engineering*, 40(2):199–205, 1970. doi:10.13182/NSE70-A19682.
- [22] Rudolph Van Der Merwe. *Sigma-point Kalman filters for probabilistic inference in dynamic state-space models*. Oregon Health & Science University, 2004.
- [23] Abraham Savitzky and Marcel JE Golay. Smoothing and differentiation of data by simplified least squares procedures. *Analytical chemistry*, 36(8):1627–1639, 1964.