

Security Decisions for Cyber-Physical Systems based on Solving Critical Node Problems with Vulnerable Nodes

Jens Otto¹, Niels Grüttemeier¹, Felix Specht¹

¹Fraunhofer IOSB-INA, Lemgo, Germany

jens.otto@iosb-ina.fraunhofer.de, niels.gruettemeier@iosb-ina.fraunhofer.de, felix.specht@iosb-ina.fraunhofer.de

Abstract

Cyber-physical production systems consist of highly specialized software and hardware components. Most components and communication protocols are not built according to the Secure by Design principle. Therefore, their resilience to cyberattacks is limited. This limitation can be overcome with common operational pictures generated by security monitoring solutions. These pictures provide information about communication relationships of both attacked and non-attacked devices, and serve as a decision-making basis for security officers in the event of cyberattacks. The objective of these decisions is to isolate a limited number of devices rather than shutting down the entire production system. In this work, we propose and evaluate a concept for finding the devices to isolate. Our approach is based on solving the CRITICAL NODE CUT PROBLEM WITH VULNERABLE VERTICES (CNP-V)—an NP-hard computational problem originally motivated by isolating vulnerable people in case of a pandemic. To the best of our knowledge, this is the first work on applying CNP-V in context of cybersecurity.

Introduction

Cyber-physical systems combine physical processes with computation (Leitão et al. 2016) and are networks of software and hardware components (Lee 2008). A subset of cyber-physical systems are cyber-physical production systems, they are in the focus of initiatives such as the Germany’s platform Industrie 4.0 or the US Industrial Internet Consortium. Their main feature is flexibility to quickly adapt to new plant topologies (Rehberger, Spreiter, and Vogel-Heuser 2016) and the integration of value-added services such as condition monitoring (Specht et al. 2018), or optimization (Otto and Niggemann 2015; Otto, Vogel-Heuser, and Niggemann 2018). This requires a high degree of interconnections between components (Wollschlaeger, Sauter, and Jasperneite 2017).

Cyber-physical production systems consist of highly specialized software and hardware components, such as programmable logic controller (PLCs), input or output devices (IO-Devices), and appliances. However, most components and communication protocols are not built according to the Secure by Design principle which limits their resilience to cyberattacks (Specht, Otto, and Eickmeyer 2022). This limitation can be overcome with common operational pictures.

They summarize the situation, update data on changing situations, exchanges data with internal and external systems, and collects information (Kim et al. 2023). Security officers can then use these operational pictures to make decisions in the event of cyberattacks. Figure 1 illustrates the relation between security monitoring, common operational pictures and decisions. Security monitoring systems consist of three main components.




Figure 1: Scope of this work: relation between security monitoring, common operational picture and decisions.

Asset discovery: Passive and active network analysis extract information about the used hardware and software components. Passive network analysis identifies basic component information, e.g. IP addresses and used protocols. Then active methods are used to gain specific component information, e.g. article number and device class. Please note that only devices are considered in the following.

Network topology: Passive network analysis is used to identify the communication relations between devices. Please note that specific communication protocols, such as SSH, OPC UA, Profinet or Ethercat, and their mapping to communication relations are not part of this work, only the relation knowledge is used.

Attack classification: Cyberattacks are detected and classified according to the MITRE ATT&CK framework (Al-Shaer, Spring, and Christou 2020; Specht, Otto, and Ratz 2023). Please note, that specific cyberattacks are not part of this work, only the knowledge of which devices are part

a of a cyberattack is used. The involved devices are marked with * (see. Figure 1) and named attacked devices.

The common operational picture consolidates information from asset discovery, network topology, and attack classification. It provides an overview of the devices, their communication relations and their classification as attacked or not-attacked. In the event of a cyberattack, a security officer can choose between two decisions:

Decision 1 (Worst-case): The security officer shuts down the production system. It is the worst-case decision, because depending on the production process, it takes days or weeks to restart the production system.

Decision 2 (Best-case): The security officer isolates only a limited number of devices. It is the best-case decision, because the production is not shut down. While the intuitive solution is to remove all attacked devices marked with a *, it is not always an optimal decision.

In this work, a new computational problem, named SECURITY NODE PROBLEM WITH VULNERABLE VERTICES (SNP-V), is introduced to model this decision task. The solutions provided by SNP-V enable a security officer to isolate certain devices in order to reduce the impact of a cyber-attack on a production system.

Related Work

This section describes the related work by initially introducing relevant approaches within the context of security applications, followed by the background of the CRITICAL NODE PROBLEM.

Security games have commonly been used for modeling security applications and determining optimal strategies for both defenders and adversaries (Rosenfeld and Kraus 2017; Kamra et al. 2018). A particular variant is network security games, which focus on the allocation of resources to network nodes or edges (Wang, Liu, and Shroff 2017). The concept of sharing defensive resources and reallocating resources on nodes in network security games has been introduced as a strategy to defend against contagious attacks (Li, Tran-Thanh, and Wu 2020; Bai et al. 2021). The application of deep learning to network security games has been increasingly proposed, aiming to discover optimal resource utilization strategies (Xue, An, and Yeo 2022; Li et al. 2023). In network security, one commonly considered problem is the graph reachability reduction, where defenders aim to eliminate specific nodes or edges in order to prevent attacks (Sheyner et al. 2002). Zheng et al. 2011 introduce a solution based on binary edge classification for unknown edge costs. An associated approach involves utilizing the inverse geodesic length metric to identify and eliminate the most critical nodes or edges within a compromised network (Najeebullah 2018; Gaspers and Najeebullah 2019). Guo et al. 2022; 2023 investigate edge blocking in network graphs and propose different solution strategies based on both reinforcement learning and mixed-integer programming.

The CRITICAL NODE PROBLEM (CNP) is an NP-complete graph problem (Arulselvan et al. 2009). It is studied extensively from an algorithmic point of view (Summa,

Grosso, and Locatelli 2011; Addis, Summa, and Grosso 2013; Hermelin et al. 2016). The problem finds application in several fields: In road networks it is used to plan emergency evacuations in disaster cases (Vitoriano et al. 2011); In context of cybersecurity it can be used to detect important vertices in a network that need to be protected (Lalou, Tahraoui, and Kheddouci 2018). The CRITICAL NODE PROBLEM WITH VULNERABLE VERTICES (CNP-V) is a generalization of the critical node problem and is originally motivated by isolating a vulnerable group of people in a social network in case of a pandemic (Schestag et al. 2022). So far, CNP-V has been studied from a purely theoretical point of view.

Problem Definition

This section describes the computational problem, named SECURITY NODE PROBLEM WITH VULNERABLE VERTICES (SNP-V). The problem has to be solved by an algorithm for automatic calculation of the devices to be isolated. SNP-V solutions enable a security officer to decide which devices need to be isolated to reduce the impact of a cyber-attack on a production system.

Definition 1 introduces the used graph notation that describes devices and connections. Definition 2 describes direct and indirect connections between devices.

Definition 1. A graph $G = (V, E)$ is a tuple consisting of a device set V and a connection set E , where each $e \in E$ is a two-element subset of V . Given a subset $C \subseteq V$ of devices that have to be removed, we let $G - C$ denote the graph obtained by deleting every device in C together with its incident connections.

Definition 2 (Connections). Let $G = (V, E)$ be a graph, and let $u \in V$ and $v \in V$ be two devices. The devices u and v are called

- (i) directly connected if $\{u, v\} \in E$,
- (ii) indirectly connected if $\{u, v\} \notin E$, but there is a path from u to v in G , and
- (iii) connected if they are directly connected or indirectly connected.

Next, assume that a subset of devices $A \subseteq V$ is under attack, named *attacked devices*. In this case, it is arguably problematic if an *attacked device* is connected to any other device. This idea of potentially problematic connections is formalized in Definition 3: Intuitively, every device $v \in V$, which is directly or indirectly connected to an *attacked device* $a \in A$ forms a vulnerable connection with the attacked device.

Definition 3 (A-vulnerability). Let $G = (V, E)$ be a graph and let $A \subseteq V$ be a subset of attacked devices. A pair of devices u and v forms a vulnerable connection if

- (i) u and v are connected according to Definition 2, and
- (ii) $u \in A$ or $v \in A$.

The A -vulnerability of G is the number of device pairs forming a vulnerable connection in G .

Definition 4 states the computational problem, named **CRITICAL NODE PROBLEM WITH VULNERABLE VERTICES (CNP-V)** (Schestag et al. 2022). In CNP-V, one aims to decrease the number of *vulnerable connections* according to Definition 3. The budget value $k \in \mathbb{N}$ describes the number of removable devices from the graph in order to reduce the number of *vulnerable connections*. The goal is, to remove these k devices in a way, such that the A -*vulnerability* of the resulting connection graph is minimal.

Definition 4 (CNP-V). *In the CRITICAL NODE PROBLEM WITH VULNERABLE VERTICES, the input is a graph $G = (V, E)$, a set $A \subseteq V$, and an integer k . The task is to find a set $C \subseteq V$ of size at most k , such that the A -vulnerability of $G - C$, according to Definition 3, is minimal.*

The set C from Definition 4 is called the *solution* of a CNP-V instance (G, A, k) . Even though it appears to be natural to exclusively remove *attacked devices*, a *solution* might in fact also contain non-attacked devices if a small budget $k < |A|$ is given. Figure 2 illustrates a *solution* containing a non-attacked device. The upper part shows a possible input graph for CNP-V. The red devices correspond to *attacked devices* A . The graph has 21 vulnerable connections with two *attacked devices*, and $3 \cdot 6 = 18$ connections with exactly one *attacked device*. The lower part shows an optimal *solution* for budget $k = 2$. Isolated devices are marked with \times . After the isolation, the graph becomes disconnected and remains only three connected device pairs including an *attacked device*.




Figure 2: Example *solutions* of a CNP-V instance (G, A, k) .

Security Node Problem with Vulnerable Vertices

This section introduces the **SECURITY NODE PROBLEM WITH VULNERABLE VERTICES (SNP-V)**. It is a new variant of CNP-V by adding a secondary optimization goal to improve the stability of the remaining network after isolating devices. The motivation of the secondary optimization goal is the lack of uniqueness for the *solution* of a CNP-V instance (G, A, k) . More precisely, a lexicographic optimization is used. Among all solutions that minimize vulnerability, one aims to find the one that provides the best connectivity of the remaining graph.

Figure 3 illustrates an example with two possible *solutions* $C_1 = \{v_1\}$ and $C_2 = \{v_2\}$. Even though, both *solutions* provide the same A -*vulnerability*, isolating v_2 also disconnects the non-attacked device v_3 from the remaining graph. Thus, in security applications, deleting v_1 is clearly a better choice. Motivated by this fact, the problem definition of CNP-V is adapted by adding a secondary goal focussing on the connectivity of non-attacked devices.




Figure 3: Example graph of an instance of CNP-V with $k = 1$, where the solution is not unique.

This idea of healthy connections is formalized in Definition 5: Intuitively, every device $v \in V$ and $v \notin A$, which is directly or indirectly connected to a non-attacked device forms a healthy connection.

Definition 5 (A-healthiness). *Let $G = (V, E)$ be a graph, and let A be a subset of attacked devices. A pair of devices u and v forms a healthy connection, if it is not a vulnerable connection. The A -healthiness of G is the number of device pairs forming a healthy connection in G .*

Next a lexicographic optimization is defined. The objective is to find a solution C whose removal results in a graph $G' = G - C$ which has maximum A -healthiness among all G' with minimum A -vulnerability. Definition 6 defines this idea as a new objective function.

Definition 6 (Objective Value). *Let $G = (V, E)$ be a graph and let $A \subseteq V$. Given a subset $C \subseteq V$, let $G' := G - C$. Moreover, let*

- (i) $\text{vul}(G')$ denote the A -vulnerability of G' , and let
- (ii) $\text{heal}(G')$ denote the A -healthiness of G' .

The objective value $\Phi(G')$ is defined as:

$$\Phi(G') := (|V|^2 + 1) \cdot \text{vul}(G') - \text{heal}(G') \in \mathbb{Z}$$

Note that a device set C minimizing $\Phi(G')$ in fact provides a solution of our lexicographic optimization: Since $|V|^2$ is an upper bound of the total number of device pairs, $\text{heal}(G') < |V|^2 + 1$. Consequently, $(|V|^2 + 1) \cdot \text{vul}(G')$ dominates the term in a way that minimizing $\Phi(G')$ minimizes $\text{vul}(G')$. Additionally, the larger the number of healthy connections, the smaller $(-\text{heal}(G'))$. Therefore, we obtain a solution of our lexicographic optimization problem, when computing a *solution* C minimizing $\Phi(G')$.

Definition 7 introduces the **SECURITY NODE PROBLEM WITH VULNERABLE VERTICES (SNP-V)**.

Definition 7 (SNP-V). *In the SECURITY NODE PROBLEM WITH VULNERABLE VERTICES (SNP-V), the input is a graph $G = (V, E)$, a set $A \subseteq V$, and an integer k . The task is to find a solution $C \subseteq V$ of size at most k , such that $\Phi(G')$, according to Definition 6, is minimal.*

Solving SNP-V

SNP-V ILP Definition

This section introduces an Integer Linear Programming (ILP) formulation of SNP-V. This formulation allows the usage of standard solver implementations. It adapts a standard ILP formulation for the **CRITICAL NODE PROBLEM** (Arulselvan et al. 2009).

Definition 8 (SNP-V-ILP). Let $(G = (V, E), A, k)$ be an instance of SNP-V. The SNP-V-ILP formulation is defined as follows:

$$\min \quad (|V|^2 + 1) \cdot \underbrace{\sum_{\{i,j\} \cap A \neq \emptyset} u_{ij}}_{A\text{-vulnerability}} - \underbrace{\sum_{\{i,j\} \cap A = \emptyset} u_{ij}}_{A\text{-healthiness}} \quad (1a)$$

$$\text{s.t.} \quad \sum_{i \in V} v_i \leq k \quad (1b)$$

$$(1 - v_i) + (1 - v_j) - 2u_{ij} \geq 0, \forall \{i, j\} \in E \quad (1c)$$

$$(1 - v_i) + (1 - v_j) - 2u_{ij} \leq 1, \forall \{i, j\} \in E \quad (1d)$$

$$u_{ij} + u_{jk} - u_{ki} \leq 1, \forall (i, j, k) \in V^3 \quad (1e)$$

$$u_{ij} - u_{jk} + u_{ki} \leq 1, \forall (i, j, k) \in V^3 \quad (1f)$$

$$-u_{ij} + u_{jk} + u_{ki} \leq 1, \forall (i, j, k) \in V^3 \quad (1g)$$

$$u_{ij} \in \{0, 1\}, \forall (i, j) \in V^2 \quad (1h)$$

$$v_i \in \{0, 1\}, \forall i \in V \quad (1i)$$

The intuition behind the formulation provided in Definition 8 is as follows: There are two types of variables. First, for every device i , there is a variable $v_i \in \{0, 1\}$ corresponding to the choice of isolated devices in the following sense: the variable v_i is assigned with 1 in a solution of the ILP if and only if the corresponding device i is contained in the solution C for SNP-V. Second, for every pair $(i, j) \in V^2$, there is a variable $u_{ij} \in \{0, 1\}$ corresponding to connectivity of devices in the following sense: the variable u_{ij} is assigned with 1 in a solution of the ILP if and only if the corresponding devices i and j are connected according to Definition 2 in the solution graph $G - C$ of SNP-V. Obviously, the Constraints (1h) and (1i) define binary domains for the variables.

Constraint (1b) ensures that the number of selected devices does not exceed the budget k . Constraints (1c) and (1d) ensure that two directly connected devices are connected in the solution if none of these devices is isolated. The Constraints (1e)–(1g) ensure that the connectivity is transitive, that is, for each $(i, j, k) \in V^3$ we have $u_{ik} = 1$ if $u_{ij} = u_{jk} = 1$. Finally, the objective (1a) models the objective function according to Definition 6.

Solving SNP-V on Instances with a Small Budget

This section states another approach for solving SNP-V. This approach is motivated by reducing the running time. Note that applying standard ILP solvers on the formulation given in Definition 8 results in a superpolynomial-time algorithm for SNP-V. Since the CRITICAL NODE PROBLEM is NP-hard (Arulselvan et al. 2009), the more general SNP-V is NP-hard as well. Thus, for arbitrary instances, there is presumably no significant running time improvement over the ILP approach. However, in case of SNP-V, one might obtain a potential speedup for many real-world instances: First, it is a reasonable assumption that the deletion budget k is relatively small in comparison to the total number of devices. In fact, since an instance becomes trivial if we are allowed to delete all attacked devices, we may assume that the dele-

tion budget is never larger than the number of attacked devices. Second, by the authors experience, many real-world networks have many devices with degree one. Herein, a device is a *degree-one device* if it has exactly one incident connection. Therefore, it is highly recommended considering an algorithm that is fast if the budget k is relatively small and the number of degree-one devices is relatively large.

Schstag et al. 2022 describe an algorithm for CNP-V with running time $\mathcal{O}(|V|^k \cdot (|V| + |E|))$. Note that only the deletion budget k appears in the exponent in this running time. The algorithm is straight forward: Let $(G = (V, E), A, k)$ be an input instance of CNP-V. Iterate over every possible device set $C \subseteq V$ of size at most k , and compute the A -vulnerability s of $G - C$. Finally, return the set C , where s is minimal. We adapt this approach by computing the objective value from Definition 6 instead of the A -vulnerability and by limiting the considered device sets $C \subseteq V$ to sets that do not contain non-attacked degree-one devices. This adaption is described in two steps. First, we formally state and prove that non-attacked degree-one devices might in fact be excluded from the search. Second, we provide the adapted algorithm as pseudocode.

Proposition 1. Let $(G = (V, E), A, k)$ be an instance of SNP-V. Furthermore, let $D \subseteq V \setminus A$ be the set of non-attacked degree-one devices. Then, there exists a solution C with $C \cap D = \emptyset$.

Proof. Let C be a set of devices with $C \cap D \neq \emptyset$. We describe how to transform C into a set C' with

- $|C'| \leq |C|$,
- $\Phi(G - C') \leq \Phi(G - C)$, and
- $|C' \cap D| < |C \cap D|$.

Note that this implies the statement as repeatedly applying this transformation converts any solution into a solution not containing devices from D . Since $C \cap D \neq \emptyset$, there exists some $v \in C \cap D$. If $\Phi(G - (C \setminus \{v\})) \leq \Phi(G - C)$, then $C' := C \setminus \{v\}$ clearly satisfies a), b), and c). Thus, we consider the case where $\Phi(G - (C \setminus \{v\})) > \Phi(G - C)$. Since removing non-attacked devices never increases the healthiness, we conclude that $G - (C \setminus \{v\})$ contains some attacked device forming a vulnerable connection with v . We thus have $|A \cap X| \geq 1$, where X denotes the connected component in $G - (C \setminus \{v\})$ that contains v . Since v has degree one, it has a unique neighbor $w \in X$. We next show that deleting w instead of v provides a device set satisfying a), b), and c). We define $C' := C \setminus \{v\} \cup \{w\}$. Note that $|C'| = |C|$. It remains to prove b) and c). To this end, consider the following cases:

Case 1: w is non-attacked. Then, since there exists some attacked device in X , the device w has at least two neighbors. Therefore, $|C' \cap D| < |C \cap D|$. Moreover, note that removing w also destroys all $|A \cap X|$ vulnerable connections including w . Thus, we have

$$\text{vul}(G - C') \leq \text{vul}(G - C) - |A \cap X|.$$

Since $|A \cap X| \geq 1$, we have $\Phi(G - C') < \Phi(G - C)$.

Case 2: w is attacked. Then, $w \notin D$ and therefore $|C' \cap D| < |C \cap D|$. Moreover, note that removing w also destroys $|X| - 2$ vulnerable connections with the devices in $X \setminus \{v, w\}$. Thus, we have

$$\text{vul}(G - C') \leq \text{vul}(G - C) - (|X| - 2).$$

If $|X| > 2$ we have $\text{vul}(G - C') < \text{vul}(G - C)$ and therefore $\Phi(G - C') < \Phi(G - C)$. If $|X| = 2$, then $X = \{v, w\}$ and both graphs $G - C$ and $G - C'$ have the exact same vulnerable and healthy connections. Then, $\Phi(G - C') = \Phi(G - C)$. Summarizing, it holds that $\Phi(G - C') \leq \Phi(G - C)$. \square

We next provide the algorithm as pseudocode. In Line 1 of Algorithm 1, D is set to be the device set containing all non-attacked degree-one devices that may be excluded from the computation according to Proposition 1. In Line 2, \mathcal{C} is set to be the family containing all subsets of $V \setminus D$ with size at most k . Afterwards, in Lines 4–8, one computes the objective value s from Definition 6 for each $G - C'$ with $C' \in \mathcal{C}$ and stores the tuple (s, C') . Finally, the subset C with minimum score is returned, cf. Line 9. The details of the computation of the score in Line 6 are described in Algorithm 2.

Algorithm 1 CyberSeg-Direct

Input: $G = (V, E)$, A , k

Output: C

```

1:  $D \leftarrow$  degree-one devices in  $V \setminus A$ 
2:  $\mathcal{C} \leftarrow$  combinations( $V \setminus D$ ,  $k$ )
3:  $F \leftarrow \emptyset$ 
4: for all  $C' \in \mathcal{C}$  do
5:    $G' \leftarrow G - C'$ 
6:    $s \leftarrow$  score( $G', A$ )
7:    $F \leftarrow F \cup \{(s, C')\}$ 
8: end for
9: return  $\arg \min_C \{(s, C) \in F\}$ 

```

In Line 1 of Algorithm 2, the connected components of the input graph are computed using a standard depth-first-search. In Lines 3–13, one iterates over all connected components. For each such component, one stores the number of vulnerable connections in a variable b using a formula by Schestag et al. 2022 in Line 10. With b at hand, the A -vulnerability (Line 11) and the A -healthiness (Line 12) of the current component are added to the total A -vulnerability (A -healthiness) of G . Finally, the score according to Definition 6 is returned, cf. Line 14.

Solving SNP-V with Greedy Algorithm

Due to the NP-hardness of SNP-V, finding an exact solution becomes intractable for larger instances. This section provides a simple scheme for a greedy heuristic that provides a trade-off between running time and solution quality. The scheme is based on Algorithm 1. Note that Algorithm 1 finds an optimal set of k devices to remove in running time $\mathcal{O}(|V \setminus D|^k \cdot (|V| + |E|))$; a running time that crucially depends on the deletion budget k . In the following, we use this algorithm to solve instances with some pre-defined

Algorithm 2 CyberSeg-Score

Input: $G = (V, E)$, A

Output: s

```

1:  $\hat{C} \leftarrow$  components( $G$ )
2:  $g, h \leftarrow 0$ 
3: for all  $(V', E') \in \hat{C}$  do
4:    $a_c = 0$ 
5:   for all  $v \in V'$  do
6:     if  $v \in A$  then
7:        $a_c \leftarrow a_c + 1$ 
8:     end if
9:   end for
10:   $b \leftarrow \binom{a_c}{2} + a_c \cdot (|V'| - a_c)$ 
11:   $h \leftarrow h + b$ 
12:   $g \leftarrow g + (\binom{|E'|}{2} - b)$ 
13: end for
14: return  $(|V|^2 + 1) \cdot h - g$ 

```

smaller budget $x < k$. Intuitively, the algorithm does not aim to find the best ‘large’ solution of size k , but repeatedly finds the best ‘small’ solution of size $x < k$. This is done as many times as x fits into k . Algorithm 3 describes this heuristic.

Algorithm 3 CyberSeg-Greedy

Input: $G = (V, E)$, A , k , x

Output: C

```

1:  $C \leftarrow \emptyset$ 
2: while  $x < k$  do
3:    $C' \leftarrow$  CyberSeg( $G - C$ ,  $A$ ,  $x$ )
4:    $C \leftarrow C \cup C'$ 
5:    $k \leftarrow k - x$ 
6: end while
7:  $C \leftarrow C \cup$  CyberSeg( $G - C$ ,  $A$ ,  $k$ )
8: return  $C$ 

```

In Line 1, the solution C is initialized as an empty set. In Lines 2–6, the current solution is extended by deleting the current best device set of size x as long as this fits into the deletion budget. Finally, in Line 7, the solution C is extended by removing the remaining $k \leq x$ devices. Observe that the greedy algorithm has a running time of $|V|^x \cdot (|V| + |E|)^{\mathcal{O}(1)}$. It depends on the chosen parameter x . That is, the larger x , the slower the algorithm, while—on the other hand—larger values of x are more likely to provide a better solution quality. The choice of x outlines a trade-off between solution quality and running time.

First Experimental Results

This section describes our first empirical results. Three different datasets are used: the Zachary’s karate club data set (Zachary 1977), a synthetic data set, and a real world data set describing a cyber-physical production system from the Smart Factory OWL (SFOWL). Zachary’s karate club dataset describes a social network of a karate club. It describes conflict and fission in small groups. The data set is

not related to the topic of security, but is often used to analyze this type of problem. In this work, individuals are devices or attacked devices and social relationships are connections. The synthetic data set is created by a graph generator (Storer 2001). The generator creates a full r -ary tree of 50 devices and a branching factor of 5. The generated topology simulates a possible network of automation components. This topology is used as it comes close to a cyber-physical production system as illustrated in Figure 4. This example consists of three production modules. Each module has a PLC, IO-Devices and virtual appliances, such as condition monitoring or optimization as described above. A central PLC controls the overall process. The SFOWL dataset describes a real-world production system with 288 devices and 737 connections, illustrated in Figure 5.




Figure 4: Synthetic dataset example.




Figure 5: SFOWL dataset.

Table 1 summarizes the metadata of the datasets. For each graph, three instances are generated by randomly choosing the set A of attacked devices. The value $p \in \{0.1, 0.25, 0.5\}$ corresponds to the fraction of attacked devices. More precisely, in a graph with n devices, we have $\lceil p \cdot n \rceil$ attacked devices. These attacked devices are sampled uniformly.

The introduced SNP-V-ILP formulation (see Definition 8) is described by the Pyomo open-source optimization modeling language and the used solver is Gurobi. The CyberSeg implementations (see Algorithm 1 and Algorithm 3) are based on Python programming language. Each combination can be computed in parallel and each computation was performed on an Apple M2 Max with 12 cores. SNP-V-ILP and CyberSeg-Direct have a timeout limit set to 600 seconds, as we assume that this limit enables a timely response in a real-world scenario.

Table 2 summarizes a solutions quality analysis. Note that CyberSeg-Direct and SNP-V-ILP both provide optimal solutions and therefore the same solution quality. As a conse-

Dataset	p	Devices	d-1	Connections	v	h
Karate	0.1	34	1	78	96	465
	0.25	34	1	78	236	325
	0.5	34	1	78	425	136
Synthetic	0.1	50	38	49	235	990
	0.25	50	31	49	522	703
	0.5	50	19	49	925	300
SFOWL	0.1	288	121	737	7917	33411
	0.25	288	100	737	18108	23220
	0.5	288	66	737	31032	10296

Table 1: Dataset descriptions: d-1=degree-one devices in $V \setminus A$, $v=A$ -vulnerability, $h=A$ -healthiness

quence, the union of both results appears in the table as *Exact* and the individual timeouts are indicated.

SNP-V-ILP: Independent of the budget k and the value of p , solving SNP-V-ILP computes a solution within less than one minute when given the Karate and the Synthetic network. In contrast, for all instances on the real-world network SFOWL, no solution was found within the time limit of 600 seconds. The results show that in many instances it is not necessary to delete all attacked devices in order to remove all vulnerable connections. In detail, for Karate with $p = 0.5$, Synthetic with $p \in \{0.1, 0.25, 0.5\}$, it is sufficient to remove 60%, 80%, 69%, and 36% of the total number of attacked devices, respectively. Note that the removed devices are not necessarily attacked devices, but devices that provide a high connectivity between attacked devices and the remaining graph. In the other two cases Karate with $p \in \{0.1, 0.25\}$, the results show that all attacked devices need to be removed to obtain A -vulnerability of $v = 0$. A further interesting observation can be made in case of Synthetic with $p = 0.5$, it is sufficient to remove nine devices to obtain A -vulnerability of $v = 0$, but removing ten devices also provides a better healthiness. Based on the solutions of the small networks, we find that the results indicate that solving SNP-V provides a good alternative to naively isolating all attacked devices, as it is sufficient to only shut down a few attacked devices. Thus, the computational problem SNP-V is a promising model for our practical use-case. However, it seems that the practical relevance of solving SNP-V via ILP is very limited as the computation takes too long. For the real-world network SFOWL, no solution was found even in cases with very small budgets k . Summarizing, aiming for practical applications, it requires for more efficient algorithms and heuristics to solve SNP-V.

CyberSeg-Direct: Since CyberSeg provides exact solutions like the SNP-V-ILP, the resulting A -vulnerability and A -healthiness are the same. Thus, we only discuss the running time of CyberSeg in this paragraph. For the solution quality, we refer to the previous paragraph discussing the SNP-V-ILP results. For the networks Karate and Synthetic, the algorithm was able to provide solutions for all $k \in \{1, \dots, 8\}$ within the time limit and ran into timeout for $k \in \{9, 10\}$. In case of SFOWL, it computed solutions for $k \in \{1, 2, 3\}$. Recall that the theoretical running time of CyberSeg crucially depends on k , which matches

this experimental evaluation. While this algorithm exploits structural characteristics like degree-one-devices and small budgets, its practical relevance is limited as in the case of the SNP-V-ILP. However, in contrast to the SNP-V-ILP, the performance for $k \leq 3$ can be seen as a promising subroutine that can be used as a plug-in for the greedy heuristic.

CyberSeg-Greedy: Recall that CyberSeg-Direct is a subroutine in CyberSeg-Greedy which is evaluated for budgets $x < k$. Motivated by the running times discussed in the previous paragraph, we performed experiments with $x = 3$ on all instances. On small instances with $p = 0.1$, the greedy algorithm always found an optimal solution. On small instances with $p \in \{0.25, 0.5\}$, the solution is close to the optimum. Observe that the budgets required to find a solution with A -vulnerability zero is at most the optimal budget plus two. In case of the SFOWL network with budget $k = 10$, the greedy algorithm found solutions decreasing the vulnerability by 86%, 80%, and 82% in case of $p = 0.1$, $p = 0.25$, and $p = 0.5$, respectively. In case of SFOWL with $p = 0.1$ further experiments for larger values of k to determine for which budget a solution with vulnerability zero was found. With $k = 22$, the heuristic found a solution with vulnerability 0 and with healthiness 3867. That is, the greedy heuristic found a solution that removes 75% of the devices in comparison to the naive solution by simply removing all attacked devices. For the real-world data set, it is noticeable that the A -healthiness values drop significantly compared to their initial ones. This is due to the fact that both A -vulnerability and A -healthiness decrease quadratically for larger k values and A -healthiness is not taken into account by the algorithm as long as vulnerable nodes remain.

Summary and Future Work

This paper introduces CyberSeg, a novel approach to identify devices in cyber-physical production systems that should be isolated in the event of a cyber-attack. The SECURITY NODE PROBLEM WITH VULNERABLE VERTICES (SNP-V) is presented for this. The necessary information, such as devices, attacked devices, and connection between devices, can be obtained from common security monitoring systems. SNP-V instances can be solved with CyberSeg and the results enable security officers to make decisions to reduce the impact of cyberattacks. CyberSeg helps to avoid worst-case decisions, such as shutting down the production system. Dependent on the production process, it takes days or weeks to restart the production system. We have shown that in all analyzed cases, the isolation of only a few devices leads to a healthy network. While this work provides a first step into studying SNP-V in context of security for cyber-physical production systems, there are several ways to extend this work. One idea is the formulation of SNP-V with specific domain knowledge to avoid isolation of devices critical for the production process. In cases where some devices are more expensive to be shut down than others, one may think of a problem version with weighted devices. Otherwise, in case of directed communication between devices one may need a problem version with directed graphs.

k	p	Karate		Synthetic		SFOWL		v	h				
		Exact	Greedy	Exact	Greedy	Exact	Greedy						
1	0.1	63	465	63	465	14	341	14	341	6175 [†]	25203 [†]	6175	25203
2	0.1	31	465	31	465	9	331	9	331	4213 [†]	16294 [†]	4213	16294
3	0.1	0	465	0	465	4	321	4	321	3530 [†]	13865 [†]	3530	13865
4	0.1	0	465	0	465	0	321	0	321	-	-	3159	13865
5	0.1	0	465	0	465	0	321	0	321	-	-	2924	13370
6	0.1	0	465	0	465	0	321	0	321	-	-	1808	8783
7	0.1	0	465	0	465	0	321	0	321	-	-	1519	8783
8	0.1	0	465	0	465	0	321	0	321	-	-	1172	5076
9	0.1	0 [‡]	465 [‡]	0	465	0	321	0	321	-	-	953	5076
10	0.1	0 [‡]	465 [‡]	0	465	0	321	0	321	-	-	821	4782
1	0.25	129	232	129	232	142	218	142	218	13294 [†]	16110 [†]	13294	16110
2	0.25	99	211	99	211	51	64	51	64	9919 [†]	10588 [†]	9919	10588
3	0.25	75	211	75	211	42	58	42	58	8614 [†]	8781 [†]	8614	8781
4	0.25	39	44	52	211	25	51	33	52	-	-	7804	8131
5	0.25	26	19	30	211	19	51	24	46	-	-	7253	7629
6	0.25	9	232	9	211	14	51	19	46	-	-	5638	4953
7	0.25	5	232	5	211	9	51	14	46	-	-	4719	4468
8	0.25	0	325	1	210	2	1	9	46	-	-	3119	3129
9	0.25	0 [‡]	325 [‡]	0	210	0	45	4	46	-	-	2841	2974
10	0.25	0 [‡]	325 [‡]	0	210	0	75	0	40	-	-	2602	2898
1	0.5	282	79	282	79	257	98	257	98	22264 [†]	7140 [†]	22264	7140
2	0.5	207	79	207	79	92	23	92	23	15151 [†]	5356 [†]	15151	5356
3	0.5	144	56	144	56	77	23	77	23	12930 [†]	4465 [†]	12930	4465
4	0.5	61	22	61	22	55	26	63	22	-	-	11930	4005
5	0.5	27	18	27	18	41	25	49	21	-	-	11054	3828
6	0.5	14	18	14	18	29	22	37	18	-	-	7889	2702
7	0.5	9	17	9	17	13	15	25	15	-	-	6902	2557
8	0.5	5	18	5	18	0	3	16	9	-	-	4462	1786
9	0.5	0 [‡]	17 [‡]	0	17	0 [‡]	21 [‡]	7	3	-	-	4088	1727
10	0.5	0 [‡]	18 [‡]	0	17	0 [‡]	55 [‡]	0	0	-	-	3729	1669

Table 2: Solutions quality analysis: $v=A$ -vulnerability, $h=A$ -healthiness, [†]=ILP timeout, [‡]=CyberSeg-Direct timeout, —=timeout for both exact approaches

References

- Addis, B.; Summa, M. D.; and Grosso, A. 2013. Identifying critical nodes in undirected graphs: Complexity results and polynomial algorithms for the case of bounded treewidth. *Discrete Applied Mathematics*, 161(16-17): 2349–2360.
- Al-Shaer, R.; Spring, J. M.; and Christou, E. 2020. Learning the associations of mitre att & ck adversarial techniques. In *2020 IEEE Conference on Communications and Network Security (CNS)*, 1–9. IEEE.
- Arulselvan, A.; Commander, C. W.; Elefteriadou, L.; and Pardalos, P. M. 2009. Detecting critical nodes in sparse graphs. *Computers & Operations Research*, 36(7): 2193–2200.
- Bai, R.; Lin, H.; Yang, X.; Wu, X.; Li, M.; and Jia, W. 2021. Defending against contagious attacks on a network with resource reallocation. In *Proceedings of the AAAI Conference on Artificial Intelligence*, volume 35, 5135–5142.
- Gaspers, S.; and Najeebullah, K. 2019. Optimal surveillance of covert networks by minimizing inverse geodesic length. In *Proceedings of the AAAI Conference on Artificial Intelligence*, volume 33, 533–540.
- Guo, M.; Li, J.; Neumann, A.; Neumann, F.; and Nguyen, H. 2022. Practical fixed-parameter algorithms for defending active directory style attack graphs. In *Proceedings of*

- the *AAAI Conference on Artificial Intelligence*, volume 36, 9360–9367.
- Guo, M.; Ward, M.; Neumann, A.; Neumann, F.; and Nguyen, H. 2023. Scalable edge blocking algorithms for defending active directory style attack graphs. In *Proceedings of the AAAI Conference on Artificial Intelligence*, volume 37, 5649–5656.
- Hermelin, D.; Kaspi, M.; Komusiewicz, C.; and Navon, B. 2016. Parameterized complexity of critical node cuts. *Theor. Comput. Sci.*, 651: 62–75.
- Kamra, N.; Gupta, U.; Fang, F.; Liu, Y.; and Tambe, M. 2018. Policy learning for continuous space security games using neural networks. In *Proceedings of the AAAI Conference on Artificial Intelligence*, volume 32.
- Kim, K.; Youn, J.; Yoon, S.; Kang, J.; Kim, K.; and Shin, D. 2023. Study on Cyber Common Operational Picture Framework for Cyber Situational Awareness. *Applied Sciences*, 13(4): 2331.
- Lalou, M.; Tahraoui, M. A.; and Kheddouci, H. 2018. The Critical Node Detection Problem in networks: A survey. *Comput. Sci. Rev.*, 28: 92–117.
- Lee, E. A. 2008. Cyber Physical Systems: Design Challenges. In *Proc. 11th IEEE Symposium on Object Oriented Real-Time Distributed Computing (ISORC)*, 363–369.
- Leitão, P.; Karnouskos, S.; Ribeiro, L.; Lee, J.; Strasser, T.; and Colombo, A. W. 2016. Smart Agents in Industrial Cyber-Physical Systems. *Proceedings of the IEEE*, 104: 1086–1101.
- Li, M.; Tran-Thanh, L.; and Wu, X. 2020. Defending with shared resources on a network. In *Proceedings of the AAAI Conference on Artificial Intelligence*, volume 34, 2111–2118.
- Li, S.; Wang, X.; Zhang, Y.; Xue, W.; Černý, J.; and An, B. 2023. Solving large-scale pursuit-evasion games using pre-trained strategies. In *Proceedings of the AAAI Conference on Artificial Intelligence*, volume 37, 11586–11594.
- Najeebullah, K. 2018. Complexity of optimally defending and attacking a network. In *Proceedings of the AAAI Conference on Artificial Intelligence*, volume 32.
- Otto, J.; and Niggemann, O. 2015. Automatic Parameterization of Automation Software for Plug-and-Produce. In *AAAI-15 Workshop on Algorithm Configuration (AlgoConf)*.
- Otto, J.; Vogel-Heuser, B.; and Niggemann, O. 2018. Automatic Parameter Estimation for Reusable Software Components of Modular and Reconfigurable Cyber-Physical Production Systems in the Domain of Discrete Manufacturing. *IEEE Transactions on Industrial Informatics*, 14(99): 275–282.
- Rehberger, S.; Spreiter, L.; and Vogel-Heuser, B. 2016. An Agent Approach to Flexible Automated Production Systems Based on Discrete and Continuous Reasoning. In *Proc. 12th IEEE International Conference on Automation Science and Engineering (CASE)*, 1249–1256.
- Rosenfeld, A.; and Kraus, S. 2017. When Security Games Hit Traffic: Optimal Traffic Enforcement Under One Sided Uncertainty. In *IJCAI*, volume 17, 3814–3822.
- Schestag, J.; Grüttemeier, N.; Komusiewicz, C.; and Sommer, F. 2022. On Critical Node Problems with Vulnerable Vertices. In *Proceedings of the 33rd International Workshop on Combinatorial Algorithms, IWOCA '22*, volume 13270 of *Lecture Notes in Computer Science*, 494–508. Springer.
- Sheyner, O.; Haines, J.; Jha, S.; Lippmann, R.; and Wing, J. M. 2002. Automated generation and analysis of attack graphs. In *Proceedings 2002 IEEE Symposium on Security and Privacy*, 273–284.
- Specht, F.; Otto, J.; and Eickmeyer, J. 2022. Cyberattack Impact Reduction using Software-Defined Networking for Cyber-Physical Production Systems. In *2022 IEEE 20th International Conference on Industrial Informatics (INDIN)*, 188–194.
- Specht, F.; Otto, J.; Niggemann, O.; and Hammer, B. 2018. Generation of adversarial examples to prevent misclassification of deep neural network based condition monitoring systems for cyber-physical production systems. In *Proc. 16th International Conference on Industrial Informatics*, 760–765.
- Specht, F.; Otto, J.; and Ratz, D. 2023. Generation of Synthetic Data to Improve Security Monitoring for Cyber-Physical Production Systems. In *2023 IEEE 21th International Conference on Industrial Informatics (INDIN)*.
- Storer, J. A. 2001. *An introduction to data structures and algorithms*. Springer Science & Business Media.
- Summa, M. D.; Grosso, A.; and Locatelli, M. 2011. Complexity of the critical node problem over trees. *Comput. Oper. Res.*, 38(12): 1766–1774.
- Vitoriano, B.; Ortuño, M. T.; Tirado, G.; and Montero, J. 2011. A multi-criteria optimization model for humanitarian aid distribution. *J. Glob. Optim.*, 51(2): 189–208.
- Wang, S.; Liu, F.; and Shroff, N. 2017. Non-additive security games. In *Proceedings of the AAAI Conference on Artificial Intelligence*, volume 31.
- Wollschlaeger, M.; Sauter, T.; and Jasperneite, J. 2017. The Future of Industrial Communication: Automation Networks in the Era of the Internet of Things and Industry 4.0. *IEEE Industrial Electronics Magazine*.
- Xue, W.; An, B.; and Yeo, C. K. 2022. NSGZero: Efficiently Learning Non-exploitable Policy in Large-Scale Network Security Games with Neural Monte Carlo Tree Search. In *Proceedings of the AAAI Conference on Artificial Intelligence*, volume 36, 4646–4653.
- Zachary, W. W. 1977. An information flow model for conflict and fission in small groups. *Journal of anthropological research*, 33(4): 452–473.
- Zheng, A. X.; Dunagan, J.; and Kapoor, A. 2011. Active graph reachability reduction for network security and software engineering. In *IJCAI Proceedings-International Joint Conference on Artificial Intelligence*, volume 22, 1750.