Time Series Dataset for Modeling and Forecasting of $\rm N_2O$ in Wastewater Treatment

Laura Debel Hansen^{1, 2, *}, Anju Rani¹, Mikkel Algren Stokholm-Bjerregaard², Peter Alexander Stentoft², Daniel Ortiz Arroyo¹, and Petar Durdevic¹

> ¹Department of Energy, Aalborg University, 6700 Esbjerg, Denmark ²Krüger Veolia, Veolia Water Technologies, 2860 Søborg, Denmark ^{*}laura.debel@veolia.com or ldh@energy.aau.dk

ABSTRACT

In this paper, we present two years of high-resolution nitrous oxide (N_2O) measurements for time series modeling and forecasting in wastewater treatment plants (WWTP). The dataset comprises frequent, real-time measurements from a full-scale WWTP, with a sample interval of 2 minutes, making it ideal for developing models for real-time operation and control. This comprehensive bio-chemical dataset includes detailed influent and effluent parameters, operational conditions, and environmental factors. Unlike existing datasets, it addresses the unique challenges of modeling N_2O , a potent greenhouse gas, providing a valuable resource for researchers to enhance predictive accuracy and control strategies in wastewater treatment processes. Additionally, this dataset significantly contributes to the fields of machine learning and deep learning time series forecasting by serving as a benchmark that mirrors the complexities of real-world processes, thus facilitating advancements in these domains. We provide a detailed description of the dataset along with a statistical analysis to highlight its characteristics, such as nonstationarity, nonnormality, seasonality, heteroscedasticity, structural breaks, asymmetric distributions, and intermittency, which are common in many realworld time series datasets and pose challenges for forecasting models.

Keywords Nitrous Oxide \cdot Time series forecasting \cdot Environmental engineering \cdot Machine Learning \cdot Data-driven modelling \cdot Operational Data \cdot Full-scale wastewater treatment plant

Specifications

Subject	Environmental science and engineering			
Specific subject area	Datadriven or mechanistic modelling or forecasting of N_2O concentration in wastewater treatment plants utilizing the activated sludge process (ASP).			
Type of data	Time series (csv).			
Data acquisition	The plant is controlled by an internal SCADA system, which receives setpoints from an online cloud-based platform developed by Krüger Veolia. Operational data was extracted from the online cloud platform at a sample interval of 2 min.			
Data format	2-minute time-aggregated raw data			
Description of data collection	Operational data was collected over 2 years from June 2022 to June 2024 using online chemical measurements of NH_4 , NO_3 , PO_4 , N_2O and DO. Additionally, control signals generated in the SCADA system and cloud-based control platform was collected simultaneously alongside temperature, suspended solids, and flow measurements of both air and wastewater delivered to the process. 12 sensor measurements and 12 various other signals yields a total of 24 signals included in the dataset.			
	Institution: BIOFOS			
Data source location	City/region: Avedøre, Copenhagen			
	Country: Denmark			
	Repository name: Mendeley Data			
Data accessibility	DOI: 10.17632/xmbxhscgpr.1			
	Direct URL to data: https://data.mendeley.com/datasets/xmbxhscgpr/1			
Related Research	Hansen, L. D., Stentoft, P. A., Ortiz-Arroyo, D. & Durdevic, P. Exploring data quality and seasonal variations of N2O in wastewater treatment: a modeling perspective. Water Practice & Technology, wpt2024045 (2024) [1]			

Value of the data

- Long-term high-resolution time series data from an operating full-scale wastewater treatment plant (WWTP) can help assess the factors and conditions that impact the N_2O production in activated sludge processes.
- Stakeholders in the water environments may take more informed decisions to optimally monitor, report, and control wastewater processes based on real-world operational data from an example case.
- Research studies in N₂O model development, control development and mitigation strategies can benefit from access to real-world operational data.

1 Objective

Wastewater treatment plants (WWTPs) play a crucial role in modern society by treating polluted water from industrial and domestic sources before releasing the treated effluent into the environment. During the biological treatment process, WWTPs are known to produce significant amounts of nitrous oxide $(N_2O)[2]$. With a global warming potential 265 times that of CO_2 over a 100-year period [3], N_2O is a potent greenhouse gas (GHG) and a major contributor to the climate footprint of WWTPs. Consequently, N_2O has gained attention in the wastewater industry and political discussions, making mitigation a priority for WWTPs.

Understanding the N_2O production mechanisms and modelling of it in full-scale WWTPs is crucial for mitigation of N_2O on a global level. To support the development of models and mitigation strategies, this time series dataset has been collected, encompassing various operational conditions during 2 years of operation in a full-scale WWTP.

The dataset serves as a benchmark for evaluating the performance of different modelling and mitigation techniques. This dataset aims to foster collaboration and knowledge sharing among industry experts, researchers, and stakeholders

involved in the water sector and beyond. Additionally, the availability of this dataset can encourage the adoption of standardized testing protocols and best practices for modelling wastewater treatment processes in general. By utilizing the dataset, researchers can explore the effect of applying a wide range of data-driven and mechanistic methodologies. The dataset promotes collaboration, standardization, and innovation in the modelling, control, and mitigation of N_2O , facilitating the adoption of advanced techniques and best practices across industries.

2 Materials and Methods

2.1 Plant description

The data is collected from Avedøre WWTP, located in the urban area of Copenhagen, Denmark. Biological treatment is applied in four parallel lines with two carousel reactors in each line. The process of interest is the activated sludge process (ASP), which occurs in the aeration tanks as shown in figure 1. Here, microbial treatment in the form of nitrification and denitrification treatment takes place by controlling the presence of air. Alternating ASP is achieved with bubble diffusers mounted at the bottom of each reactor and is controlled based on the concentration of ammonium (NH₄), nitrate (NO₃), and dissolved oxygen (O_2) concentration. After the treatment, the activated sludge is separated from the mixed liquor and recycled into the system to continue the treatment process. The data is collected from line 3 with most sensors located in one carousel reactor. Other operational variables that are monitored suspended solids (SS), temperature (T), phosphate (PO_4), valve position in aeration pipe, airflow from the joint blower station, inflow of wastewater, and control signals. Additionally, the airflow to each tank is estimated based on the valve position and airflow from the joint blower station. Figure 2 illustrates the location of chemical sensors.



Figure 1: Layout of a WWTP with ASP. The parameters k, m, and n vary based on plant-specific dimensioning. Adapted from [1].

The case plant treats wastewater for 350.000 population equivalent (PE). Operational data related to the biological process in the aeration tank is available from June 2022 to June 2024.

2.2 Data Collection

Data was collected using the online cloud platform, Hubgrade Performance Plant¹ (HPP), connected to the plant's SCADA system. As this is operational data, no additional procedures were implemented to acquire it. The sensors were maintained according to standard operational practices, without extra measures to enhance data quality beyond what is typical for a Danish WWTP. This ensures a comprehensive dataset representing real world conditions with challenges such as missing data due to maintenance and replacement of equipment. The sample period ranges between 2-5 minutes, with all data subsequently up-sampled to preserve the signal dynamics. The information is categorized into several types: measurements of ongoing processes, control signals generated by the SCADA system, alarm signals (or watchdogs) that trigger operational mode shifts upon exceeding predefined thresholds, and process modes, represented by Boolean signals or integer codes indicating the current operational state. There are 16 different types of signals

¹https://www.veoliawatertechnologies.com/en/hubgrade-performance-plant-module-digital-solution

Table 1: Categorized sensor data and control signals available in the dataset. The column *Add. location* indicates if the signal is also available at another location. The row color indicates: measurement (blue), estimated values (orange),

controlled states (yellow), and watchdog (green).									
Name	Add. location	Abbrv.	Unit	Comment					
INLET.STATE.SWM INLET FLOW		SWM	-	Storm Water mode state. An integer signal describing if the plant runs a special wet- weather control due to high inflow usually caused by precipitation.					
INLET.Q BIOLOGY.BLOWERSTATION 1.Q.AIRFLOW BIOLOGY.LINE 3 TANK 1.N2O BIOLOGY.LINE 3 TANK 1.NH4 BIOLOGY.LINE 3 TANK 1.NO3		Q_{in} $Q_{air,total}$ N_2O NH_4 NO_3	m ³ /h Nm ³ /h mg-N/L mg-N/L mg-N/L	Total flow of wastewater Combined airflow from blower station Nitrous Oxide Ammonium Nitrate					
BIOLOGY.LINE 3 TANK 1.02 BIOLOGY.LINE 3 TANK 1.SS BIOLOGY.LINE 3 TANK 1.PO4 BIOLOGY.LINE 3 TANK 1.TEMPERATURE	TANK 2 TANK 2 TANK 2	O_2 SS PO_4 T	mg/L g/L mg-P/L °C	Dissolved Oxygen Suspended solids Phosphate Temperature					
BIOLOGY.LINE 3 TANK 1.Q.AIRFLOW	TANK 2	Q_{air}	Nm ³ /h	Estimated Airflow over valve					
BIOLOGY.LINE 3 TANK 1 VALVE 1.PCT BIOLOGY.LINE 3.PHASECODE.SETPOINT	TANK 2	$\substack{u_v \ \phi}$	% -	Valve position Phase code. A line-specific 4-digit code indicating the inlet and outlet tank, along with the aeration phase in each tank.					
BIOLOGY.LINE 3 TANK 1.PROCESSPHASE	TANK 2	ϕ_1,ϕ_2	-	Aeration phase. An integer signal describ- ing conditions in the given tank					
BIOLOGY.LINE 3.PROCESSPHASE.INLET TANK		ϕ_{in}	-	Inlet tank. An integer signal describing if wastewater is flowing to tank 1 or 2					
BIOLOGY.LINE 3.PROCESSPHASE.OUTLET TANK		ϕ_{out}	-	Outlet tank. An integer signal describing if wastewater is exiting from tank 1 or 2					

which are all described in table 1. Table 1 furthermore provides an overview of the system measurements, controlled variables, watchdog and estimated variables.

2.2.1 N2O sensor

·····

Dissolved N_2O concentrations were measured using a Clark-type electro-chemical N_2O sensor from Unisense Environment, Denmark[4]. The sensor features a replaceable sensor head with a manufacturer-guaranteed lifespan of 4 months, though a lifespan of over 6 months is expected. Prior to deployment, the sensor is calibrated using a two-point calibration at the same temperature as the wastewater. This ensures measurements are accurate within an uncertainty of $\pm 5\%$ within $\pm 3^{\circ}C$ of the calibration temperature. To account for seasonal temperature variations, it is recommended to perform a two-point calibration every two months. However, it should be noted that no metadata of performed calibrations are available, which is an issue addressed is [1]. The sensor measures, in its default configuration, N_2O concentrations within the range of 0-1.5 mg N₂O-N/L with a resolution of 0.005 mg N₂O-N/L. However, the sensor can be recalibrated to suit the anticipated N₂O concentration range at a specific plant, although this adjustment may reduce resolution, resulting in larger measurement increments. The sensor's response time is 65 seconds for temperatures between 10-30°C, with slower response times at lower temperatures. Information about the sensor was obtained from the manufacturer's manual and personal communication.

2.2.2 Airflow estimation

The plant has a shared compressor station that delivers an airflow to a shared manifold. The valve opening to each tank then determines the flow to each specific tank. An approximation of the airflow to each tank is given in equations (1) and (2), using the total airflow delivered by the compressor and valve opening to the specific tank.

The airflow correction factor, $C_{v,i}$ based on the valve position, $U_{v,i}$:

$$C_{i}(U_{v,i}) = \begin{cases} \frac{60}{33}U_{v,i}, & \text{if } 0 \le U_{v,i} \le 33\\ \frac{30}{33}U_{v,i}, & \text{if } 33 < U_{v,i} \le 66\\ \frac{10}{34}U_{v,i}, & \text{if } 66 < U_{v,i} \le 100 \end{cases}$$
(1)

Here, $C_{v,i}$, is an airflow correction factor based on the valve position, $U_{v,i}$. As soon as a valve is open, it takes a major part of the combined airflow. However, the airflow over the valve does not increase linearly with the valve position,



Figure 2: Aerial photograph of the 8 aeration tanks at the case plant. The sensor placement, aeration field and flow directions are indicated in tank 1 and tank 2 for line 3.

but rather in a sigmoid-shaped way as given by equation (1). Using this relationship, the most open valve will have the highest estimated airflow. The estimated airflow to tank i is given in equation (2).

$$\widehat{Q}_{air,i} = \frac{C_i(U_{v,i})}{\sum\limits_{j=1}^n C_j(U_{v,j})} Q_{air,total}$$
(2)

in which $\widehat{Q}_{air,i}$ is the estimated airflow to tank *i*. $C_i(U_{v,i})$ is the flow correction factor as a function of the valve position $U_{v,i}$. The total airflow delivered by the combined blower station is denoted $Q_{air,total}$.

2.2.3 Variable naming

All variables in the dataset are named according to their location and the type of observation; sensor measurement, setpoints, watchdogs and process modes. The variable name is composed by specifications separated by a point (.) as described here:

name = {UnitOperation}.{SubUnitOperation}.{Type}.{SubType}

The different specification elements in the name are listed below:

```
UnitOperation:
   The main location specification which indicates if the variable is collected
   at the inlet to the WWTP or in the biological process. Can be "Inlet" or
   "Biology".
SubUnitOperation:
   The second location specification (if any) which specifies the location
   within the unit. Can specify the line number, tank number, "blower station",
   "state" or "process phase"
```

Type: The main type specification, such as "N2O", "NH4", "Q", etc. SubType: Specifies the sub-type such as "setpoint".

This variable naming convention is also used in table 1.

2.2.4 Phase codes and control inputs

All biological processes (nitrification, denitrification) are controlled using integer code to describe the conditions governing each biological tank. A four-digit code is used in the online control system to describe the process for each of the biological lines shown in figure 2. These codes are referred to as biological phase codes. The meaning of each digit in the phase codes is described in table 2.

Table 2: Biological phase codes definition.

ϕ	Description	Value
ϕ_{in}	The tank that wastewater flows into	Takes a value of 1 or 2
ϕ_{out}	The tank that effluent flows from	Takes a value of 1 or 2
ϕ_1	Conditions in tank 1	Takes a value of 0, 1, or 2
ϕ_2	Conditions in tank 2	Takes a value of 0, 1, or 2

As noted in table 2, digit ϕ_1 and ϕ_2 can take values between 0-2. They define the conditions in tank 1 and 2, respectively. The three possible options are:

0: Anaerobic conditions without aeration and mixing.

- 1: Anoxic conditions (denitrification) without aeration and with mixing.
- 2: Aerobic conditions (nitrification) with aeration and mixing.

Example

A phasecode $\phi = 1112$ means: inflow to tank 1, outflow from tank 1, denitrification in tank 1 and nitrification in tank 2.

A phasecode $\phi = 1222$ means: inflow to tank 1, outflow from tank 2, nitrification in tank 1 and nitrification in tank 2. A phasecode $\phi = 2222$ means: inflow to tank 2, outflow from tank 2, nitrification in tank 1 and nitrification in tank 2.

2.2.5 Quality Assessment

Each signal in the dataset is accompanied by a corresponding quality signal that evaluates its quality at every time step. The quality is indicated by an integer, following this rule:

0 = Good quality 1 = Bad quality

A straightforward quality assessment is performed for each signal collected in the HPP. A measurement can be classified as having poor quality due to two reasons: (1) the sensor itself indicates poor quality, typically due to maintenance issues as specified by the manufacturer, or (2) the value remains constant over a fixed period, at which point the HPP flags the signal as corrupted.

A watchdog, setpoint, or control state is considered to have poor quality if it is not utilized in the plant's online control system. Similarly, an estimate's quality is considered poor if any of the signals used in its calculation were given poor quality.

The quality assessment is included as a separate variable, resulting in two column names for each measurement. An example is given here for the N_2O measurements: BIOLOGY.LINE 3 TANK 1.N20 value and BIOLOGY.LINE 3 TANK 1.N20 quality. It is noteworthy that the value variable remains unaltered by the quality variable; therefore, users of the dataset who are interested in conducting their own quality assessment can do so, as the values represent raw, unfiltered data.

2.3 Data Visualization and Summary Statistics

Figures 3 and 4 illustrate the hourly and daily variations in N_2O concentation and other measurements and signals. These examples, taken from July 2023 (1 day) and April 2024 (7 days), respectively, demonstrate the dynamic changes



Figure 3: Example of variations in N_2O concentration and other signals over an arbitrary period of 24 hours.

in the process over different time frames. Figure 3 highlights the impact of alternating control of the activated sludge process (ASP), showing the dissolved oxygen setpoint (O2_sp) being regulated with varying phase durations. This variation is also evident in figure 4, where the phase durations of the aeration, inlet tank, and outlet tank fluctuate over time. Additionally, figure 4 provides several instances of storm water mode (SWM) activation due to heavy precipitation. In this special state, the system prioritizes preventing sludge from being discharged from the tanks, which may compromise nutrient removal.

The summary statistics are presented in table 3 and provide a comprehensive view of the data characteristics for each sensor measurement included in the dataset. For the control inputs and phase descriptions, i the statistics are a representation of the state of the system. Below is the explanation of each column in the table:

• Variable: The name of the data column in the dataset.



Figure 4: Example of variations in N₂O concentration and other signals over an arbitrary period of 7 days.

- Mean: The average value of each variable.
- Std: The standard deviation of each variable.
- Min: The minimum value of each variable.
- Q1: The first quartile (25th percentile) of each variable.
- Q2: Median (50th percentile) of each variable.
- Q3: The third quartile (75th percentile) of each variable.
- Max: The maximum value of each variable.

Table 3: Summary statistics of the raw data. The rows are color-coded to indicate the signal type: measurement (blue), estimated values (orange), controlled states (yellow), and watchdog (green).

Variable	mean	std	min	Q1	Q2	Q3	max
INLET.Q value	3080.9	2329.9	-5572.5	2095.5	2303.8	4329.9	17192.6
BIOLOGY.BLOWERSTATION 1.Q.AIRFLOW value		7333.1	0.0	11552.6	16754.5	21765.0	43356.6
BIOLOGY.LINE 3 TANK 1.N2O value	0.1	0.2	-0.0	-0.0	0.0	0.1	12.0
BIOLOGY.LINE 3 TANK 1.NH4 value	2.3	2.2	-0.0	1.0	1.9	3.0	20.0
BIOLOGY.LINE 3 TANK 1.NO3 value	2.8	2.8	-0.3	1.2	2.2	3.7	52.7
BIOLOGY.LINE 3 TANK 1.O2 value	0.6	0.6	-0.0	0.2	0.3	1.0	10.9
BIOLOGY.LINE 3 TANK 1.SS value	2.6	0.9	0.0	2.1	2.5	3.0	35.1
BIOLOGY.LINE 3 TANK 1.TEMPERATURE value	15.7	3.4	6.5	12.6	15.7	18.9	27.1
BIOLOGY.LINE 3 TANK 1.PO4 value	1.1	1.0	0.0	0.5	0.9	1.4	16.6
BIOLOGY.LINE 3 TANK 2.02 value	0.7	0.8	-0.0	0.2	0.4	1.1	10.9
BIOLOGY.LINE 3 TANK 2.SS value	2.6	0.9	0.0	2.0	2.7	3.2	50.1
BIOLOGY.LINE 3 TANK 2.TEMPERATURE value	15.6	3.4	6.3	12.6	15.5	18.8	27.1
BIOLOGY.LINE 3 TANK 1.Q.AIRFLOW value	2185.0	2131.2	0.0	0.0	2160.6	4008.8	12973.0
BIOLOGY.LINE 3 TANK 2.Q.AIRFLOW value	2156.1	2091.7	0.0	0.0	2128.8	3903.5	12703.3
BIOLOGY.LINE 3 TANK 1 VALVE 1.PCT value	44.5	42.1	0.0	0.0	40.8	89.6	100.0
BIOLOGY.LINE 3 TANK 1.02.SETPOINT value	0.6	0.6	0.0	0.0	1.0	1.0	2.5
BIOLOGY.LINE 3 TANK 1.PROCESSPHASE value	1.5	0.6	0.0	1.0	2.0	2.0	2.0
BIOLOGY.LINE 3 TANK 2 VALVE 1.PCT value	43.3	41.0	0.0	0.0	34.1	83.3	100.0
BIOLOGY.LINE 3 TANK 2.02.SETPOINT value	0.7	0.6	0.0	0.0	1.0	1.1	2.5
BIOLOGY.LINE 3 TANK 2.PROCESSPHASE value	1.5	0.6	0.0	1.0	2.0	2.0	2.0
BIOLOGY.LINE 3.PHASECODE.SETPOINT value	NA	NA	0.0	1112.0	1222.0	2221.0	2222.0
BIOLOGY.LINE 3.PROCESSPHASE.INLET TANK value	1.5	0.5	0.0	1.0	1.0	2.0	2.0
BIOLOGY.LINE 3.PROCESSPHASE.OUTLET TANK value	1.5	0.5	0.0	1.0	2.0	2.0	2.0
INLET.STATE.SWM INLET FLOW value	0.1	0.3	0.0	0.0	0.0	0.0	1.0

Ethics Statement

This research does not involve experiments, observations, or data collection related to human or animal subjects.

Declaration of competing interest

The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

Data Availability

https://data.mendeley.com/datasets/xmbxhscgpr/1

Acknowledgement

We extend our sincere gratitude to Avedøre WWTP for their cooperation and for granting us permission to use and publish their data. Their support has been invaluable to this research. This research was supported by Aalborg University and Krüger Veolia under the Danish Innovation Foundation grant number 1044-00031B.

References

- 1. Hansen, L. D., Stentoft, P. A., Ortiz-Arroyo, D. & Durdevic, P. Exploring data quality and seasonal variations of N2O in wastewater treatment: a modeling perspective. *Water Practice* & *Technology*, wpt2024045 (2024).
- 2. Law, Y., Ye, L., Pan, Y. & Yuan, Z. Nitrous oxide emissions from wastewater treatment processes. *Philosophical Transactions of the Royal Society B: Biological Sciences* **367**, 1265–1277. ISSN: 14712970 (2012).
- 3. IPCC. Climate Change 2013: The Physical Science Basis. Contribution of Working Group I to the Fifth Assessment Report of the Intergovernmental Panel on Climate Change tech. rep. (Cambridge University Press, Cambridge, United Kingdom and New York, USA, 2013), 1535.
- 4. Unisense Environment A/S. *N2O WASTEWATER SYSTEM* 2022. https://unisense-environment.com/wp-content/uploads/2022/11/2022.11-N2O-WW-System_english-2.pdf.