# Leveraging Convex Relaxation to Identify the Feasibility of Conducting AC False Data Injection Attack in Power Systems

1<sup>st</sup> Mohammadreza Iranpour

Department of Electrical and Computer Engineering California State University Northridge (CSUN) Los Angels, USA

arXiv:2502.20464v1 [eess.SY] 27 Feb 2025

Abstract-FDI (False Data Injection) attacks are critical to address as they can compromise the integrity and reliability of data in cyber-physical systems, leading to potentially severe consequences in sectors such as power systems. The feasibility of FDI attacks has been extensively studied from various perspectives, including access to measurements and sensors, knowledge of the system, and design considerations using residual-based detection methods. Most research has focused on DC-based FDI attacks; however, designing AC FDI attacks involves solving a nonlinear optimization problem, presenting additional challenges in assessing their feasibility. Specifically, it is often unclear whether the infeasibility of some designed AC FDI attacks is due to the nonconvexity and nonlinearity inherent to AC power flows or if it stems from inherent infeasibility in specific cases, with local solvers returning infeasibility. This paper addresses this issue by leveraging the principle that if a convexified AC FDI attack design problem is infeasible, the attack design itself is infeasible, irrespective of nonlinear solution challenges. We propose an AC FDI attack design based on convexified power flow equations and assess the feasibility of the proposed attack by examining the extent of the attackable region. This approach utilizes a Quadratic Convex (QC) relaxation technique to convexify AC power flows. To evaluate the proposed method, we implement it on the IEEE 118-bus test system and assess the feasibility of an AC FDI attack across various attack zones.

# I. INTRODUCTION

False Data Injection (FDI) attacks pose a significant threat to the integrity and reliability of modern power systems. These attacks involve injecting malicious data into the system's state estimation process, leading to incorrect operational decisions that can compromise the grid's stability and security. Numerous studies have reviewed FDI attacks, focusing on the requirements for conducting FDI attacks, construction methods, and detection and defense strategies. The construction methods have been examined from various perspectives, including FDI attacks with limited budgets, those based on state estimation with incomplete system knowledge, and data-driven approaches. In all of these cases, the feasibility of implementing a successful attack has been demonstrated and analyzed [1]–[3]. In these cases, the attacker needs to create a plan that fits the specific circumstances and goals. making sure the attack remains undetected while achieving its objectives [4]-[7].

While there has been a lot of research on DC-based FDI attacks, there is much less work on AC FDI attacks, and only a few studies have been published on this topic [8]–[12]. The primary challenge in designing AC FDI attacks lies in the non-linear nature of AC power flow equations. Unlike DC power flow models, which are linear and easier to manipulate, AC models require solving non-linear optimization problems [11].

This work has been supported from NSF contract #2308498.

2<sup>nd</sup> Mohammad Rasoul Narimani Department of Electrical and Computer Engineering California State University Northridge (CSUN) Los Angels, USA Rasoul.narimani@csun.edu

Although some research, such as [9], has studied AC-based FDI attacks based on linearization around the target state under the assumption that SE is obtained, there are limited resources that have used convexification techniques to assess the feasibility of an AC FDI attack. For instance, in [13], a novel convexification framework based on semidefinite programming (SDP) is employed to delineate the "attackable region" for any given set of measurement types and grid topology.

In general, these problems involve non-linear variables, making it difficult to determine the feasibility of an attack. Specifically, it is often unclear whether an infeasible attack is due to the inherent challenges of solving a non-linear optimization problem or the infeasibility of the attack design itself. This hidden factor may hinder the successful design of an attack, a consideration that has not been addressed in recent studies. To address these challenges, this paper leverages a critical insight: if a convexified AC FDI attack is infeasible, the attack design itself is inherently infeasible, regardless of the non-linear nature of the problem [14]–[19]. This insight allows us to bypass the difficulties associated with non-linear optimization by focusing on the convexified version of the problem.

We propose a novel approach to designing AC FDI attacks based on convexified power flow equations. In fact, building on the work done in [11], we have replaced the nonlinear power flow equations in the AC FDI attack process with convexified power flow equations. Many recent research efforts have developed convex relaxations of nonlinear power flow problems, as reviewed in [20]. Semidefinite programming, second-order cone programming, linear relaxation of power flow equations, and quadratic convex (OC) relaxation methods are examples of well-known approaches for convexifying nonlinear power flow equations. We use a Ouadratic Convex (OC) relaxation technique to transform the nonlinear AC power flow equations into a convex form [19]. This transformation simplifies the problem, making it easier to assess the feasibility of the attack design. If an attack designed in the convexified format is infeasible, it will certainly be infeasible in the nonlinear situation due to the design constraints. The Quadratic Convex (QC) relaxation is a promising approach that constructs convex envelopes around the trigonometric and product terms in the polar representation of the power flow equations [21]. In this paper, by defining these envelopes and also defining new corresponding linear variables for nonlinear variables, we have convexified the nonlinear power flow equations and then designed AC FDI attacks based on these equations.

This paper is organized as follows. In Section II, we model an AC False Data Injection (FDI) attack based on the nonlinear power flow equations. Section III presents the convexification process of these nonlinear power flow equations using the Quadratic Convex (QC) relaxation method. In Section IV, we analyze the efficiency of the proposed method in assessing the feasibility of AC FDI attacks by implementing it on the IEEE 118-bus test system. Finally, Section V concludes the paper.

#### II. OPTIMAL DESIGNING OF AC FDI ATTACK

Designing an optimal AC false data injection (FDI) attack requires solving a challenging nonlinear optimization problem. Researchers have studied various methods for creating these optimal attacks. In this paper, we aim to optimize the magnitude of the attack vector injected into the targeted measurements using the unified approaches discussed in [11].

The metering process in modern power systems can be prone to errors, which may impact State Estimation (SE) operations. To identify these errors, the residual (the difference between observed measurements (z) and estimated values (h(x))) is used as a detection parameter. If this residual exceeds a predefined threshold, it indicates the presence of bad data. This process is known as Bad Data Detection (BDD). However, if attackers inject a false data set (c) into these measurements in a way that satisfies equation (1), and then use an attack vector a based on equation (2), they can manipulate the data without being detected by the system's detection modules.

$$r_{a} = z_{a} - h(x_{a})$$
  
=  $z_{a} - h(x_{a}) + h(x) - h(x)$   
=  $z + a - h(x_{a}) + h(x) - h(x)$   
=  $r + a - h(x_{a}) + h(x)$ . (1)

$$a = h(x_a) - h(x). \tag{2}$$

In these equations,  $r_a$  and r are the residuals for underattack and normal measurements, respectively.  $x_a = x + c$  and x are state vectors for under-attack and normal measurements, respectively. h is the set of nonlinear power flow equations that relate measurements and states. Based on this assumption, the key to designing a successful attack vector a in Equation (2) is determining the function h(x). By considering the following steps and assumptions, we can define this nonlinear function and then the attack vector a.

- Rationalizing Changes in Power Flow Equations: The attack must justify any changes in power flow equations resulting from the injected false data.
- 2) Defining Attacked and Normal Areas: The attack area, where changes occur, should be delineated from the unaffected normal area. The attack area includes a contiguous set of buses, while the normal area remains unchanged.
- 3) Maintaining Power Transfers: During an FDI attack, the total power transferred between the affected and unaffected areas must stay the same. To achieve this, the attack area should be enclosed by buses that inject power. These buses manage power changes within the attack zone by creating specific injection measurements. Additionally, the state variables at the boundary of the attack area must stay the same to keep all changes confined within the attack zone. To define the attack zone, key focal buses have been chosen and the area has

been expanded by including buses that inject no power and neighboring buses that inject power as the boundary.

4) Algebraic Sum of Power in the Attack Zone: In the attack zone, the total power generated and consumed must remain unchanged. For buses that neither inject nor draw power, the sum of active and reactive power flows must be zero. For buses that do inject or draw power, the power injection after the attack equals the original injection power plus the changes in power flow in the lines connected to them within the attack zone.

Continuing, we have modeled these assumptions as an optimization problem to calculate the attack vector a. Suppose the sets of buses and lines in the system are represented by  $\mathcal{B}$ , and  $\mathcal{L}$ , respectively. Also,  $\mathcal{B}_{\mathcal{A}}$ , and  $\mathcal{L}_{\mathcal{A}}$  are the corresponding sets of buses and lines within the attack zone. Let  $S_m = P_m + jQ_m$ represent the complex power injection,  $V_m$  and  $\theta_m$  represent the voltage magnitude and angle at bus  $m \in \mathcal{B}_{\mathcal{A}}$ , each line  $(m, l) \in \mathcal{L}_{\mathcal{A}}$  is modeled as a II circuit with mutual admittance  $g_{ml} + jb_{ml}$  and shunt admittance  $jb_{c,ml}$  and the voltage angle difference between buses m and l for  $(m, l) \in \mathcal{L}$  is denoted as  $\theta_{ml} = \theta_m - \theta_l$ . The difference between state variables, including both voltage magnitudes and angles, and their values before the FDI attack is shown in Equation (3) as vector c.

$$c = [\tilde{V}_m - V_{m,fix}, \hat{\theta}_m - \theta_{m,fix}]$$
(3)

Where  $\tilde{V}_m$  and  $\tilde{\theta}_m$  are the variables representing the voltage magnitude and angle that need to be calculated to conduct the attack, and  $V_{m,fix}$  and  $\theta_{m,fix}$  are the known values of voltage magnitude and angle before the attack. By minimizing the sum of squared differences between the variable states before and after the attack as the objective function, we can optimize the attack vector for designing the AC FDI attack problem, as represented in Equations (4a)-(4i).

$$\min \sum_{m \in \mathcal{B}_{\mathcal{A}}} \left( \tilde{V}_m - V_{m,fix} \right)^2 + \left( \tilde{\theta}_m - \theta_{m,fix} \right)^2 \right) \quad (4a)$$

subject to  $(\forall i \in \mathcal{B}_{\mathcal{A}}, \forall (l, m) \in \mathcal{L}_{\mathcal{A}})$ 

(

 $P_{ml}$ 

$$g_{sh,i}\tilde{V}_i^2 + \sum_{\substack{(l,m)\in\mathcal{L},\\\text{s.t. }l=i}}\tilde{P}_{lm} + \sum_{\substack{(l,m)\in\mathcal{L},\\\text{s.t. }m=i}}\tilde{P}_{ml} = P_{i,G} - P_{i,D}, \qquad (4b)$$

$$-b_{sh,i}\tilde{V}_i^2 + \sum_{\substack{(l,m)\in\mathcal{L},\\st=l-i}} \tilde{Q}_{lm} + \sum_{\substack{(l,m)\in\mathcal{L},\\st=m-i}} \tilde{Q}_{ml} = Q_{i,G} - Q_{i,D}, \qquad (4c)$$

$$\tilde{P}_{lm} = g_{lm} \tilde{V}_l^2 - g_{lm} \tilde{V}_l V_m \cos\left(\tilde{\theta}_l - \theta_m\right) - b_{lm} \tilde{V}_l V_m \sin\left(\tilde{\theta}_l - \theta_m\right),$$
(4d)

$$\tilde{Q}_{lm} = -\left(b_{lm} + b_{c,lm}/2\right)\tilde{V}_l^2 + b_{lm}\tilde{V}_lV_m\cos\left(\tilde{\theta}_l - \theta_m\right) - g_{lm}\tilde{V}_lV_m\sin\left(\tilde{\theta}_l - \theta_m\right),$$
(4e)

$$\tilde{P}_{ml} = g_{lm} V_m^2 - g_{lm} \tilde{V}_l V_m \cos\left(\tilde{\theta}_l - \theta_m\right) + b_{lm} \tilde{V}_l V_m \sin\left(\tilde{\theta}_l - \theta_m\right),$$
(4f)

$$\tilde{Q}_{ml} = -\left(b_{lm} + b_{c,lm}/2\right)V_m^2 + b_{lm}\tilde{V}_lV_m\cos\left(\tilde{\theta}_l - \theta_m\right) + g_{lm}\tilde{V}_lV_m\sin\left(\tilde{\theta}_l - \theta_m\right)$$
(4g)

$$= W_{lm} * P_{lm}^{PF}, \tag{4h}$$

$$\tilde{Q}_{ml} = W_{lm} * Q_{lm}^{PF}.$$
(4i)

In these equations  $\tilde{P}_{ml}$ ,  $\tilde{Q}_{ml}$ ,  $\tilde{V}_l(\tilde{V}_m)$  and  $\tilde{\theta}_l(\tilde{\theta}_m)$  represent the active and reactive power flow between buses m and  $l (m, l) \in \mathcal{L}$ , and the voltage magnitude and angle values of buses m and l, after the attack. Similarly,  $P_{ml}$ ,  $Q_{ml}$ ,  $V_l(V_m)$  and  $\theta_l(\theta_m)$  represent the same quantities before the attack. Additionally,  $P_{m,G}$ ,  $Q_{m,G}$ ,  $P_{m,D}$ , and  $Q_{m,D}$  are the active and reactive power generation and demand at bus m, respectively. It is notable that in Equations (4b) and (4c), when these equations are written for zero-injection buses, the righthand side of these equations is equal to zero. Equations 4h and 4i are additional constraints for overloading a specified line in the attack zone by a predefined coefficient W. By considering this constraint, we can design an optimal AC FDI attack for specific goals, such as overloading a certain line by a predefined coefficient.  $P_{lm}^{PF}$  and  $Q_{lm}^{PF}$  are the active and reactive power flows before the attack. After solving this optimization problem, we can calculate the power injection values for non-zero injection buses within the attack zone as follows:

$$\tilde{P}_m = P_m + \sum_{(m,l)\in\mathcal{L}_A} (\tilde{P}_{m,l} - P_{m,l}),$$
(5a)

$$\tilde{Q}_m = Q_m + \sum_{(m,l)\in\mathcal{L}_{\mathcal{A}}} (\tilde{Q}_{m,l} - Q_{m,l}).$$
(5b)

Here,  $\tilde{P_m}$ ,  $\tilde{Q_m}$ ,  $P_m$ , and  $Q_m$  represent the active and reactive power injections at bus m after and before the attack, respectively. Notably, in Equations (5a),  $\tilde{P}m, l$  and  $\tilde{Q}m, l \in \mathcal{L}_A$  should be considered only for the lines within the attack zone that are connected to bus m. After calculating all of these values, we can define the attack vector a based on Equation (2). The attack vector a is determined by the difference between the calculated values of power injections and their corresponding values before the attack, ensuring that the designed attack effectively meets the specified objectives. By accurately defining and optimizing a, we can achieve a successful AC FDI attack while adhering to the constraints and goals set for the attack.

$$a = [\tilde{P_{ml}} - P_{ml}, \tilde{Q_{ml}} - Q_{ml}, \tilde{P_m} - P_m, \\ \tilde{Q_m} - Q_m, \tilde{V_m} \angle \tilde{\theta_m} - V_m \angle \theta_m]^T$$

#### III. THE QC RELAXATION OF THE PROPOSED PROBLEM

As mentioned in Section I, the quadratic convex (QC) relaxation [21] is a promising approach that utilizes convex envelopes around non-convex terms, including trigonometric functions, squared terms, and bilinear products. This method transforms the original non-convex problem into a convex one, which is generally easier to solve. The effectiveness of QC relaxation largely depends on the size and tightness of the variable bounds. By minimizing a linear objective function over the convex region defined by these convex envelopes, QC relaxation provides solutions that are either exact or close approximations to the original problem. This technique has demonstrated significant success in solving or approximating solutions for many practical problems, particularly those that are NP-hard and challenging to tackle with traditional methods [16], [22], [23]. The approach has been applied to various

fields, including operations research, engineering, and economics, showcasing its versatility and robustness. For further details and comprehensive overviews of QC relaxation and its diverse applications, please refer to the cited reference [20].

The QC relaxation is formed by introducing new variables  $w_{ii}$ ,  $w_{lm}$ ,  $c_{lm}$ , and  $s_{lm}$  to represent the products of voltage magnitudes and trilinear monomials. These new variables capture the interactions between voltage magnitudes and trigonometric functions for connected buses. Specifically,  $w_{ii}$  represents the squared terms of voltage magnitudes,  $w_{lm}$  captures the product of voltage magnitudes at different buses,  $c_{lm}$  denotes the bilinear terms involving voltage magnitudes and trigonometric functions, and  $s_{lm}$  corresponds to additional trilinear products involving these functions. Equation (6) mathematically represents these terms. By defining these variables, the QC relaxation transforms the original non-convex problem into a convex one, making it more tractable to solve while providing useful approximations or exact solutions for complex optimization challenges.

$$w_{ii} = V_i^2, \qquad \forall i \in \mathcal{N}, \qquad (6a)$$

$$w_{lm} = V_l V_m, \qquad \forall (l,m) \in \mathcal{L},$$
 (6b)

$$c_{lm} = w_{lm} \cos\left(\theta_{lm}\right), \qquad \forall (l,m) \in \mathcal{L}, \qquad (6c)$$

$$s_{lm} = w_{lm} \sin(\theta_{lm}), \qquad \forall (l,m) \in \mathcal{L}.$$
 (6d)

For each line  $(l,m) \in \mathcal{L}$ , these definitions imply the following relationships between the variables  $w_{ll}$ ,  $c_{lm}$ , and  $s_{lm}$ :

$$c_{lm}^2 + s_{lm}^2 = w_{ll} w_{mm}, (7a)$$

$$c_{lm} = c_{ml},\tag{7b}$$

$$g_{lm} = -s_{ml} \tag{7c}$$

The QC relaxation is formulated by enclosing the squared and bilinear product terms within convex envelopes, which are represented here as set-valued functions:

$$\langle x^2 \rangle^T = \begin{cases} \check{x} : \begin{cases} \check{x} \ge x^2, \\ \check{x} \le (\overline{x} + \underline{x}) x - \overline{x}\underline{x}. \end{cases}$$
(8a)

$$\langle xy \rangle^{M} = \begin{cases} \widetilde{xy} : \begin{cases} \widetilde{xy} \ge \underline{xy} + \underline{yx} - \underline{xy}, \\ \widetilde{xy} \ge \overline{xy} + \overline{yx} - \overline{xy}, \\ \widetilde{xy} \le \underline{xy} + \overline{yx} - \overline{xy}, \\ \widetilde{xy} \le \overline{xy} + \underline{yx} - \overline{xy}. \end{cases}$$
(8b)

where  $\check{x}$  and  $\check{xy}$  are "auxiliary" variables representing the corresponding sets. The envelope  $\langle x^2 \rangle^T$  denotes the convex hull of the squared function, while the so-called "McCormick envelope"  $\langle xy \rangle^M$  represents the convex hull of a bilinear product, as discussed in [24]–[26]. Additionally, the QC relaxation includes the formulation of convex envelopes for trigonometric functions, specifically  $\langle \sin(x) \rangle^S$  and  $\langle \cos(x) \rangle^C$ . These envelopes are designed to approximate the sine and cosine functions, respectively, by providing convex relaxations that simplify the optimization process. The envelopes  $\langle \sin(x) \rangle^S$  and  $\langle \cos(x) \rangle^C$  are constructed as follows:

$$\langle \sin(x) \rangle^S =$$

$$\begin{cases} \check{S} : \begin{cases} \check{S} \leqslant \cos\left(\frac{x^{m}}{2}\right)\left(x - \frac{x^{m}}{2}\right) + \sin\left(\frac{x^{m}}{2}\right), \\ \check{S} \geqslant \cos\left(\frac{x^{m}}{2}\right)\left(x + \frac{x^{m}}{2}\right) - \sin\left(\frac{x^{m}}{2}\right), \\ \check{S} \geqslant \frac{\sin(x) - \sin(\overline{x})}{x - \overline{x}}\left(x - \underline{x}\right) + \sin\left(\underline{x}\right) \text{ if } \underline{x} \geqslant 0, \\ \check{S} \leqslant \frac{\sin(x) - \sin(\overline{x})}{x - \overline{x}}\left(x - \underline{x}\right) + \sin\left(\underline{x}\right) \text{ if } \overline{x} \leqslant 0. \end{cases}$$

$$(9a)$$

$$\begin{split} \left\langle \cos(x) \right\rangle^{C} &= \\ \left\{ \begin{split} &\check{C} : \left\{ \begin{split} &\check{C} \leqslant 1 - \frac{1 - \cos(x^{m})}{(x^{m})^{2}} x^{2}, \\ &\check{C} \geqslant \frac{\cos(x) - \cos(\overline{x})}{x - \overline{x}} \left( x - \underline{x} \right) + \cos\left(\underline{x}\right). \end{split} \right. \end{split} \tag{9b}$$

where  $x^m = \max(|\underline{x}|, |\overline{x}|)$ . The auxiliary variables  $\check{S}$  and  $\check{C}$  again represent the corresponding set. For  $-90^\circ < \underline{x} < \overline{x} < 90^\circ$ , bounds on the sine and cosine functions are:

$$\underline{s} = \sin(\underline{x}) \leqslant \sin(x) \leqslant \overline{s} = \sin(\overline{x}), \qquad (10a)$$

$$\underline{c} = \min(\cos(\underline{x}), \cos(\overline{x})) \leqslant \cos(x)$$

$$\leqslant \overline{c} = \begin{cases} \max(\cos(\underline{x}), \cos(\overline{x})), \text{ if } \operatorname{sign}(\underline{x}) = \operatorname{sign}(\overline{x}), \\ 1, \text{ otherwise.} \qquad (10b) \end{cases}$$

By substituting the squared, product, and trigonometric terms in Equations 4a-(4g) with the new variables  $w_{ii}$ ,  $w_{lm}$ ,  $c_{lm}$ , and  $s_{lm}$ , we can reformulate these equations to incorporate the convex envelopes. This substitution allows us to express the original equations in terms of these new variables, leading to a more tractable optimization problem. The convexified equations are as follows:

$$\min \sum_{m \in \mathcal{B}_{\mathcal{A}}} \left( \tilde{V}_m - V_{m,fix} \right)^2 + (\tilde{\theta}_m - \theta_{m,fix})^2 \right)$$
(11a)  
while the equation of th

subject to  $(\forall i \in \mathcal{B}_{\mathcal{A}}, \forall (l, m) \in \mathcal{L}_{\mathcal{A}})$ 

$$P_{i}^{g} - P_{i}^{d} = g_{sh,i} w_{ii} + \sum_{\substack{(l,m) \in \mathcal{L} \\ \text{s.t. } l = i}} P_{lm} + \sum_{\substack{(l,m) \in \mathcal{L} \\ \text{s.t. } m = i}} P_{ml}, \quad (11b)$$

$$Q_{i}^{g} - Q_{i}^{d} = -b_{sh,i} w_{ii} + \sum_{\substack{(l,m) \in \mathcal{L} \\ \text{s.t. } l = i}} Q_{lm} + \sum_{\substack{(l,m) \in \mathcal{L} \\ \text{s.t. } m = i}} Q_{ml}, \quad (11c)$$

$$(\underline{V}_i)^2 \leqslant w_{ii} \leqslant (\overline{V}_i)^2, \tag{11d}$$

$$P_{lm} = g_{lm}w_{ll} - g_{lm}c_{lm} - b_{lm}s_{lm},$$
(11e)

$$Q_{lm} = -(b_{lm} + b_{sh,lm}/2) w_{ii} + b_{lm}c_{lm} - g_{lm}s_{lm}, \quad (11f)$$
$$w_{ii} \in \langle V^2 \rangle^T \quad (11g)$$

$$w_{ii} \in \langle V_i \rangle , \qquad (11g)$$

$$w_{ii} \in \langle V_i \rangle \rangle^M \qquad (11h)$$

$$w_{lm} \in \langle V_l V_m \rangle \quad , \tag{111}$$

$$c_{lm} \in \left\langle w_{lm} \left\langle \cos\left(\theta_{lm}\right) \right\rangle^{\circ} \right\rangle , \qquad (11i)$$

$$s_{lm} \in \left\langle w_{lm} \left\langle \sin\left(\theta_{lm}\right) \right\rangle^{S} \right\rangle , \qquad (11j)$$

Equations 
$$(4h)$$
- $(4i)$ ,  $(7b)$ ,  $(7c)$ . (11k)

Note that the trilinear terms in (4b)– (4g) are addressed in (11h)–(11j) by recursively applying McCormick envelopes (8b) (i.e., first applying (8b) to the product of voltage magnitudes to obtain  $w_{lm}$  and then to the product of  $w_{lm}$  and  $\langle \cos(\theta_{lm}) \rangle^C$  or  $\langle \sin(\theta_{lm}) \rangle^S$ ). The optimization problem described in Equation (11) involves a quadratic objective function with linear constraints. The objective function is represented as  $\frac{1}{2}x^TQx + c^Tx + d$ , where Q is a symmetric matrix. When Q is positive semidefinite (PSD), the quadratic function becomes convex. As a result, the problem can be classified as a convex quadratic program (QP). Convex QPs can be solved globally, ensuring that the solutions found are optimal. For convex QPs, various algorithms like interior-point methods, active-set methods, and gradient-based methods can be used. These methods are designed to find the global minimum efficiently.

Based on these relaxed power flow equations, we can design an AC FDI attack using the process outlined in Section II. It is important to note that, in this context, we need to fix all corresponding variables in their relaxed format, including those in Equation 6 ( $w_{ii}$ ,  $w_{lm}$ ,  $c_{lm}$ , and  $s_{lm}$ ) for the variables in the out-of-the-attack zone. Additionally, to ensure that all changes are confined within the attack zone,  $w_{ii}$  should be fixed for the boundary buses in this new set of convexified equations.

### IV. EFFICIENCY ASSESSMENT OF PROPOSED METHOD

In this section, the proposed approach for assessing the feasibility of conducting optimal AC-FDI attacks is applied to the IEEE 118-bus test system from the PGLib-OPF v18.08 benchmark library [27] to evaluate its effectiveness. We have implemented two different scenarios for this purpose. In the first scenario, we demonstrate whether an optimal AC-FDI attack can be feasible or infeasible by considering two different attack zones. In the second scenario, we show how varying the values of W in constraint (4h) affects the feasibility of the optimal AC-FDI attack, as addressed in Equation 11, within a specific zone.

#### First Scenario:

In this scenario, we considered two different attack zones and designed AC FDI attacks for those zones using the proposed methods in Sections II and III. In this regard, as shown in Fig. 1, we first consider buses 13, 14, 15, 17, 18, 19, 20, 21, 22, 33 and 34 as attack zone 1. By implementing the design process based on the convexified power flow equations and setting W = 1.2 in constraint (4h) for the line between buses 18 and 19, the solver can find a feasible solution for the objective function. The corresponding values of voltage magnitudes and angles of buses in the attack zone before and after the attack are listed in Table I.

It is noteworthy that in Table I, the voltages of boundary buses remain unchanged after the attack to prevent the spread of power transmission changes in the lines. However, the voltage magnitudes and angles of targeted buses in the attack zone have changed. In Table I, gray cells correspond to the buses in the attack zone with variable values, while white cells indicate boundary buses with fixed voltage magnitudes and angles. Additionally, all power flow and power injection measurements in the lines and buses of the attack zone that need to be manipulated to implement a successful attack are shown in red in Fig. 1.

Furthermore, when considering buses 15, 18, 19, 20, 21, 33 and 34 as the second attack zone, as shown in Fig. 1, the solver fails to find a feasible solution for the objective function. This indicates that the corresponding QP problem, the optimization problem in (11), and consequently there is a guarantee that the nonconvex nonlinear optimization problem in (4) has no feasible solution, which is a crucial point in designing AC FDI attack. While the aim of designing a sparse attack vector is to target zones with fewer measurements, it's important to note that making the region smaller can render the solution infeasible. Therefore, a trade-off must be struck between minimizing the area and ensuring solution feasibility.



Figure 1. One-line diagram depicting the IEEE 118-bus test system, with the attack zones indicated.

Table I Voltage magnitude and angle of busses in the first attack zone of first scenario, for before and after a feasible optimal attack.

Bus Number	Before Attack		<b>Optimal Feasible Attack</b>	
	Voltage Magnitude	Voltage Angle	Voltage Magnitude	Voltage Angle
13	0.9683	11.6297	0.9683	11.6297
14	0.9836	11.7715	0.9836	11.7715
15	0.97	11.4741	0.9707	11.4594
17	0.9951	13.9952	0.9951	13.9952
18	0.973	11.7808	0.9956	11.763
19	0.962	11.3146	0.946	11.3034
20	0.9569	12.191	0.9578	12.1781
21	0.9577	13.778	0.9586	13.7611
22	0.969	16.3316	0.969	16.3316
33	0.9709	10.8538	0.9709	10.8538
34	0.984	11.5114	0.984	11.5114

# Second Scenario :

In this scenario, we considered buses 15, 18, 19, 20, 33, 34and 36 as the third attack zone as it is shown in Fig.2. If we enforce constraint (4h) for the line between buses 18 and 19 with W = 1.2, the solver can find a feasible solution for Equation (11). The corresponding values of voltage magnitudes and angles of buses in the attack zone, before and after the attack implementation, are listed in Table II. In this table, grav cells correspond to the buses in the attack zone with variable values, while white cells indicate boundary buses with fixed voltage magnitudes and angles. By enforcing power flow in the line that connects buses 18 and 19, i.e., setting W = 2in Equation 4h, the solver fails to find a feasible solution for the relaxed problem. Consequently, there will be no solution for the original optimization problem in (4). Moreover, this demonstrates that modifying the constraints of the proposed optimization problem can lead to infeasibility. Thus, both the size of the attack area and the constraints can contribute to the infeasibility of the optimal AC FDI attack. If the convex problem in (11) is infeasible then the corresponding nonlinear problem solution is certainly infeasible because the solver cannot find a feasible solution for the proposed problem. By convexifying the design of the AC FDI attack problem, we can easily check if the problem is feasible and has a solution,

Table II Voltage magnitude and angle of busses in the third attack zone of the second scenario, for before and after feasible optimal attack situations.

Bus Number	Before attack		Optimal feasible attack	
	Voltage Magnitude	Voltage Angle	Voltage Magnitude	Voltage Angle
13	0.9683	11.6297	0.9683	11.6297
14	0.9836	11.7715	0.9836	11.7715
15	0.97	11.4741	0.9477	11.4456
17	0.9951	13.9952	0.9951	13.9952
18	0.973	11.7808	0.9704	11.7238
19	0.962	11.3146	0.9615	11.2656
20	0.9569	12.191	0.9569	12.191
33	0.9709	10.8538	0.9709	10.8538
34	0.984	11.5114	0.984	11.5114

unlike the nonconvex problem which cannot be solved using current local solvers even if a solution exists. Thus, the proposed method can be exploited to ensure the feasibility of conducting an AC FDI attack.

# V. CONCLUSION

This paper addresses the challenges in assessing the feasibility of designing AC False Data Injection (FDI) attacks. While most existing research has focused on DC-based FDI attacks, AC FDI attacks present additional complexities due to the need to solve nonlinear optimization problems. This study highlights the difficulty in distinguishing between the infeasibility of an attack due to the nonlinearity and nonconvexity associated with the AC FDI attack design problem and the inherent infeasibility of the attack design itself. To overcome these challenges, we proposed a method that utilizes convexified power flow equations to design AC FDI attacks. By employing a Quadratic Convex (QC) relaxation technique, we were able to convexify the AC power flows and thereby provide a more straightforward assessment of the attack's feasibility. Our approach was validated on the IEEE 118bus test system, demonstrating its effectiveness in determining the feasibility of optimal AC FDI attacks across different attack zones and various constraints for the objective function. In addition to demonstrating the efficiency of the proposed QC relaxation method in assessing the feasibility of AC FDI



Figure 2. Third attack zone in One-line diagram of the IEEE 118-bus test system.

attacks, the findings in this paper highlight the importance of considering various factors that influence the feasibility of such attacks. These factors include the attack area and the constraints of the optimization problem. This research offers a robust framework for future studies to design optimal AC FDI attacks, addressing perspectives such as sparse AC FDI attacks. Unlike sparse DC FDI attacks, which have been extensively studied, there is limited research on sparse AC FDI attacks. This paper aims to fill that gap and provide a foundation for further exploration in this area.

#### REFERENCES

- [1] M. Zhang, C. Shen, N. He, S. Han, Q. Li, Q. Wang, and X. Guan, "False data injection attacks against smart gird state estimation: Construction, detection and defense," *Science China Technological Sciences*, vol. 62, no. 12, pp. 2077–2087, 2019.
- [2] J. Zhao, L. Mili, and M. Wang, "A generalized false data injection attacks against power system nonlinear state estimator and countermeasures, IEEE Transactions on Power Systems, vol. 33, no. 5, pp. 4868-4877, 2018
- [3] J. Zhang, Z. Chu, L. Sankar, and O. Kosut, "Can attackers with limited information exploit historical data to mount successful false data injection attacks on power systems?" *IEEE Transactions on Power Systems*, vol. 33, no. 5, pp. 4775–4786, 2018.
- [4] O. Boyaci, M. R. Narimani, K. R. Davis, M. Ismail, T. J. Overbye, and E. Serpedin, "Joint detection and localization of stealth false data injection attacks in smart grids using graph neural networks," *Transactions on Smart Grid*, vol. 13, no. 1, pp. 807–819, 2021. IEEE
- [5] O. Boyaci, M. R. Narimani, K. Davis, and E. Serpedin, "Generating connected, simple, and realistic cyber graphs for smart grids," in 2022 IEEE Texas Power and Energy Conference (TPEC). IEEE, 2022, pp. 1-6.
- "Infinite impulse response graph neural networks for cyberattack [6] localization in smart grids," *arXiv preprint arXiv:2206.12527*, 2022.
- [7] systems," in 2022 3rd International Conference on Smart Grid and Renewable Energy (SGRE). IEEE, 2022, pp. 1–6.
- [8] M. Jin, J. Lavaei, and K. H. Johansson, "Power grid ac-based state estimation: Vulnerability analysis against cyber attacks," *IEEE Transactions on Automatic Control*, vol. 64, no. 5, pp. 1784–1799, 2018.
  [9] M. A. Rahman, E. Al-Shaer, and R. G. Kavasseri, "A formal model for
- verifying the impact of stealthy attacks on optimal power flow in power grids," in 2014 ACM/IEEE International Conference on Cyber-Physical
- Systems (ICCPS). IEEE, 2014, pp. 175–186. A. Teixeira, K. C. Sou, H. Sandberg, and K. H. Johansson, "Secure control systems: A quantitative risk management approach," *IEEE* [10] Control Systems Magazine, vol. 35, no. 1, pp. 24-45, 2015. [11] M. Iranpour and M. R. Narimani, "Ac false data injection attacks in
- power systems: Design and optimization," 2024. —, "Designing sparse ac false data injection attack," *arXiv preprint arXiv:2409.18331*, 2024. [12]

- [13] M. Jin, J. Lavaei, and K. Johansson, "A semidefinite programming relaxation under false data injection attacks against power grid ac state estimation," in 2017 55th Annual Allerton Conference on Communication, Control, and Computing (Allerton). IEEE, 2017, pp. 236–243. M. R. Narimani, D. K. Molzahn, K. R. Davis, and M. L. Crow,
- [14] Tightening qc relaxations of ac optimal power flow through improved linear convex envelopes," *arXiv preprint arXiv:2310.14463*, 2023. [15] M. R. Narimani, D. K. Molzahn, and M. L. Crow, "Tightening qc
- relaxations of ac optimal power flow problems via complex per unit normalization," *IEEE Transactions on Power Systems*, vol. 36, no. 1, p. 281–291, 2020.
- [16] M. R. Narimani, Strengthening QC relaxations of optimal power flow problems by exploiting various coordinate changes. Missouri University of Science and Technology, 2020.
- [17] M. R. Narimani, D. K. Molzahn, H. Nagarajan, and M. L. Crow, "Comparison of various trilinear monomial envelopes for convex relaxations of optimal power flow problems," in 2018 IEEE Global Conference on Signal and Information Processing (GlobalSIP). IEEE, 2018, pp. 865-869
- [18] M. R. Narimani, D. K. Molzahn, D. Wu, and M. L. Crow, "Empirical investigation of non-convexities in optimal power flow problems," in 2018 Annual American Control Conference (ACC). IEÊE, 2018, pp. 3847-3854.
- [19] M. R. Narimani, D. K. Molzahn, and M. L. Crow, "Improving qc relaxations of opf problems via voltage magnitude difference constraints and envelopes for trilinear monomials," in 2018 Power Systems Computation Conference (PSCC). IEEE, 2018, pp. 1–7.
- [20] D. K. Molzahn, I. A. Hiskens *et al.*, "A survey of relaxations and approximations of the power flow equations," *Foundations and Trends*® *in Electric Energy Systems*, vol. 4, no. 1-2, pp. 1–221, 2019. C. Coffrin, H. L. Hijazi, and P. Van Hentenryck, "The qc relaxation:
- [21] A theoretical and computational study on optimal power flow," *IEEE Transactions on Power Systems*, vol. 31, no. 4, pp. 3008–3018, 2015. M. R. Narimani, D. K. Molzahn, and M. L. Crow, "Tightening qc
- [22] relaxations of ac optimal power flow problems via complex per unit normalization," IEEE Transactions on Power Systems, vol. 36, no. 1, pp. 281-291, 2021
- [23] M. R. Narimani, D. K. Molzahn, H. Nagarajan, and M. L. Crow, "Comparison of various trilinear monomial envelopes for convex relaxations of optimal power flow problems," in 2018 IEEE Global Conference on Signal and Information Processing (GlobalSIP), 2018, pp. 865–869. [24] B. Kocuk, S. S. Dey, and X. A. Sun, "Strong socp relaxations for the
- optimal power flow problem," *Operations Research*, vol. 64, no. 6, pp. 1177–1196, 2016.
- [25] C. Coffrin, H. L. Hijazi, and P. Van Hentenryck, "Strengthening the sdp relaxation of ac power flows with convex envelopes, bound tightening, and valid inequalities," *IEEE Transactions on Power Systems*, vol. 32, no. 5, pp. 3549-3558, 2016.
- G. P. McCormick, "Computability of global solutions to factorable [26] nonconvex programs: Part i-convex underestimating problems," Math*ematical programming*, vol. 10, no. 1, pp. 147–175, 1976. IEEE PES Task Force on Benchmarks for Validation of Emerging
- [27] Power System Algorithms, "The Power Grid Library for Benchmarking AC Optimal Power Flow Algorithms," *arXiv:1908.02788*, Aug. 2019. [Online]. Available: https://github.com/power-grid-lib/pglib-opf