

# Battery Energy Storage Scheduling for Optimal Load Variance Minimization

Yichen Zhang\*, Alexander Melin†, Mohammed Olama†, Seddik Djouadi\*, Jin Dong† and Kevin Tomsovic\*

\*Department of Electrical Engineering and Computer Science, University of Tennessee, Knoxville, TN 37996-2250

† Oak Ridge National Laboratory, Oak Ridge, TN 37831

Email: {yzhan124, mdjouadi, tomsovic}@utk.edu., {melina, olamahussem, dongj}@ornl.gov.

**Abstract**—Generation portfolio can be significantly altered due to the deployment of distributed energy resources (DER) in distribution networks and the concept of microgrid. Generally, distribution networks can operate in a more resilient and economic fashion through proper coordination of DER. However, due to the partially uncontrollable and stochastic nature of some DER, the variance of net load of distribution systems increases, which raises the operational cost and complicates operation for transmission companies. This motivates peak shaving and valley filling using energy storage units deployed in distribution systems. This paper aims at theoretical formulation of optimal load variance minimization, where the infinity norm of net load is minimized. Then, the problem is reformulated equivalently as a linear program. A case study is performed with capacity-limited battery energy storage model and the simplified power flow model of a radial distribution network. The influence of capacity limit and deployment location are studied.

## I. INTRODUCTION

Increasing deployment of renewable sources (mainly wind and solar photovoltaic (PV) generation) has decreased the power consumption for distribution companies. However, deep penetration of renewable resources into the current electric grid remains a challenging problem. When there is a concurrent drop in renewable generation and increase in demand, the power consumption at the point of common coupling (PCC) between distribution networks and the main grid changes rapidly. This is known as the duck curve issue [1]. In particular, the most significant daily ramp starts around 5:00 p.m. when the sun sets (i.e., solar generation ends) and the demand increases [2]. The traditional power system is designed to meet the highest level of demand but ramping rates are limited particularly for large thermal units. Large amounts of renewable generation during off-peak hours deepen the valley and increase the ramp rate requirement. Fast ramping units, however, are limited in number and capacity, capital-intensive

Research sponsored by the Laboratory Directed Research and Development Program of Oak Ridge National Laboratory (ORNL), managed by UT-Battelle, LLC for the U.S. Department of Energy under Contract No. DE-AC05-00OR22725. The submitted manuscript has been authored by a contractor of the U.S. Government under Contract DE-AC05-00OR22725. Accordingly, the U.S. Government retains a nonexclusive, royalty-free license to publish or reproduce the published form of this contribution, or allow others to do so, for U.S. Government purposes.

and subjected to possible transmission network congestions [3].

An alternative solution is peak shaving and valley filling, referred to here as load variance minimization, by utilizing various dispatchable resources in distribution networks. Electric vehicles (EV) are scheduled in [4] so that the power at PCC follows a target profile. A storage scheduling algorithm that is resilient to the inevitable errors between the forecasted and actual demand is proposed in [5] for peak demand reduction. A day-ahead battery energy storage scheduling is performed in low voltage unbalance distribution networks in [6], where peak load shaving is considered as the main objective and load leveling is regarded as the second objective. In [7], household load variance is minimized by EV control. Tap changer effects on peak shaving from EV was studied in [8]. Price-based programs of demand response, which is based on dynamic pricing rates, can be employed to flatten the demand curve by offering a higher price during peak periods and a lower price during off-peak periods [9]. Household appliances can also participate in peak shaving as shown in [10]. Meanwhile, power at the PCC can be limited to a certain range during cost-based [11], [12] or risk-based [13] scheduling.

Most of the aforementioned research relies on a cost-optimization framework, which highly depends on the specific electricity price profile or market mechanism. Consequently, it is hard to clarify the optimal solution of load variance minimization constrained only by physical limits. A recent theoretical study on peak shaving in [14] proved the optimal solution under limited storage capacity. It was shown that the infinity norm of the power at PCC is minimized if the energy at PCC takes the shortest path within the energy band between the load energy and the energy summation of load and storage limit. Such a theoretical study helps clarify the physical limits under correct mathematical principle without mixed effects of cost and other considerations. For now, there is no theoretical formulation for load variance minimization.

Thus, this paper aims at theoretical study on load variance minimization. The infinity norm minimization-based battery energy storage (BES) scheduling is formulated to optimally flatten the load. This formulation is more general than the




Fig. 1: Load flattening objective.

shortest path principle [14], which is only applicable to peak shaving. Moreover, an equivalent formulation is proposed to convert the optimization problem into a linear program. The radial distribution network power flow (DistFlow) proposed in [15], [16] is employed in this study with several simplifications made based on [17]. The impacts of capacity limit, voltage constraints and location of BES units on load variance minimization performance are investigated.

The remainder of this paper is organized as follows. Section II introduces the infinity norm minimization-based scheduling formulation and its equivalent form. The BES model and radial distribution network power flow are introduced as well. Section III presents the case study on a lumped system as well as a radial feeder. Finally, the conclusion and future work are discussed in Section IV.

## II. PROBLEM FORMULATION

### A. Objective Function

Let  $P_{Bc}(t)$  and  $P_{Bd}(t)$  denote total BES charging and discharging powers, respectively. Let  $P_L(t)$  denote the forecasted total load profile, which is assumed to be known in this paper. Loss is neglected for now. Then, the power at PCC  $P_g(t)$  can be expressed as follows

$$P_g(t) = P_{Bc}(t) - P_{Bd}(t) + P_L(t) \quad (1)$$

where  $P_{Bc}(t) > 0$  and  $P_{Bd}(t) > 0$ . The objective is to minimize the demand peak-valley gap. To explore the optimality, the ideal case is set as the target curve, where there is no peak-valley gap illustrated as the red line in Fig. 1. Then, the objective can be expressed as the infinity norm minimization as follows

$$\min_{P_{Bc}(t), P_{Bd}(t)} \|P_{Bc}(t) - P_{Bd}(t) + P_L(t) - \theta\|_\infty \quad (2)$$

In robust control, instead of minimizing  $\|T_{zw}\|_\infty$ , it is usually desired to minimize the upper bound  $\gamma$ , where  $\|T_{zw}\|_\infty < \gamma$  and  $\gamma > 0$  [18]. Similar idea is applied into the objective reformulation as the objective in (2) is equivalent to

$$\min_{P_{Bc}(t), P_{Bd}(t)} K \quad (3)$$

such that

$$0 \leq |P_{Bc}(t) - P_{Bd}(t) + P_L(t) - \theta| \leq K \quad (4)$$

There are two ways to deal with the target curve  $\theta$ . One is to treat  $\theta$  as a given constant. The second approach is to regard  $\theta$  as a decision variable. Since here the objective is to minimize the variance of the power at PCC, so  $\theta$  needs to be limited between the valley and peak of forecasted load. Then the alternative problem can be formulated as

$$\min_{P_{Bc}(t), P_{Bd}(t), \theta} \alpha K + \beta \theta \quad (5)$$

such that

$$\begin{aligned} 0 \leq |P_{Bc}(t) - P_{Bd}(t) + P_L(t) - \theta| \leq K \\ \min P_L(t) \leq \theta \leq \max P_L(t), \alpha > 0, \beta > 0 \end{aligned} \quad (6)$$

*Remark 2.1:* The formulation in [14] employs the infinity norm in the following form

$$\|z(t)\|_\infty = \lim_{m \rightarrow \infty} \left( \int_0^T |z(\tau)|^m d\tau \right)^{1/m} \quad (7)$$

The shortest path principle can be applied when  $|z(\tau)|^m$  is monotonically increase. It is true when performing peak shaving without reverse load flow to main grid since  $z(\tau) = P_g(\tau) > 0$ . But it does not hold when minimizing load variance, where  $z(\tau) = P_g(\tau) - \theta$  is not always positive. As seen, the formulation proposed above is more general.

### B. Battery Energy Storage Model

Let  $\mathcal{E}$  denote the set of buses that have BES and load connected. The battery model can be expressed as follows [19]

$$E_{b,i}(t) = E_{b,i}(t-1) + \eta T P_{bc,i}(t) - \frac{1}{\eta} T P_{bd,i}(t) \quad \forall i \in \mathcal{E} \quad (8)$$

where  $P_{bc,i}(t)$  and  $P_{bd,i}(t)$  are charging and discharging power of BES at bus  $i$  in kW.  $E_{b,i}(t)$  is the available capacity of BES at bus  $i$  (kW·h).  $\eta$  represents the BES charging/discharging efficiency.  $T$  is the time interval. The BES capacity limit can be expressed by the following constraints

$$\text{SOC}_{\min} B_{\text{cap}} \leq E_{b,i}(t) \leq \text{SOC}_{\max} B_{\text{cap}} \quad \forall i \in \mathcal{E} \quad (9)$$

where  $B_{\text{cap}}$  is the rated capacity in kW·h.  $\text{SOC}_{\min}$  and  $\text{SOC}_{\max}$  are the state-of-charge limits in percentage. In general, simultaneous charging and discharging is unrealistic. Binary variable can be introduced to force only one action to be activated during each scheduling interval  $T$  [20] as follows

$$\begin{aligned} P_{Bc}(t) &= \sum_{i \in \mathcal{E}} P_{bc,i}(t), P_{Bd}(t) = \sum_{i \in \mathcal{E}} P_{bd,i}(t) \\ 0 \leq P_{bc,i}(t) &\leq P_{bc,\max} m_{bc,i}(t) \quad \forall i \in \mathcal{E} \\ 0 \leq P_{bd,i}(t) &\leq P_{bd,\max} m_{bd,i}(t) \quad \forall i \in \mathcal{E} \\ m_{bc,i}(t) + m_{bd,i}(t) &\leq 1 \quad \forall i \in \mathcal{E} \end{aligned} \quad (10)$$

where  $P_{bc,\max}$  and  $P_{bd,\max}$  are the BES charging and discharging power limits.  $m_{bc,i}(t)$  and  $m_{bd,i}(t)$  are binary variables representing the operating modes of charging and discharging.




Fig. 2: One line diagram of a main distribution feeder.

1 means the corresponding mode is activated while 0 stands for deactivation. The last constraint in Eq. (10) ensures no simultaneous charging and discharging situation.

### C. Radial Distribution Network Power Flow

The distribution network power flow (DistFlow) is borrowed from [15] and more generally from [16] including lateral branches, which has been employed in [21] for microgrid scheduling. Consider a radial distribution network shown in Fig. 2. Let  $\mathcal{N}$  denote the set of buses that only have load connected. The following equations can be used to describe the complex power flows at each node  $i$  at time  $t$

$$\begin{aligned} P_{i+1}(t) &= P_i(t) - r_i \frac{P_i^2(t) + Q_i^2(t)}{V_i^2(t)} - P_{nl,i+1}(t) \\ Q_{i+1}(t) &= Q_i(t) - x_i \frac{P_i^2(t) + Q_i^2(t)}{V_i^2(t)} - Q_{nl,i+1}(t) \\ V_{i+1}^2(t) &= V_i^2(t) - 2[r_i P_i(t) + x_i Q_i(t)] + (r_i^2 + x_i^2) \frac{P_i^2(t) + Q_i^2(t)}{V_i^2(t)} \end{aligned} \quad (11)$$

where nl stands for net load.  $x_i$  is inductance from branch  $i$  to  $i+1$ .  $P_i$  and  $Q_i$  are the load flow from branch  $i$  to  $i+1$ . The first approximation is made by dropping the quadratic terms as the branch losses are much smaller than the branch power [16]. Then, the simplified DistFlow is shown as

$$\begin{aligned} P_{i+1}(t) &= P_i(t) - P_{nl,i+1}(t) \\ Q_{i+1}(t) &= Q_i(t) - Q_{nl,i+1}(t) \\ V_{i+1}^2(t) &= V_i^2(t) - 2[r_i P_i(t) + x_i Q_i(t)] \end{aligned} \quad (12)$$

The second approximation is made by the following assumption in [17]

$$[V_i(t) - V_0(t)]^2 \approx 0, \quad (13)$$

which leads to

$$V_i^2(t) \approx V_0^2(t) + 2V_0(t)[V_i(t) - V_0(t)] \quad (14)$$

The rationality of the second approximation lies in the fact that the per unit voltage variation along the line remain within the bounds for proper operation of a distribution system as

$$1 - \varepsilon \leq V_i(t) \leq 1 + \varepsilon \quad (15)$$

where  $\varepsilon > 0$  is generally very small [17]. After the two approximations, the DistFlow equations become

$$\begin{aligned} P_{i+1}(t) &= P_i(t) - P_{i+1}^{nl}(t), Q_{i+1}(t) = Q_i(t) - Q_{i+1}^{nl}(t) \\ V_{i+1}(t) &= V_i(t) - \frac{r_i P_i(t) + x_i Q_i(t)}{V_0(t)}, P_L(t) = \sum_{i \in \mathcal{E} \cup \mathcal{N}} P_{L,i}(t) \\ P_{nl,i}(t) &= P_{L,i}(t), Q_{nl,i}(t) = Q_{L,i}(t) \quad \forall i \in \mathcal{N} \\ P_{nl,i}(t) &= P_{L,i}(t) + P_{bc,i}(t) - P_{bd,i}(t) \quad \forall i \in \mathcal{E} \\ Q_{nl,i}(t) &= Q_{L,i}(t) + Q_{bc,i}(t) - Q_{bd,i}(t) \quad \forall i \in \mathcal{E} \end{aligned} \quad (16)$$

The terminal condition is given as  $P_n(t) = 0$  and  $Q_n(t) = 0$  for all  $t$ . As we can see, by restricting the voltage variation the BES power is confined. Consequently, this turns out to be another constraint for load variance minimization.

## III. CASE STUDY

In this section, we will evaluate the performance of the proposed technique on a 12 kV distribution system. The study is performed on two versions of the system, i.e., a lumped version and a radial version, for different purposes. The parameters are given as  $P_{base} = 1$  MW,  $\varepsilon = 0.05$ ,  $SOC_{min} = 5\%$ ,  $SOC_{max} = 95\%$ ,  $\eta = 0.9$ ,  $T = 1$  [h],  $E_{b,i}(0) = SOC_{min} \times B_{cap}$  for  $i \in \mathcal{E}$ ,  $V_0(t) = 1.02$  for any  $t$ .  $P_{bc,max}$  and  $P_{bd,max}$  are assumed to be sufficiently large.

### A. A Lumped System without Voltage Constraint

The lumped system shown in Fig. 3 is employed to study the property of the formulation. The system consists of one aggregated BES and load, and is assumed to be lossless. Consider the first optimization problem

$$\begin{aligned} \min \quad & K \\ & P_{Bc}(t), P_{Bd}(t) \\ \text{s.t.} \quad & (4), (8), (9), (10) \end{aligned} \quad (17)$$

The problem in (17) is a mix-integer linear programming (MILP). Let  $\theta = 1830$ . The load flattening results when BES capacity equals to 1200 kW·h, 1600 kW·h and 2200 kW·h are shown in Fig. 4. Based on the scheduling results using (17), when  $B_{cap} \geq 2040$  kW·h, the load flattening attains the best performance, where  $K = 0$ .

As expected, the value of objective function varies with the choice of  $\theta$ . The relationship curve under different BES capacity is studied and illustrated in Fig. 5. As shown, when the BES capacity is less than or equal to the critical capacity limit, there is only one choice of  $\theta$  that can reach the best load flattening performance under that particular capacity limit. After the critical limit, larger BES capacity will lead to wider range of  $\theta$  that can minimize the load variance to




Fig. 3: A lumped system.




Fig. 4: Load variance minimization results under different BES capacity when  $\theta = 1830$ : (a), (b), (c) and (d), (e), (f) are power curves and BES energy curves when  $B_{cap}$  equals to 1200 kW·h, 1600 kW·h and 2200 kW·h, respectively.




Fig. 5: Relationship between value of objective function and choice of  $\theta$  under different BES capacity limits.

zero shown as the flat bottom in Fig. 5. In these scenarios, it is always desired to use the smallest  $\theta$  for cost reduction, which corresponds to the left turning point at the flat bottom. This critical choice of  $\theta$  enables the energy balance between peak shaving and valley filling. It should be mentioned that the curves will be altered when the BES unit starts from a different initial condition.

Regarding  $\theta$  as another decision variable yields:

$$\begin{aligned} \min_{P_{Bc}(t), P_{Bd}(t)} \quad & \alpha K + \beta \theta \\ \text{s.t.} \quad & (6), (8), (9), (10) \end{aligned} \quad (18)$$

The scheduling results are summarized in Tab. I. When  $\alpha > \beta$ , the values of the objective function are exactly those turning points in Fig. 5. However, once  $\alpha < \beta$ ,  $\theta$  is minimized with priority and pushed to its lower limit. Thus, the infinity norms are much larger than those in the first case. The scheduled power at PCC of these two cases with different BES capacity is shown in Fig. (6). When the BES capacity is larger than the critical value, although the values of the objective function are different, the scheduled results are the same. But it is not the case when the BES capacity is not adequate for a perfect flattening.




Fig. 6: Scheduled power at PCC under different objective weighting factors and BES capacity. (a) 1200 kW·h, (b) 1600 kW·h and (c) 2040 kW·h.

### B. A Radial Feeder with Voltage Constraints

In this section, the lumped system is expanded into a 18-bus radial feeder to study the voltage constraint. Loss is considered in this case. The same total net active load in previous section is used, and distributed to each bus according to Tab. II. The reactive load is assumed to be fixed and given in Tab. II as well. Based on the study in the last subsection, Formulation 2 is chosen with larger weighting factor on infinity norm  $K$  than target  $\theta$ , which leads to

$$\begin{aligned} \min_{P_{Bc}(t), P_{Bd}(t)} \quad & \alpha K + \beta \theta \\ \text{s.t.} \quad & (6), (8), (9), (10), (15), (16), \alpha > \beta \end{aligned} \quad (19)$$

One BES with adequate size of 2200 kW·h is deployed in different nodes and the scheduled power at PCC is shown in Fig. 7. Due to the voltage constraint, when the BES is deployed at the end of the network, the charging power is limited to further limit the voltage drop along the line. When the deployment location is moving forward, the scheduled power is approaching the best performance as expected. The

TABLE I: Results of Problem in (18)

Capacity	1200 kWh	1600 kWh	2040 kWh	2400 kWh	2800 kWh
$\alpha > \beta$	$K = 89.8, \theta = 1781$	$K = 45.7, \theta = 1803$	$K = 0, \theta = 1827$	$K = 0, \theta = 1827$	$K = 0, \theta = 1827$
$\alpha < \beta$	$K = 428.7, \theta = 1442$	$K = 407.1, \theta = 1442$	$K = 385.4, \theta = 1442$	$K = 385.3, \theta = 1442$	$K = 385.3, \theta = 1442$

TABLE II: Radial Feeder Data

From	To	Loads on to-node			
		R (p.u.)	X (p.u.)	% in Total P	Q in p.u.
0	1	0.000574	0.000293	6.64	0.06
1	2	0.00307	0.001564	5.98	0.04
2	3	0.002279	0.001161	7.97	0.08
3	4	0.002373	0.001209	3.99	0.03
4	5	0.0051	0.004402	3.99	0.02
5	6	0.001166	0.003853	13.29	0.1
6	7	0.00443	0.001464	13.29	0.1
7	8	0.006413	0.004608	3.99	0.02
8	9	0.006501	0.004608	3.99	0.02
9	10	0.001224	0.000405	2.99	0.03
10	11	0.002331	0.000771	3.99	0.035
11	12	0.009141	0.007192	3.99	0.08
12	13	0.003372	0.004439	7.97	0.01
13	14	0.00368	0.003275	3.99	0.02
14	15	0.004647	0.003394	3.99	0.02
15	16	0.008026	0.010716	3.99	0.02
16	17	0.004558	0.003574	5.98	0.04




Fig. 7: Scheduled power at PCC when one BES with capacity of 2200 kW-h is deployed at different buses.

best performance is achieved when the BES is deployed at bus 13 or any bus ahead of bus 13.

#### IV. CONCLUSIONS AND FUTURE WORKS

This paper proposes an infinity norm minimization problem aiming at minimizing the load variance. Two linear programs are formulated to solve the proposed problem. The equivalence of these two problems are observed under certain conditions. A case study is performed with capacity-limited battery energy storage model and the simplified power flow model of a radial distribution network. The critical capacity of BES is obtained for the best performance, meaning zero variance of the scheduled power at PCC. Deployment location is also studied. It is shown that for better scheduling performance it is desired to deploy the BES units in the front of a radial network due to the voltage constraints.

Based on the proposed formulation, optimal allocation and

sizing of BES units for load variance minimization can be determined. Different types of DER like fuel cell [22] can be integrated and analyzed. Since the formulation provides capability of reshaping power at PCC, a resiliency-oriented or a market-oriented scheduling problem can be considered. Distributed coordination of BES units and tap changers over a large distribution network with more sophisticated power flow model would be an interesting extension.

#### REFERENCES

- [1] What the duck curve tells us about managing a green grid. California ISO. [Online]. Available: [https://www.caiso.com/Documents/FlexibleResourcesHelpRenewables\\_FastFacts.pdf](https://www.caiso.com/Documents/FlexibleResourcesHelpRenewables_FastFacts.pdf)
- [2] B. M. Sanandaji, T. L. Vincent, and K. Poolla, "Ramping rate flexibility of residential hvac loads," *IEEE Trans. Sustain. Energy*, vol. 7, no. 2, pp. 865–874, 2016.
- [3] A. Majzoubi and A. Khodaei, "Application of microgrids in supporting distribution grid flexibility," *IEEE Trans. Power Syst.*, vol. 32, no. 5, pp. 3660–3669, 2017.
- [4] Z. Wang and S. Wang, "Grid power peak shaving and valley filling using vehicle-to-grid systems," *IEEE Trans. Power Del.*, vol. 28, no. 3, pp. 1822–1829, 2013.
- [5] M. Rowe, T. Yunusov, S. Haben, C. Singleton, W. Holderbaum, and B. Potter, "A peak reduction scheduling algorithm for storage devices on the low voltage network," *IEEE Trans. Smart Grid*, vol. 5, no. 4, pp. 2115–2124, 2014.
- [6] K. A. Joshi and N. M. Pindoriya, "Day-ahead dispatch of battery energy storage system for peak load shaving and load leveling in low voltage unbalance distribution networks," in *Proc. IEEE PES Innov. Smart Grid Technol. (ISGT)*, 2015, pp. 1–5.
- [7] L. Jian, H. Xue, G. Xu, X. Zhu, D. Zhao, and Z. Shao, "Regulated charging of plug-in hybrid electric vehicles for minimizing load variance in household smart microgrid," *IEEE Trans. Ind. Electron.*, vol. 60, no. 8, pp. 3218–3226, 2013.
- [8] M. J. E. Alam, K. M. Muttaqi, and D. Sutanto, "A controllable local peak-shaving strategy for effective utilization of pev battery capacity for distribution network support," *IEEE Trans. Ind. Appl.*, vol. 51, no. 3, pp. 2030–2037, 2015.
- [9] M. H. Albadi and E. F. El-Saadany, "A summary of demand response in electricity markets," *Electr. Power Syst. Res.*, vol. 78, no. 11, pp. 1989–1996, 2008.
- [10] D. Caprino, M. L. Della Vedova, and T. Facchinetti, "Peak shaving through real-time scheduling of household appliances," *Energy and Buildings*, vol. 75, pp. 133–148, 2014.
- [11] P. Malysz, S. Sirouspour, and A. Emadi, "An optimal energy storage control strategy for grid-connected microgrids," *IEEE Trans. Smart Grid*, vol. 5, no. 4, pp. 1785–1796, 2014.
- [12] K. Worthmann, C. M. Kellett, P. Braun, L. Grüne, and S. R. Weller, "Distributed and decentralized control of residential energy systems incorporating battery storage," *IEEE Trans. Smart Grid*, vol. 6, no. 4, pp. 1914–1923, 2015.
- [13] R. Khodabakhsh and S. Sirouspour, "Optimal control of energy storage in a microgrid by minimizing conditional value-at-risk," *IEEE Trans. Sustain. Energy*, vol. 7, no. 3, pp. 1264–1273, 2016.
- [14] Y. Levron and D. Shmilovitz, "Power systems optimal peak-shaving applying secondary storage," *Electr. Power Syst. Res.*, vol. 89, pp. 80–84, 2012.
- [15] M. E. Baran and F. F. Wu, "Network reconfiguration in distribution systems for loss reduction and load balancing," *IEEE Trans. Power Del.*, vol. 4, no. 2, pp. 1401–1407, 1989.
- [16] M. Baran and F. F. Wu, "Optimal sizing of capacitors placed on a radial distribution system," *IEEE Trans. Power Del.*, vol. 4, no. 1, pp. 735–743, 1989.

- [17] H.-G. Yeh, D. F. Gayme, and S. H. Low, "Adaptive var control for distribution circuits with photovoltaic generators," *IEEE Trans. Power Syst.*, vol. 27, no. 3, pp. 1656–1663, 2012.
- [18] M. Mahmoud and M. Zribi, "H-infinity-controllers for time-delay systems using linear matrix inequalities," *J. Optimiz. Theory and Applic.*, vol. 100, no. 1, pp. 89–122, 1999.
- [19] P. Kou, D. Liang, and L. Gao, "Distributed empc of multiple microgrids for coordinated stochastic energy management," *Applied Energy*, vol. 185, pp. 939–952, 2017.
- [20] G. Liu, M. Starke, B. Xiao, X. Zhang, and K. Tomsovic, "Microgrid optimal scheduling with chance-constrained islanding capability," *Electr. Power Syst. Res.*, vol. 145, pp. 197–206, 2017.
- [21] Z. Wang, B. Chen, J. Wang, M. M. Begovic, and C. Chen, "Coordinated energy management of networked microgrids in distribution systems," *IEEE Trans. Smart Grid*, vol. 6, no. 1, pp. 45–53, 2015.
- [22] M. E. Raoufat, A. Khayatian, and A. Mojallal, "Performance recovery of voltage source converters with application to grid-connected fuel cell dgs," *IEEE Trans. Smart Grid*, 2016.