# Controlling Time-Variant Virtual Inertia from Storage by Dynamic Programming and PROPT

Shuchang Yan, Student Member, IEEE

Abstract—The integration of renewables gradually replaces the traditional power plants, and this makes that the rotational inertia provided by the power plants is decreasing with time. Virtual inertia emulated by power electronic devices is becoming a promising way to stabilize the frequency of power system when a disturbance happens. And how to control virtual inertia to achieve desired performance is an important question to be answered. In this work, authors formulate an optimal control problem to describe the behaviour of controlling the timevariant inertia from storage, and structure preserving model is utilized to describe the dynamics of system, where frequencies of all buses are preserved. Also, practical constraints such as frequency contraints for buses, power/energy constraints for storage are incorporated in the optimal control problem. To solve this optimal control problem, dynamic programming (DP) and PROPT MATLAB Optimal Control Software are employed to obtain global optimal solution (virtual inertia trajectory). The simulation results show the correctness and effectiveness of our problem formulation and solving method.

# I. INTRODUCTION

To achieve better environmental and economic benefits, more and more renewable energy sources are brought into the current power system. On the one hand, the wind power is uncertian and variable, and thus, wind power prediction with 100 percent accuracy is impossible. This will make power imbalance happens more frequently than before. On the other hand, the traditional power plants are decreasing while most of renewables connect to the power grid with power electronic devices where no inertia is provided, which means a low-inertia power system is coming now [1]. Researchers in power system area proposes to use power electronic devices to emulate virtual inertia to stabilize the frequency when a disturbance happens. And the research question is where to locate and how to control virtual inertia from these power electronic-interfaced devices can have the strongest support to the frequency of the power system.

To anwser this question, two factors, the location to implement the control and the control method for virtual inertia should be seriously considered. Reference [2] investigates the effect of deploying energy storage with droop control centrally and distributedlly on the primary frequency regulation of power system. Reference [3] finds that deploying energy storage with droop contol can improve the transient performance indices such as frequency nadir by comparing power system with and without energy storage. Reference [4] further extends the work in reference [2] and focuses on the relationship between the location of energy storage and primary frequency response in the low-inertia system. It is noted that references [2]–[4] adopt a pure simulation approach to analyze the question. The benefit is that we can obtain a deterministic result for the optimal location and control parameters of storage for primay frequency response, however, the dificiencies are also obvious: the solution obtained in a certian grid may not be suitable for other grids and the control parameters during the transient process are fixed.

1

To design a more scientific method to analyze this question, reference [5] adopts a gradient-based method to analyze how the virtual inertia and damping allocate can have desired transient performance. Reference [6] takes one step forward to include the transfer function of energy storage into that of power system, and analyzes that the relationship between frequency indices and virtual inertia/damping. However, the modelling in references [5], [6] fails to analyze the effects of the location of energy storage on the frequency indices. References [7], [8] utilize  $H_2$  norm to describe the transient performance. The allocation result of virtual inertia and damping can ensure the coherency of system, but it is noted that frequency contraints such as lower and upper limits can not be implemented in their problem formulations. Reference [9] takes the assumption that frequency dynamics at all buses are the same in transient process, and then utilizes the secondorder model to replace the original power system model to give the analytical relationshiop between frequency indices and virtual inertia and damping. However, the assumption is reasonable for a meshed network, and it is not in line with reality for certain types of grid structure such as chain-type system. Also, there is a common deficiency in references [2]-[9] that control parameters or virtual inertia/damping during the transient process are fixed.

For the research on time-variant inertia, reference [10] reviews the control methods for the power electronic equipments to emulate virtual inertia. To the best of author's knowledge, there is only one reference [11] to analyze how to control timevariant inertia to meet frequency requirements. However, there are several deficiencies: first, high-order power system dynamics is approximated by second-order system, which means the frequencies of different buses (or stucture information) are covered by one aggregated frequency; second, the LQR optimization technique is based on the linearized model, so the virtual inertia trajectory may not be optimal or appropriate for a large disturbance of the power system.

Based on the literature review above, authors here point out the design requirements for problem formulation and the corresponding control methods of time-variant virtual inertia from power electronic devices:

i. The problem formulation should allow that frequency of all buses can be presented or analyzed.

- ii. The control method can better give a global optimal rather than local optimal trajectory of control inputs.
- iii. The control method (or solving algorithm) should be suitable to solve different system dynamics, and this is due to the fact the dynamics of power electronic devices varies from each other.
- iv. The control method can make frequency trajectory meet the specific requirements such as lower and upper frequency limits in the transient process and the steady frequency requirements after the disturbance.

To meet the above requirements, authors formulate an optimal control problem to obtain the optimal time-variant inertia trajectory and dynamic programming, as a widely applicable method, is employed here to solve this optimal control problem. For high dimensional optimal control problem, PROPT Matlab Optimal Control Software is utilized here to deal with this optimal control problem.

The remainder of this paper is structured as follows. In Section II, the structure preserving model and energy storage model are presented. Section III formulates the optimal problem including the objectives and constraints. Section IV illustrates that how to utilize dynamic programming and PROPT to solve this optimal control problem. The case study is done in section V to verify the problem formulation and the corresponding solving method. The last section (Section VI) gives the final conclusion and future research directions.

#### II. MODELING

#### A. Power System Dynamics

The structure preserving model [12] is utilized here to model the dynamics of power system. In this model, reactive power is ignored and voltage magnititudes at all buses are assumed to be constant at 1 per unit value (p.u.). And all the transmission lines in the power system are assumed to be resistanceless. There are N nodes or buses in the power system. Nodes or buses with inertia and without inertia are denoted as the set G and set L respectively, and superscripts g and l are the elements from G and L respectively. In power system, the nodes with inertia are generally buses with generators or motors, and the corresponding dynamics are described as follows,

$$\delta_i^g = \omega_i^g \tag{1}$$

$$\dot{\omega}_{i}^{g} = -\frac{D_{i}}{M_{i}}\omega_{i}^{g} - \frac{1}{M_{i}}\sum_{\substack{j=1\\j\neq i}}^{N} b_{ij}\sin(\delta_{i} - \delta_{j}) + \frac{1}{M_{i}}P_{i}^{0} \qquad (2)$$

where  $\delta_i$  and  $\delta_j$  are the angle of bus *i* and bus *j* respectively, and  $M_i$  and  $D_i$  are the inertia and damping of bus *i* respectively,  $\omega_i$  is the frequency at bus *i*, and it takes the nominal frequency as a reference,  $b_{ij}$  is the susceptance between bus *i* and bus *j*, and  $b_{ij} \sin(\delta_i - \delta_j)$  is the active power flow from bus *i* to bus *j*,  $P_i^0$  is a shorthand for  $P_{M,i}^0 - P_{D,i}^0$ , which is the difference between mechanical power input  $P_{M,i}^0$  of generator at bus *i* and load demand  $P_{D,i}^0$  at bus *i*. For the nodes without inertia, usually load buses without motor loads, the dynamics can be described as follows,

$$\dot{\delta}_{i}^{l} = -\frac{1}{D_{i}} \sum_{\substack{j=1\\j\neq i}}^{N} b_{ij} \sin(\delta_{i} - \delta_{j}) + \frac{1}{D_{i}} P_{i}^{0}$$
(3)

where the mechanical power input  $P_{M,i}^0$  at buses without inertia is equal to 0 and  $P_i^0$  is equal to  $-P_{D,i}^0$ , representing the active power drawn from the node *i*.

#### B. Energy Storage Dynamics

Energy storage can mimic the behaviour of synchronous generators to provide virtual inertia and damping, the dynamics of energy storage is given below [9],

$$\dot{\delta}_i^e = \omega_i^e \tag{4}$$

$$\dot{\omega}_{i}^{e} = -\frac{D_{e,i}}{M_{e,i}}\omega_{i}^{e} - \frac{1}{M_{e,i}}\sum_{\substack{j=1\\j\neq i}}^{N} b_{ij}\sin(\delta_{i} - \delta_{j}) + \frac{1}{M_{e,i}}P_{i}^{e} \quad (5)$$

where  $M_{e,i}$  and  $D_{e,i}$  are the virtual inertia and damping for the energy storage at bus *i* respectively,  $P_i^e$  is the constant power input or power output for energy storage at bus *i*. The nodes or buses with energy storage are denoted with the set *S*. For simplicity's consideration, there exists  $N = G \cup L \cup S$ ,  $G \cap L = \emptyset$ ,  $G \cap S = \emptyset$  and  $L \cap S = \emptyset$ .

# C. Constraints for the System Dynamics

 $P_i^r$ 

The dynamics of power system with energy storage can be expressed by (1)-(5). However, there are some practical limits such as the frequency limits for several certain buses. The system constraints are listed as follows,

$$|\omega_i| \le \omega_i^{max} \tag{6}$$

$$\omega_i(t_1)$$
 is within a predefined range (7)

$$P_{i}^{min} \leq P_{i}^{r} = P_{i}^{e} - M_{e,i} \dot{w}_{i}^{e} - D_{e,i} w_{i}^{e} \leq P_{i}^{r,max}$$
 (8)

$$E_{i}^{al,l} \le \int_{t_{0}}^{t_{1}} P_{i}^{r} dt \le E_{i}^{al,u}$$
(9)

where  $\omega_i^{max}$  is the allowable frequency change of bus *i*,  $P_i^{r,min}$  and  $P_i^{r,max}$  are the lower and upper power limits for energy storage at bus *i*, and  $E_i^{al,l}$  and  $E_i^{al,u}$  are the lower and upper limits of energy change for storage at bus *i*, and  $t_1$  is final time instant of concerned time interval. It should be noted that the specific values of  $E^{al,l}$  and  $E^{al,u}$  should be based on the current state of charge of storage.

# **III. PROBLEM FORMULATION**

The aim of this work is to control the virtual inertia to make sure that transient performance can be enhanced while the power and energy changes of storage do not go beyond their limits, and also specific frequency requirements of certain buses could be met during the transient process.

$$\min_{M_{e,s}(t)} \int_{t_0}^{t_1} \sum_{s \in S} a_s (M_{e,s}(t) - M_{e,i,d})^2 \\
+ \sum_{i \in N} b_i |\omega_i(t)| \\
+ \sum_{i \in N} c_i \delta_i(t)^2 dt$$
(10)

subject to

where  $M_{e,s,d}$  is desired or reference virtual inertia value provided by storage at bus s;  $M_{e,s}(t)$ , virtual inertia provided by storage at bus s, is the control input;  $\delta_i$  and  $\omega_i$ , angle and frequency respectively, are the state variables. We denote the  $M_{e,s}(t)$  as  $u_{e,s}(t)$ , denote  $\delta_i$  and  $\omega_i$  as  $x_i(t)$ , and denote the term to be integrated in the objective function as  $g(\mathbf{x}(\mathbf{t}), \mathbf{u}(\mathbf{t}))$ for convenience, where  $\mathbf{x}(\mathbf{t})$  and  $\mathbf{u}(\mathbf{t})$  are stacked by  $x_i(t)$  and  $u_{e,s}(t)$  respectively. And then, the optimal control problem could be expressed as the following concise form,

$$\min_{\mathbf{u}(t)} \int_{t_0}^{t_1} g(\mathbf{x}(t), \mathbf{u}(t)) dt \tag{11}$$

$$\dot{\mathbf{x}}(t) = \mathbf{f}(\mathbf{x}(t), \mathbf{u}(t)) \tag{12}$$

$$\mathbf{x}(t) \subset \mathbf{X}(t) \tag{13}$$

$$\mathbf{u}(t) \subset \mathbf{U}(t) \tag{14}$$

$$Other \ constraints \tag{15}$$

where  $\mathbf{X}(t)$  is allowable trajectory for  $\mathbf{x}(t)$ , and  $\mathbf{U}(t)$  is allowable trajectory for  $\mathbf{u}(t)$ . The objective function is to minimize the virtual inertia change (control effort) and angle/frequency change (control performance) of all buses in the system.

# **IV. SOLVING METHOD**

In this section, dynamic programming and PROPT MAT-LAB OPTIMAL CONTROL SOFTWARE will be introduced respectively to solve this optimal control problem.

# A. Dynamic Programming

Dynamic programming is a classical method to solve optimal control problem, and its basic idea is to break a complex optimization problem into multi-stage subproblems, and the full-stage global optimal solution (or trajectory) is obtained through combining the optimal solution of subproblems, which is also known as "Bellman's Principle of Optimality" [13], [14]. The benefit is that we can obtain a global optimal trajectory within constraints for an optimal control problem.

In this work, we adopt level-set dynamic programming (LS DP) proposed in reference [15] to solve this problem and the results are also compared with these solved by basic DP. The difference of LS DP and the basic DP algorithm is that the former one utilizes interpolation between backward-reachable

and non-backward-reachable grid points so that the obtained solution accuracy will be increased dramatically. The procedures to implement the LS DP and basic DP into our optimal control problem are listed as follows, and for the details of LS DP algorithm, readers please refer to reference [15]:

### Step 1) Initial Parameter Setting

Choose a node/bus for angle/frequency reference in the power system. This is quite important because the value of angle and frequency of other buses will not fly to the distance if we have a reference bus.

Choose the time interval for the simulation  $(t_0 \text{ and } t_1 \text{ respectively})$ , the lower and upper bounds of states variables  $\mathbf{x}(t)$  and control inputs  $\mathbf{u}(t)$ , the value or ranges for the state variables  $\mathbf{x}(t)$  at the final time  $t_1$ .

Choose the time step  $(T_s)$  for discretization of system dynamics, the penalty for final state  $(\phi_N(\mathbf{x}_N))$ , also denoted as My.Inf in Matlab code [16]) and number of state points in the grid  $(N_x)$ .  $N_x$  is utilized to discretize the space of state variables or control input x.

# Step 2) Discretize the System Dynamics

Discretize the system dynamics based on the initial parameter setting as follows,

$$\min_{\mathbf{u}(k)} g_N(\mathbf{x}_N) + \sum_{N_0}^{N-1} (g_k(\mathbf{x}_k, \mathbf{u}_k) \times T_s)$$
(16)

$$\mathbf{x}(k+1) = \mathbf{f}_k(\mathbf{x}(k), \mathbf{u}(k)) \tag{17}$$

$$\mathbf{x}(k) \subset \mathbf{X}(k) \tag{18}$$

$$\mathbf{u}(k) \subset \mathbf{U}(k) \tag{19}$$

$$Other \ constraints \tag{20}$$

for all 
$$k = N_0, N_0 + 1, ..., N$$

Where N is denoted as the last time instant in discretized version optimization,  $g_N(\mathbf{x}_N)$  is the cost of final state  $x_N$ . To implement the constraints (18) on state variables and other constraints (20), we add penalties  $\phi_N(\mathbf{x}_N)$  and  $\phi_k(\mathbf{x}_k)$  on the cost function respectively as follows,

$$\min_{\mathbf{u}(k)} \quad g_N(\mathbf{x}_N) + \phi_N(\mathbf{x}_N) + \sum_{N_0}^{N-1} (g_k(\mathbf{x}_k, \mathbf{u}_k) + \phi_k(\mathbf{x}_k, u_k)) \times T_s$$
(21)

$$\mathbf{x}(k+1) = \mathbf{f}_k(\mathbf{x}(k), \mathbf{u}(k)) \tag{22}$$

$$\mathbf{u}(k) \subset \mathbf{U}(k) \tag{23}$$

for all 
$$k = N_0, N_0 + 1, ..., N$$

Finally, we bring the control objectives (10) into (21) and obtain the final discretized optimal control formulation.

$$\min_{\mathbf{u}(k)} g_{N}(\mathbf{x}_{N}) + \phi_{N}(\mathbf{x}_{N}) \\
+ \left(\sum_{s \in S} \sum_{N_{0}}^{N-1} a_{s}(M_{e,s}(k) - M_{e,i,d})^{2} + \sum_{i \in N} \sum_{N_{0}}^{N-1} b_{i} |\omega_{i}(k)| + \sum_{i \in N} \sum_{N_{0}}^{N-1} c_{i} \delta_{i}(k)^{2} \\
+ \sum_{N_{0}}^{N-1} \phi_{k}(\mathbf{x}_{k}, \mathbf{u}_{k})) \times Ts$$
(24)

$$\mathbf{x}(k+1) = \mathbf{f}_k(\mathbf{x}(k), \mathbf{u}(k))$$
(25)  
$$\mathbf{u}(k) \subset \mathbf{U}(k)$$
(26)

for all 
$$k = N_0, N_0 + 1, ..., N$$

where the first two terms in control objective are stage cost and penalty respectively for state variables in the final stage, and the next three terms are stage cost for state variables from stage  $N_0$  to N-1, and the last term is penalties to make state variables within the constraints (18) and (20).

# Step 3) Run the Simulation

After running the simulation, we obtain the optimal control input trajectory and the trajectories of state variables. Comparisons are made between cases with and without constraints, and constant inertia supply and time-variant inertia supply from storage.

# B. PROPT MATLAB OPTIMAL CONTROL SOFTWARE

PROPT MATLAB OPTIMAL CONTROL SOFTWARE is a platform to solve the optimal control problem (described by ODE and DAE) in engineering practice. Many types of control problems such as disturbance control and flight path tracking can be solved efficiently. For the detailed the information about PROPT, readers can refer to reference [17], and here we list the key steps and parameters that we need for the optimal control problem in this work.

Step 1) Initial Parameter Setting

Determine the time interval and the length of time steps for simulation. And then, the lower and upper limits for both the state variables and input variables should be determined. Finally, the initial and final value of state variables should be determined.

# Step 2) Determine the Control Objective

To determine the control objective, both the original control objective and the penalty related to the contraints of state variables should be considered.

$$\min_{\mathbf{u}(t)} \int_{t_0}^{t_1} g(\mathbf{x}(t), \mathbf{u}(t)) + \phi(\mathbf{x}(t), \mathbf{u}(t)) dt \qquad (27)$$

$$\dot{\mathbf{x}}(t) = \mathbf{f}(\mathbf{x}(t), \mathbf{u}(t)) \tag{28}$$

$$\mathbf{u}(t) \subset \mathbf{U}(t) \tag{29}$$

$$Other \ constraints \tag{30}$$

where  $\phi(\mathbf{x}(t), \mathbf{u}(t))$  is the penalties related to the constraints of state variables (see (13)).

# Step 3) Run the Simulation

After running the simulation, we obtain the optimal control input trajectory and the trajectories of state variables.

# V. CASE STUDY

We will do two case studies in this section. The first case study is conducted in a simple two-bus system, where typical grid parameters are utilized. And next, we will employ a more realistic 12-bus system to verify the solving method.

For the case study in 2-bus system, the simulation is run in Matlab R2018a on a computer with Microsoft Windows, i5-7500 3.40GHz, and 8GB RAM. For the Matlab code to implement the basic DP and level-set DP, readers can refer to reference [18] and download it at [16]. For parameter initialization, it is suggested by authors that the discretization of state variable space and time step should be as fine as possible if computation ability is allowed. Or there is a compromise between your discretization step and your computation ability. The result for comparison is obtained from LS DP, if there is no special statement.

For the case study in 12-bus system, the PROPT MAT-LAB OPTIMAL CONTROL SOFTWARE of trial version is utilized, and it can be downloaded at [19]. And 'High Dim Control' is selected for 'options.name' in the optimization program. The simulation for this case is run on MacBook Pro, 2.3GHz Intel Core i5 and 8GB 2133MHz LPDDR3 memory.

A. 2-bus system



Fig. 1. 2-bus test system.

Fig. 1 shows the a two-bus system where storage at bus 1 connects to the grid at bus 2. Bus 2 is set as a reference bus which means  $\delta_2 \equiv 0$  and  $\omega_2 \equiv 0$  during the transient process. The initial parameters are given in Tab. I for simulation, we can see that the setting is that there is no power exchange between the storage and the grid at the initial time instant, and the disturbance is set as the 0.3 p.u. power increase at bus 1.

Parameter	Value	Parameter	Value
$T_s$	0.5 s	$t_1$	30 s
$N_{\delta_1}$	201	$N_{\omega_1}$	51
$\delta_1(0)$	0	$\omega_1(0)$	0
$\delta_1(t)$	[0, 0.6]	$\omega_1(t)$	[-0.5, 0.5]
$\delta_1(N)$	[0, 0.6]	$\omega_1(N)$	[-0.02, 0.02]
$M_1(t)$	[4 s, 10 s]	$B_{1-2}$	1
$\overline{D}_{e,1}$	1	$N_{M_{e,1}}$	51

1) Time-variant Inertia vs. Constant Inertia: First we set the control objective is as follows:

$$\min_{\mathbf{u}(k)} \quad \phi_N(\mathbf{x}_N) + \sum_{i \in N} \sum_{N_0}^{N-1} b_i |\omega_i(k)| \times Ts \tag{31}$$

where  $b_i$  is the coefficient and equals to 1, and  $\phi_N(\mathbf{x}_N)$  is 2 here. After running the simulation, we obtain the optimal trajectories of  $\delta_1(k)$ ,  $\omega_1(k)$  and  $M_{e,1}(k)$ , as shown in Fig 2, Fig 3 and Fig 4 respectively.



Fig. 2. Angle at bus 1.



Fig. 3. Frequency at bus 1.

For the basic DP, the value of objective function is 2.7549 (frequency absolute value integration: 0.7549 + penalty: 2), and for the LS DP, the value is 2.7408 (frequency absolute value integration: 0.7508 + penalty: 2), it can be seen that LS DP can achieve better result compared with basic DP.

We also see some interesting phenomena when the inertia can be changed with time:



Fig. 4. Inertia change at bus 1.

- i. When the time t is between 0s and 5s, the maximum virtual inertia is chosen by the storage, this is to prevent the increase of frequency  $\omega_1$ .
- ii. When the value of frequency  $\omega_1$  changes sign, or the frequency changes the direction of motion, the inertia change will switch between two boundary values, this is also to prevent the frequency change.
- iii. The value of frequency at the final state is within the predefined range, which means penalty  $\phi_N(\mathbf{x}_N)$  takes effects.

The results listed above show that this optimal control problem has been successfully solved. To compare this case with one where inertia is fixed, we adopt the following control objective,

$$\min_{\mathbf{u}(k)} \phi_N(\mathbf{x}_N) + \sum_{i \in N} \sum_{N_0}^{N-1} b_i |\omega_i(k)| \times Ts + \sum_{s \in S} \sum_{N_0}^{N-1} a_s (M_{e,s}(k) - M_{e,i,d})^2 \times T_s$$
(32)

where  $a_s$  equal 100000, and desired inertia  $M_{e,i,d}$  is 4s. Through this control objective, we want to see that the virtual inertia will be at 4s over the time.



Fig. 5. Frequency at bus 1.

It can seen from Fig. 5 and Fig. 6 that inertia at bus 1 keeps constant at 4s and frequency at bus 1 experiences larger oscillations than that in Fig. 3. For the frequency absolute



Fig. 6. Inertia change at bus 1.

value integration with time in contant-inertia case, the value is 1.2792. The running time of basic DP and LS DP for control objective (31) is 91.6709s and 115.4804s, and the running time of basic DP and LS DP for control objective (32) is 84.4507s and 97.7915s respectively.

2) Verifying the other constraints: In this subsection, the author would like to verify that dynamic programming can meet the other constraints such as the energy constraints of storage. The case (control objective (32)) in the last subsection is a base case. We want to add the following constraint:

$$P_i^{r,min} \le P_i^r = P_i^e - M_{e,i} \dot{w^e}_i - D_{e,i} w_i^e \le P_i^{r,max}$$
(33)

$$E_i^{al,l} \le \int_{t_0}^{t_1} P_i^r dt \le E_i^{al,u} \tag{34}$$

They are power capacity constraint and energy capcacity cosntraints respectively. And we bring the parameters into these two constraints and discretize them as follows,

$$P_{i}^{r,min} \leq P_{i}^{r}(k) = -M_{e,i} \frac{w^{e}{}_{i}(k+1) - w^{e}{}_{i}(k)}{T_{s}} -w_{i}^{e}(k) \leq P_{i}^{r,max}$$
(35)

$$E_i^{al,l} \le \sum_{N_0}^{N-1} P_i^r(k) \le E_i^{al,u}$$
(36)

For the base case, the power change and energy change of storage are shown in Fig. 7 and in Fig. 8 respectively. The minimum and maximum value of P(k) is -0.3 p.u and 0.1880 p.u. at t=0.5s and at t=7s respectively. It is noted that we utilize the discretization method and intial value of state varables are 0, so the minimum value of P(k) at the first step t=0.5s is fixed and is equal to -0.3 p.u.. Another fact is that this is a single-machine infinite-bus system, the controllability of state variables are limited. And thus, we set  $P_i^{r,max} = 0.15$  p.u. And we penalize the power change by upper limits, this will significantly increase the energy in the storage. To make the



Fig. 7. Power change of storage at bus 1.



Fig. 8. Energy change of storage at bus 1.

result more clear, we only implement power constraints for storage, and the control objective is as follows,

$$\min_{\mathbf{u}(k)} \phi_N(\mathbf{x}_N) + \sum_{i \in N} \sum_{N_0}^{N-1} b_i |\omega_i(k)| \times Ts + \sum_{s \in S} \sum_{N_0}^{N-1} d_s max(P_i^r(k) - 0.15, 0)$$
(37)

where  $d_s$  is the coefficient, and equals to 100000, and  $b_i$  equals to 1. The power change, energy change of storage, and virtual inertia trajectory are shown in Fig. 9, Fig. 10 and Fig. 11 respectively. It can be seen that power change of storage does not go beyond its upper limit 0.15 p.u. during the transient process and the maximum value of P(k) is 0.1272 p.u. at time t=9s. And running time for basic DP and LS DP is 82.7141s and 90.8032s respectively.

In this optimal control problem, constraint (36) is related to multi-stage state variables, in fact, it is noted that storage capacity can also be treated as a state variable, and this constraint will be easy to be transformed into a penalty function, which can be added on the control objective. Since this paper focuses on the effect of time-variant virtual inertia, we only point out the feasible methods to deal with these kinds of constraints.



Fig. 9. Power change of storage at bus 1.



Fig. 10. Energy change of storage at bus 1.



Fig. 11. Virtual inertia change at bus 1.

### B. 12-bus system

The 12-bus test system in Fig. 12 is modified from the wellknown two-area system in reference [20] and an additional area is added as reference [5]. The transformer reactance is 0.15 p.u. and the line impedance is (0.0001+0.001i) p.u./km. We still utilize structure preserving model to describe the dynamics of power system. The base capacity of this system for power flow calculation is set as 100MVA. The inertia and damping of original power system is given in Table IV and the steady power flow condition is given in Table II. It is assumed that there are motor loads (including little inertia and damping) at the load buses. And bus 9 is a set as a reference bus in the system. The time step is 0.5s and the time interval for running the simulation is 40s. Our eyesight in this case will be put on minimizing frequency devations and power flow oscillations on transmission lines. The contingency setting is power increase of 60MW (0.6 p.u.) at bus 1.



Fig. 12. 12-bus test system.

1) Base Case: For comparison purpose, we first do a base case where the virtual inertia of storage is fixed. And we adopt  $a_s=1$  and  $M_{e,i,d} = 4$  for  $i \in S$ ,  $b_i=0$ ,  $c_i=0$  for  $i \in N$  in control objective (10). And the angle, frequency, inertia trajectories and power flow from bus 4 to bus 8 are shown in Fig. 13, Fig. 14, Fig. 15 and Fig. 16.



Fig. 13. Angle at each bus.

The time for this case study is 1.8123s for symbolic processing and 3.9842s for CPU calculation. The time integration for frequency absolute value is 1.8157 p.u. s. The power peak is 1.7959 p.u. at t=9s.

2) Minimizing frequency deviations: To minimize the frequency deviations, we do a case where  $a_s=0$  for  $i \in S$ ,  $b_i=1$ ,  $c_i=0$  for  $i \in N$ . And the angle, frequency and inertia trajectories are shown in Fig. 17, Fig. 18 and Fig. 19 as follows,

The time for the base case study is 3.5128s for symbolic processing and 247.65s for CPU calculation. The time integration for frequency absolute value is 1.4975 p.u.·s, and we can see that the control objective for frequency minimization is achieved.



Fig. 14. Frequency at each bus.



Fig. 15. Virtual inertia change at each bus.



Fig. 16. Power flow at transmission line 4-8.

3) Minimizing the power flow oscillations: To minimize the power flow ocillations, we adopt the following control objective,

$$\min_{M_{e,s}(t)} \int_{t_0}^{t_1} \max(b_{48} \sin(\delta_4 - \delta_8) - 1.7, 0) \ dt \tag{38}$$

We enlarge the virtual inertia range to [0.1s, 15s], and the power flow and virtual inertia trajectories are shown in Fig. 20 and Fig. 21.

The time for this case study is 3.0355s for symbolic processing and 4.3600s for CPU calculation. The power peak is 1.7853 p.u. at t=9s. And we can see that even though



Fig. 17. Angle at each bus.



Fig. 18. Frequency at each bus.



Fig. 19. Virtual inertia change at each bus.

we enlarge the virtual inertia range, in this case, the effect of virtual inertia change on the minimizing the power flow oscillation is limited. The virtual inertia provided by all storage is the minimum value at around 0.1s.

# VI. CONCLUSION

This paper novelly treats controlling time-variant virtual inertia as an optimal control problem, and provides two corresponding methods, dynamic programming and PROPT respectively, to solve it. Dynamic programming is a generally applicable method for different kinds of system models, which means the analysis can be conducted for power system with different types of power-electronic equipments. For the



Fig. 20. Power flow at transmission line 4-8.



Fig. 21. Virtual inertia change at each bus.

PROPT method, this software can deal with high-dimensional control with very fast speed, which is desired for analysis.

This work opens a new space for frequency control, research opportunities followed by this work can be as follows,

- i. Dynamic programming will suffer the problem 'curse of dimensionality', the calculation time will exponentially increase with the increase of state variables. For the high dimensional dynamic system, what should we do if we still want to use dynamic programming method?
- ii. In this work, the wind power change is not considered, if wind power is considered, how do we change the model correspondingly?
- iii. In this work, we only treat the virtual inertia as the control input, in fact, power input/output of storage can also be treated as the control input with a certain cost coefficient, so which is better between controlling power or controlling virtual inertia to achieve a specific control objective?

APPENDIX A INITIAL PARAMETERS FOR 12-BUS SYSTEM SIMULATION.

TABLE II
Power Flow Condition for 12-bus system.

Gen	1	2	5	6	9	10
P(MW)	138	1050	719	350	700	700
Load	3	4	7	8	11	12
P (MW)	400	567	490	800	400	1000

 TABLE III

 INITIAL PARAMETERS FOR SIMULATION OF 12-BUS SYSTEM.

Parameter	Value	Parameter	Value
$\delta_1(0)$	-0.1931	$\omega_1(0)$	0
$\delta_2(0)$	-0.0452	$\omega_2(0)$	0
$\delta_3(0)$	-0.2552	$\omega_3(0)$	0
$\delta_4(0)$	-0.3340	$\omega_4(0)$	0
$\delta_5(0)$	-0.1146	$\omega_5(0)$	0
$\delta_6(0)$	-0.3681	$\omega_6(0)$	0
$\delta_7(0)$	-0.4381	$\omega_7(0)$	0
$\delta_8(0)$	-0.4960	$\omega_8(0)$	0
$\delta_9(0)$	0	$\omega_9(0)$	0
$\delta_{10}(0)$	-0.1750	$\omega_{10}(0)$	0
$\delta_{11}(0)$	-0.3150	$\omega_{11}(0)$	0
$\delta_{12}(0)$	-0.4150	$\omega_{12}(t)$	0
$D_{e,4}$	0.1 p.u.	$D_{e,8}$	0.1 p.u.
$D_{e,4}$	0.1 p.u.	$M_{e,4}(t)$	[4s, 10s]
$M_{e,8}(t)$	[4s, 10s]	$M_{e,12}(t)$	[4s, 10s]

 TABLE IV

 INERTIA AND DAMPING DISTRIBUTION OF ORIGINAL POWER SYSTEM.

Bus. No.	Inertia (s) / Damping (p.u.)
1, 2	15/3
5, 6	20/4
9, 10	10/2
3, 7, 11	1/0.1

#### REFERENCES

- A. Ulbig, T. S. Borsche, and G. Andersson, "Impact of low rotational inertia on power system stability and operation," *IFAC Proceedings Volumes*, vol. 47, no. 3, pp. 7290–7297, 2014.
- [2] A. Adrees and J. V. Milanovic, "Study of frequency response in power system with renewable generation and energy storage," in *Power Systems Computation Conference (PSCC)*, 2016. IEEE, 2016, pp. 1–7.
- [3] A. Adrees and J. V. Milanović, "Impact of energy storage systems on the stability of low inertia power systems," in *Innovative Smart Grid Technologies Conference Europe (ISGT-Europe), 2017 IEEE PES.* IEEE, 2017, pp. 1–6.
- [4] A. Adrees, J. V. Milanović, and P. Mancarella, "The influence of location of distributed energy storage systems on primary frequency response of low inertia power systems," in 2018 IEEE Power & Energy Society General Meeting (PESGM). IEEE, 2018, pp. 1–5.
- [5] T. S. Borsche, T. Liu, and D. J. Hill, "Effects of rotational inertia on power system damping and frequency transients," in *Decision and Control (CDC), 2015 IEEE 54th Annual Conference on*. IEEE, 2015, pp. 5940–5946.
- [6] T. Borsche and F. Dörfler, "On placement of synthetic inertia with explicit time-domain constraints," arXiv preprint arXiv:1705.03244, 2017.
- [7] B. K. Poolla, D. Groß, T. Borsche, S. Bolognani, and F. Dörfler, "Virtual inertia placement in electric power grids," in *Energy Markets and Responsive Grids*, 2018, pp. 281–305.
- [8] B. K. Poolla, D. Groß, and F. Dörfler, "Placement and implementation of grid-forming and grid-following virtual inertia," arXiv preprint arXiv:1807.01942, 2018.
- [9] S. Guggilam, C. Zhao, E. Dall'Anese, C. Chen, and S. Dhople, "Optimizing der participation in inertial and primary-frequency response," *IEEE Transactions on Power Systems*, 2018.
- [10] J. Fang, H. Li, Y. Tang, and F. Blaabjerg, "On the inertia of future moreelectronics power systems," *IEEE Journal of Emerging and Selected Topics in Power Electronics*, 2018.
- [11] U. Markovic, Z. Chu, P. Aristidou, and G. Hug-Glanzmann, "Lqr-based adaptive virtual synchronous machine for power systems with high inverter penetration," *IEEE Transactions on Sustainable Energy*, 2018.
- [12] A. R. Bergen and D. J. Hill, "A structure preserving model for power system stability analysis," *IEEE Transactions on Power Apparatus and Systems*, no. 1, pp. 25–35, 1981.
- [13] R. Bellman and R. E. Kalaba, Dynamic programming and modern control theory. Citeseer, 1965, vol. 81.
- [14] D. P. Bertsekas, D. P. Bertsekas, D. P. Bertsekas, and D. P. Bertsekas, *Dynamic programming and optimal control.* Athena scientific Belmont, MA, 1995, vol. 1, no. 2.
- [15] P. Elbert, S. Ebbesen, and L. Guzzella, "Implementation of dynamic programming for n-dimensional optimal control problems with final state constraints," *IEEE Transactions on Control Systems Technology*, vol. 21, no. 3, pp. 924–931, 2013.
- [16] ETH, "Dpm function," http://www.idsc.ethz.ch/research-guzzella-onder/downloads.html.
- [17] P. Rutquist and M. Edvall, "Propt-matlab optimal control software, tomlab optimization," *Inc., Pullman, WA*, p. 65, 2010.
- [18] O. Sundstrom and L. Guzzella, "A generic dynamic programming matlab function," in 2009 IEEE Control Applications, (CCA) & Intelligent Control, (ISIC). IEEE, 2009, pp. 1625–1630.
- [19] "Propt matlab optimal control software," http://tomdyn.com/index.html.
- [20] P. Kundur, N. J. Balu, and M. G. Lauby, *Power System Stability and Control.* McGraw-hill New York, 1994, vol. 7.