Optimal Economic Gas Turbine Dispatch with Deep Reinforcement Learning

Manuel Sage^{*} Martin Staniszewski^{**} Yaoyao Fiona Zhao^{*}

* Department of Mechanical Engineering, McGill University, Montreal, Canada (e-mail: manuel.sage@mail.mcgill.ca, yaoyao.zhao@mcgill.ca). ** Siemens Energy Canada Limited, Montreal, Canada (e-mail: martin.staniszewski@siemens-energy.com)

Abstract: Dispatching strategies for gas turbines (GTs) are changing in modern electricity grids. A growing incorporation of intermittent renewable energy requires GTs to operate more but shorter cycles and more frequently on partial loads. Deep reinforcement learning (DRL) has recently emerged as a tool that can cope with this development and dispatch GTs economically. The key advantages of DRL are a model-free optimization and the ability to handle uncertainties, such as those introduced by varying loads or renewable energy production. In this study, three popular DRL algorithms are implemented for an economic GT dispatch problem on a case study in Alberta, Canada. We highlight the benefits of DRL by incorporating an existing thermodynamic software provided by Siemens Energy into the environment model and by simulating uncertainty via varying electricity prices, loads, and ambient conditions. Among the tested algorithms and baseline methods, Deep Q-Networks (DQN) obtained the highest rewards while Proximal Policy Optimization (PPO) was the most sample efficient. We further propose and implement a method to assign GT operation and maintenance cost dynamically based on operating hours and cycles. Compared to existing methods, our approach better approximates the true cost of modern GT dispatch and hence leads to more realistic policies.

Keywords: reinforcement learning, data-based control, intelligent control of power systems, optimal operation and control of power systems

1. INTRODUCTION

Gas turbines (GTs) play an interesting role in the discussion on modern power grids. When fired with fossil fuels such as natural gas, GTs emits greenhouse gases (GHG) and hence contribute to anthropogenic global warming. On the other hand, the significant increase in GT deployment in many areas, for example throughout North America, has allowed to phase out coal power plants which emit roughly twice as much GHG per unit of energy produced (Aramayo, 2020; NREL, 2021). Due to a raising incorporation of intermittent renewable energy (RE) and the lack of utility-scale energy storages for economic and technical reasons, the role of GTs in modern power grids has also changed. Fast ramping rates, partial-load operation, and higher cycle numbers are necessary to cope with the new market requirements (Tsoutsanis et al., 2016) and to facilitate the integration of RE. These aspects indicate the important role that GTs play in transitioning power grids and why natural gas is sometimes termed a *bridge fuel* (Levi, 2013). In the future, GTs fired with biogas or green hydrogen might combine the current advantages of GTs with low (or even net-zero) emissions.

The economic dispatch of GTs and hybrid energy systems (HES) involving GTs has thus been researched for many years. Mathematically, the dispatching translates into an optimization problem, and a wide range of approaches has been applied to the optimization of such systems,

C2023 the authors. This work has been accepted to IFAC for publication under a Creative Commons Licence CC-BY-NC-ND

predominantly with the objective to minimize the cost of operation. Most approaches can be assigned to one of the following three categories (Zhang et al., 2020): 1) classical mathematical methods such as Lagrangian relaxation (Ongsakul and Petcharaks, 2004; Thorin et al., 2005); 2) programming methods such as linear programming and dynamic programming (Carrion and Arroyo, 2006; Ommen et al., 2014); and 3) evolutionary-inspired heuristic methods such as genetic algorithms and particle swarm optimization (Hussain et al., 2019; Dixit et al., 2011).

Recently, with reinforcement learning (RL) a fourth category has gained attention due to an increasing number of successful implementations. Inspired by the progress of deep reinforcement learning (DRL) in popular computer science control tasks such as video games or robotic simulators (Mnih et al., 2015; Schulman et al., 2017), researchers have adopted DRL to the optimal dispatch problem. A key aspect behind the growing popularity of these datadriven models is that they do not require the derivation of a mathematical model of the analyzed system (Li et al., 2020). Model-free RL solely requires a sample model of the environment that generates the desired outputs for a set of inputs. This greatly facilitates the problem formulation and allows to incorporate existing GT models into environments for RL. Additionally, in the case of changing operating conditions, only the inputs and not the underlying formulas and constraints must be adjusted (Zhou et al., 2020).

A second advantage of DRL is its ability to cope with uncertainty. It is difficult to formally capture uncertainty regarding loads and intermittent energy sources in the objective functions and constraints of traditional whitebox approaches. Accounting for a large number of possible scenarios, for example by modeling longer time periods, quickly exceeds the size in which these methods can compute exact solutions (Perera and Kamalaruban, 2021). In the existing literature applying DRL to power dispatch, uncertainty is usually limited to RE and loads. While intermittent RE is affected stronger by uncertainty, the performance of GT also partially depends on the ambient conditions and is thus uncertain. The case study that we conduct in this work shows that throughout the course of a year the deliverable baseload power of the modeled GT can fluctuate between 22.7 MW and 30.3 MW due to varying ambient conditions. This represents a nonnegligible margin of approximately 25%.

In this study, we demonstrate the two advantages of DRL, model-free optimization and uncertainty handling, by incorporating an existing thermodynamic tool provided by Siemens Energy into our RL problem formulation. This allows a much more accurate GT power plant modeling than possible with traditional methods, taking into account the effect of ambient conditions on fuel consumption and power output. We further propose a new scheme to dynamically assign operation and maintenance (O&M) cost, which is based on operational hours and cycle counts, to every action taken by the RL agent. Our results from a case study in Alberta, Canada show that modern DRL algorithms perform well on the GT dispatch task regarding obtained rewards and sample efficiency. Furthermore, the results indicate that the proposed O&M cost scheme affects the policies learned and leads to more realistic GT operation.

2. RELATED WORK

With soft actor-critic (SAC), a DRL algorithm was deployed in the work of Teng et al. (2021) to optimally dispatch an electricity-gas system. Besides a GT, the system includes a power-to-gas converter, storages for power and gas, wind turbines (WT), and photovoltaic (PV). The economic dispatch of a combined heat- and power (CHP) system via distributed proximal policy optimization (DPPO) is described in Zhou et al. (2020). Here the objective is cost minimization for generating heat and power while meeting the respective demands. The DPPO algorithm is applied to both day-ahead as well as realtime dispatch. In Lin et al. (2020), the DRL algorithm asynchronous advantage actor-critic (A3C) is used for the economic dispatch of a virtual power plant (VPP). The VPP consists of three subregions that are each composed of WT, PV, GT, controllable loads, and uncontrollable loads. With microgrids and multiarea integrated energy systems, similar power systems have been dispatched by hierarchical RL in the work of Hao et al. (2021) and Li et al. (2020). Where compared to existing methods, the authors of the above studies reported better results with RL. Other studies applied RL to HES without GTs (Phan and Lai, 2019; Zhang et al., 2021). The various applications of RL to energy systems have been reviewed by Zhang et al. (2020) and Perera and Kamalaruban (2021).

In the above reviewed literature, GTs are modeled in a simplified way: via quadratic functions mapping power dispatch to operating cost (Hao et al., 2021; Li et al., 2020; Lin et al., 2020; Zhou et al., 2020), or as linear function connecting produced electricity and cost (Teng et al., 2021; Zhou et al., 2020). Teng et al. (2021) and Lin et al. (2020) also include cost associated with GHG emissions to the GT modeling approach. Lin et al. (2020) further expands the model with depreciation cost and O&M cost by multiplying a cost coefficient for O&M with the power produced by the gas turbines at every time step. Our approach differs from the related work regarding two aspects: 1) The incorporation of an existing GT modeling tool into the environment controlled by the RL agent. This enables us to replace the simple linear or quadratic functions commonly used to approximate GT operation cost. 2) The dynamic calculation of O&M cost based on the number of GT cycles and operating hours. The approach is motivated by the observation that other implementations of O&M cost can lead to unrealistic policies. These policies have high numbers of short cycles that would drastically increase cost in practice.

3. METHODOLOGY

3.1 Problem Formulation

For the case study, the SGT-A35, an aero-derivative GT from Siemens Energy with a nameplate capacity of 35 MW, is dispatched over a modeling period of one year with an hourly resolution. The GT is supplying power to an industrial facility with varying demands. These demands can also be met from the electricity grid at changing rates. The RL agents are thus required to learn when to operate the GT at what power level and when to purchase electricity instead. The location is assumed to be at 51.5°N, 111.75°W in Alberta. The province was chosen for three reasons: 1) it has recently experienced a transition from coal to gas and hence has significant gas infrastructure. 2) it has a large, energy-intense industry, and 3) it has great fluctuations in ambient conditions throughout the year. We use historical data from 2018 for our experiments. The climate data was obtained from the ERA5 reanalysis model (Hersbach et al., 2020) and consists of time-series for ambient temperature, ambient pressure, and relative humidity. For electricity, we take hourly pool prices from the Alberta Electric System Operator (2021) and assume that the modeled power plant can purchase electricity at these rates.

The demand is modeled via a load profile that we synthetically generate for this case study. It mimics a shiftbased demand as it occurs for manufacturing companies under single shift operation, with significant fluctuations between day and night as well as workday and weekend. The profile was generated by adding random hourly and weekly permutation, demand increases during hot and cold periods, as well as different holidays and plant-closure times to a weekly base template. Figure 1 shows a random week of the obtained demand.

The dispatch of the GT is a sequential decision-making job in which the RL agent decides at what power level the GT runs for every hour. The difference between demanded and



Fig. 1. Example of demand profile and maximum deliverable GT power for a random week in 2018.

produced power is bought from the electricity grid, however, surplus electricity cannot be sold. With this choice and the varying demands, we intent to better simulate the requirements on modern GT operation regarding partial loads and cycle numbers. The goal of the agent is to minimize the total annual cost C_{Total} :

$$\min C_{Total} = \sum_{t=0}^{8760} (C_{GT}(t) + C_{Grid}(t))$$
(1)

subject to:

 C_{O8}

$$C_{Grid}(t) = k_{Grid}(t) \times p_{Grid}(t) \tag{2}$$

$$C_{GT}(t) = C_{Fuel}(t) + C_{O\&M}(t) \tag{3}$$

$$C_{Fuel}(t) = k_{Fuel} \times q_{Fuel}(t) \tag{4}$$

$$k_{M}(t) = k_{GT,fixed} + b_{cycle}(t) \times k_{GT,cycle}$$
(5)

$$+b_{oper}(t) imes \kappa_{GT,oper}$$

$$D(t) = p_{GT}(t) + p_{Grid}(t) - p_{Waste}(t)$$
(6)

$$0 \le p_{GT}(t) \le \overline{p}_{GT}(t) \tag{7}$$

Where $C_{GT}(t)$ and $C_{Grid}(t)$ represent the cost of GT usage and electricity purchase from the grid at time step t, respectively. $k_{Grid}(t)$ and $p_{Grid}(t)$ are the pool price and the amount of purchased electricity. The cost of GT usage is composed of the cost of fuel, $C_{Fuel}(t)$, and O&M, $C_{O\&M}(t)$, associated with the current hour. The cost of fuel is computed by multiplying the amount of fuel burnt $q_{Fuel}(t)$ with the price of fuel k_{Fuel} . The fuel used for this case study is natural gas and the price is assumed to be fixed at C\$ 3.9 / GJ for the investigated period. The quantity of burnt fuel and the produced power, $p_{GT}(t)$, are determined for each hour by the provided thermodynamic tool. If $p_{GT}(t)$ is smaller than the industrial load, D(t), the difference is bought from the grid. Excess energy is wasted $(p_{Waste}(t))$. $\overline{p}_{GT}(t)$ is the maximum deliverable power by the GT. Figure 2 shows how the thermodynamic tool is integrated into the environment. It is first initialized with details on the plant setup and then queried at every hour with the agent's action and the respective ambient conditions. The tool then computes the produced net electricity and the resulting fuel flow. Researchers without access to a comparable software could replace equation 4 by the existing approaches previously mentioned, or resort to commercial plant modeling software such as HOMER¹ or Thermoflow 2

The O&M cost, $C_{O\&M}(t)$, are composed of a fixed component for each hour of the year, $k_{GT, fixed}$, a component for each GT cycle, $k_{GT,cycle}$, and a component for general operation, $k_{GT,oper}$. $b_{cycle}(t)$ is a binary variable that is 1 if the GT was started in the respective hour and zero otherwise. $b_{oper}(t)$ is a binary variable that is 1 if the GT is running for more than eight hours in a row and zero otherwise. The eight-hour threshold stems from the ratio: expected lifetime in hours over expected lifetime in cycles. Maintenance occurs after whatever is reached first, a certain number of hours or cycles. Thus, a mechanism is required that assigns cost depending on actual usage history and not only depending on the hours of operation. Algorithm 1 shows the proposed dynamic O&M cost calculation method in pseudocode. Note that the binary variables from Eq. 5 have been replaced by a single nonbinary variable, $\hat{G}T_{state}$. This variable stores the relevant part of the operational history and is part of the state space to keep the process memoryless or Markovian.

Algorithm 1 Calculation of O&M cost, $C_{O\&M}$
Initialize L_h , L_c , $C_{O\&M,fix}$, $C_{O\&M,var}$
$GT_{state} \leftarrow 0$
$GT_{hcount} \leftarrow 0$
for each step t of epsiode do:
get action a from RL agent
$C_{O\&M} \leftarrow 0$
if $a \neq 0$ then
if $GT_{state} = 0$ then
$C_{O\&M} \leftarrow C_{O\&M,var}/L_c \ \triangleright \text{ Cost for started cycle}$
$\mathbf{if} \ GT_{state} = 2 \mathbf{ then}$
$C_{O\&M} \leftarrow C_{O\&M,var}/L_h \triangleright \text{ Cost for long operation}$
$C_{O\&M} \leftarrow C_{O\&M} + C_{O\&M, fix}/8760$ \triangleright Fixed cost
if $a = 0$ then \triangleright Update GT_{state} and GT_{hcount}
$GT_{state} \leftarrow 0$
$GT_{hcount} \leftarrow 0$
else
$GT_{hcount} \leftarrow GT_{hcount} + 1$
if $GT_{hcount} \ge round(L_h/L_c)$ then
$GT_{state} \leftarrow 2$
else
$GT_{state} \leftarrow 1$
end for

end for

Table 1. Rounded parameter values for O&M cost calculation. GT life data and O&M cost were estimated based on Robb (2017); Balestrino (2019) and U.S. Energy Information Administration (2020), respectively.

Variable name	Description	Value
L_h	GT life in hours	200,000
L_c	GT life in cycles	26,000
$C_{O\&M,fix}$	Annual fix O&M cost in C\$	780,000
$C_{O\&M,var}$	Lifetime variable O&M cost in C\$	33,000,000

Table 1 shows approximate values for the O&M parameters. Rounded to the nearest integer, the ratio of lifetime in hours over lifetime in cycles is eight. In other words, if the average cycle has a duration of around eight hours, cycle and hour-based cost contribute equally to the variable O&M cost. The traditional, purely time-based cost estimation method fails to assign realistic cost for shorter cycle times. For example, with average cycles of two hours, the variable lifetime O&M cost would still be assigned

 $^{^1~{\}rm https://www.homerenergy.com/}$

² https://www.thermoflow.com/



Fig. 2. Agent - environment interaction and information flow. The thermodynamic GT tool was provided by Siemens Energy. Maintenance cost, start-up correction, and reward calculator were developed for this study.

throughout 200,000 hours but actually occur within only 52,000 hours when 26,000 cycles are reached. The proposed method solves this shortcoming by assigning cycle-based O&M cost whenever the GT is started, and hour-based O&M cost for each hour in cycles longer than eight hours.

The last addition to the environment is a start-up correction. When the GT is running, changes between power levels only take a few minutes due to high ramp rates. This does not affect hourly production considerably and is thus neglected. Starting the GT, however, has a profound impact on the current hour which is furthermore dependent on the ambient temperature. A regular start of the modeled A35 variant takes around 20 min from turn on to baseload power, while a start below 0° C requires an additional 15 min of engine warm-up, called mechanical idle. For the sake of simplicity, we assume the fuel consumption during start-up is equal to the fuel consumption at mechanical idle and apply a correction to the computed hourly net electricity and fuel flow depending on the temperature. This reduces the reward in hours when the GT is started and makes short cycles less attractive for the RL agent.

3.2 Reinforcement Learning

RL is a subcategory of machine learning in which an agent learns by interacting with the environment. As a feedback, the agent obtains rewards for the interactions and seeks to maximize the accumulated episodic rewards, i.e. the sum of rewards over one episode. In our experiments, the reward is the negative of the cost function at every hour and one episode is one year (see Eq. 1). The state vector is 6-dimensional and storing the following variables: pool price, load, ambient temperature, ambient pressure, relative humidity, and GT-state. The action space is onedimensional and bounded to range [0,1] by the environment, representing 0-100% of the available GT power at the respective hour. The implemented algorithms are RE-INFORCE, deep Q-networks (DQN), and proximal policy optimization (PPO). For REINFORCE, a continuous and a discrete version are tested. Together with DQN (discrete) and PPO (continuous), this results in two algorithms for each category. The discrete algorithms choose from seven

possible actions: [0, 0.5, 0.6, 0.7, 0.8, 0.9, 1] which are unevenly spaced due to significantly decreasing efficiencies under partial loads.

The DRL algorithms deployed in this study differ regarding their category and complexity. We implement all algorithms in PyTorch with artificial neural networks (ANNs) as function approximators. REINFORCE (Williams, 1992) is a policy-gradient Monte-Carlo algorithm. Implemented with a single policy network without baseline, it is the simplest DRL algorithm tested. PPO (Schulman et al., 2017) is a more sophisticated policy gradient algorithm with a modern actor-critic architecture. PPO seeks to keep policy updates within an approximated trust-region by optimizing a clipped surrogate loss. This algorithm has performed particularly well on continuous control tasks. PPO and REINFORCE train stochastic policies where actions are obtained by sampling from a learned normal distribution. DQN (Mnih et al., 2015) belongs to the group of value-iteration algorithms and its update is based on tabular Q-learning. Further modifications such as experience replay and a periodically updated target network enabled this algorithm to outperform existing methods on discrete control tasks when it was introduced. Both PPO and DQN are among the most popular DRL algorithms and commonly used to benchmark state-of-the-art methods. Our implementations of PPO and DQN are based on code from Han (2020) and Paszke (2017), respectively. For detailed discussions of the three algorithms, the reader is referred to the original papers.

We compare the results of the four tested variants to two baselines: the cross-entropy method (CEM) and a rule-based baseline. The CEM, introduced by Rubinstein (1999), is a heuristic, population-based optimization method that often serves as baseline for continuous RL algorithms. Our implementation of CEM is based on the work of Cook (2018). The rule-based baseline is implemented via a single if-then-else statement. If the condition is true, the GT is operated at baseload power (100%), else it is turned off. Among the state-variables, demand and electricity price influence the reward the most. The conditions for the if-statement are thus different thresholds for these two variables and possible logical combination of them via AND and OR statements. These simple rules don't allow for operation on partial loads, but instead operate the GT always at highest efficiency.

4. RESULTS AND DISCUSSION

We perform hyperparameter tuning for each algorithm and report the best results obtained regarding reward maximization and sample efficiency. All results reported in this section are average values over five independent runs. Fig. 3 shows the training curves of the algorithms for a training time of 250 episodes. The shaded area represents +/- one standard deviation and allows to assess the stability of the tested models. The best rule found for the rule-based baseline scored C\$ -4.32 million and operates the GT if the pool price exceeds C\$ 95/MWh. All four DRL algorithms outperform this baseline and learn better GT dispatch policies than the CEM. Both REINFORCE variants behave similarly and converge to lower episodic rewards while showing greater fluctuations compared to DQN and PPO. The training curve for DQN is highly dependent on the selected exploration-exploitation strategy. We use epsilongreedy action selection with linear epsilon-decay from 0.8 to 0.001. To obtain comparable results, we keep epsilon fixed at 0.001 for the last 10 episodes and report averaged episodic rewards over 5 runs and 10 episodes in Table 2. With annual cost of C\$-3.98 million, DQN reached the overall best rewards.

Sample efficiency is computed in a similar fashion by averaging the rewards over the first 20 episodes. Again, the choice of epsilon significantly influences this metric for DQN. We notice that only a few episodes are required for DQN to converge. Thus, its sample efficiency is measured for a shorter training period of 20 episodes, 10 with decaying epsilon and 10 with fixed epsilon. The dotted line in Fig. 3 shows this experiment. Sample efficiency scores for all algorithms are listed in Table 2. PPO is the most sample efficient algorithm, CEM again performs the worst in this metric.

Besides analyzing the performance, we investigate the effect of the proposed dynamic O&M cost scheme on the learned policies. Therefore, PPO and DQN are retrained over 50 episodes using three different variants of the environment: one with the proposed dynamic scheme, one with O&M cost based on operational hours only (i.e., b_{cycle} in Eq. 5 is always 0 and b_{oper} is 1 if the GT operates and 0 otherwise), and one with no variable O&M cost (i.e., b_{cycle} and b_{oper} are always 0).

We compare the environments regarding average rewards, annual operational hours, and annual cycles of the GT as displayed in Table 3. Interestingly, despite obtaining nearly the same rewards, the two algorithms differ in the learned policies. DQN dispatches the GT more often, causing both higher annual cycle and hour counts. A clear tendency across both algorithms is visible for the different variants of O&M cost calculation. Averaged over both algorithms, purely hourly-based O&M costs led to operating time increases of 32% in hours and of even 95% in cycles. If no variable O&M costs are assigned, the increase is even higher: 95% for operating hours and 198% for cycles compared to the proposed cost scheme. This



Fig. 3. Training curves of implemented models.

demonstrates that our approach influences agent behavior and successfully discourages short cycles.

5. CONCLUSIONS

The results of this study confirm that DRL is well-suited for economic dispatch problems involving uncertainty. Especially the more modern algorithms demonstrated higher sample efficiency and higher rewards. This applies to both continuous and discrete action selection. However, in different settings, for example if purchasing power from the grid is not possible and accurate load-following is required, continuous algorithms might be preferable.

The results further highlight the importance of an accurate O&M cost calculation due to its impact on learned policies. This is particularly relevant where GTs are operated to balance the intermittency of RE. Here, the proposed dynamic O&M scheme allows to better approximate the true cost of frequent but short cycles.

Table 2. Accumulated rewards and sample efficiencies of tested algorithms.

Algorithm	Acc. reward	Sample efficiency	
REINFORCE (continuous)	-4.22	-5.27	
REINFORCE (discrete)	-4.21	-5.57	
DQN	-3.98	-5.16	
PPO	-4.01	-4.73	
CEM	-4.40	-6.37	

Table 3. Comparison of performance and policy characteristics for DQN and PPO with different O&M scheme implementations.

		dynamic	hourly	no variable
		O&M	O&M	O&M
Acc. reward	DQN	-4.00	-3.96	-3.88
(M CAD)	PPO	-4.01	-3.97	-3.88
GT oper.	DQN	632	857	1129
hours	PPO	486	617	814
GT oper.	DQN	117	247	394
cycles	PPO	92	160	228

ACKNOWLEDGEMENTS

This work is supported by the McGill Engineering Doctoral Award (MEDA) and MITACS grant number IT13369. We thank Mahtab Salehii and Siemens Energy in Montreal for supporting our research.

REFERENCES

- Alberta Electric System Operator (2021). Market and system reporting. https://www.aeso.ca/market/ market-and-system-reporting/, visisted on 2022-10-27.
- Aramayo, L. (2020). More than 100 coal-fired plants have been replaced or converted to natural gas since 2011. https://www.eia.gov/todayinenergy/detail. php?id=44636, visited on 2022-10-23.
- Balestrino, C. (2019). Evolutionary improvements of Siemens SGT-A35 gas turbine (industrial RB211). Gas turbines for energy network symposium.
- Carrion, M. and Arroyo, J. (2006). A computationally efficient mixed-integer linear formulation for the thermal unit commitment problem. *IEEE Transactions on Power Systems*, 21(3), 1371–1378.
- Cook, A. (2018). CEM. URL https://github.com/ udacity/deep-reinforcement-learning/commits/ master/cross-entropy/CEM.ipynb.
- Dixit, G.P., Dubey, H.M., Pandit, M., and Panigrahi, B.K. (2011). Artificial bee colony optimization for combined economic load and emission dispatch. In International Conference on Sustainable Energy and Intelligent Systems (SEISCON 2011), 340–345.
- Han, Q. (2020). PPO PyTorch mujoco. URL https://github.com/qingshi9974/PPO-pytorch-Mujoco.
- Hao, R., Lu, T., Ai, Q., and He, H. (2021). Distributed online dispatch for microgrids using hierarchical reinforcement learning embedded with operation knowledge. *IEEE Transactions on Power Systems*, 1–1.
- Hersbach, H., Bell, B., Berrisford, P., Hirahara, S., Horányi, A., Muñoz-Sabater, J., Nicolas, J., Peubey, C., Radu, R., Schepers, D., et al. (2020). The ERA5 global reanalysis. *Quarterly Journal of the Royal Meteorologi*cal Society, 146(730), 1999–2049.
- Hussain, S., Al-Hitmi, M., Khaliq, S., Hussain, A., and Asghar Saqib, M. (2019). Implementation and comparison of particle swarm optimization and genetic algorithm techniques in combined economic emission dispatch of an independent power plant. *Energies*, 12(11).
- Levi, M. (2013). Climate consequences of natural gas as a bridge fuel. *Climatic change*, 118(3), 609–623.
- Li, Y., Tang, H., Lv, K., Wang, K., and Wang, G. (2020). Optimization of dynamic dispatch for multiarea integrated energy system based on hierarchical learning method. *IEEE Access*, 8, 72485–72497.
- Lin, L., Guan, X., Peng, Y., Wang, N., Maharjan, S., and Ohtsuki, T. (2020). Deep reinforcement learning for economic dispatch of virtual power plant in internet of energy. *IEEE Internet of Things Journal*, 7(7), 6288– 6301.
- Mnih, V., Kavukcuoglu, K., Silver, D., Rusu, A.A., Veness, J., Bellemare, M.G., Graves, A., Riedmiller, M., Fidjeland, A.K., Ostrovski, G., et al. (2015). Human-level control through deep reinforcement learning. *nature*, 518(7540), 529–533.
- NREL (2021). Life cycle greenhouse gas emissions from electricity generation: Update. https://www.nrel. gov/docs/fy21osti/80580.pdf, visited on 2022-10-26.

- Ommen, T., Markussen, W.B., and Elmegaard, B. (2014). Comparison of linear, mixed integer and non-linear programming methods in energy system dispatch modelling. *Energy*, 74, 109–118.
- Ongsakul, W. and Petcharaks, N. (2004). Unit commitment by enhanced adaptive lagrangian relaxation. *IEEE Transactions on Power Systems*, 19(1), 620–628.
- Paszke, A. (2017). Reinforcment learning (DQN) tutorial. URL https://pytorch.org/tutorials/ intermediate/reinforcement_q_learning.html.
- Perera, A. and Kamalaruban, P. (2021). Applications of reinforcement learning in energy systems. *Renewable* and Sustainable Energy Reviews, 137, 110618.
- Phan, B.C. and Lai, Y.C. (2019). Control strategy of a hybrid renewable energy system based on reinforcement learning approach for an isolated microgrid. *Applied Sciences*, 9(19).
- Robb, D. (2017). Aeroderivative gas turbines. https://www.turbomachinerymag.com/view/ aeroderivative-gas-turbines, visited on 2022-11-25.
- Rubinstein, R. (1999). The cross-entropy method for combinatorial and continuous optimization. *Methodology* and computing in applied probability, 1(2), 127–190.
- Schulman, J., Wolski, F., Dhariwal, P., Radford, A., and Klimov, O. (2017). Proximal policy optimization algorithms. *CoRR*, abs/1707.06347.
- Teng, X., Long, H., and Yang, L. (2021). Integrated electricity-gas system optimal dispatch based on deep reinforcement learning. In 2021 IEEE Sustainable Power and Energy Conference (iSPEC), 1082–1086.
- Thorin, E., Brand, H., and Weber, C. (2005). Long-term optimization of cogeneration systems in a competitive market environment. *Applied Energy*, 81(2), 152–169.
- Tsoutsanis, E., Meskin, N., Benammar, M., and Khorasani, K. (2016). A dynamic prognosis scheme for flexible operation of gas turbines. *Applied Energy*, 164, 686–701.
- U.S. Energy Information Administration (2020). Capital cost and performance characteristic estimates for utility scale electric power generating technologies. URL https://www.eia.gov/analysis/studies/ powerplants/capitalcost/pdf/capital_cost_ AEO2020.pdf.
- Williams, R.J. (1992). Simple statistical gradient-following algorithms for connectionist reinforcement learning. *Machine learning*, 8(3), 229–256.
- Zhang, G., Hu, W., Cao, D., Liu, W., Huang, R., Huang, Q., Chen, Z., and Blaabjerg, F. (2021). Data-driven optimal energy management for a wind-solar-dieselbattery-reverse osmosis hybrid energy system using a deep reinforcement learning approach. *Energy Conver*sion and Management, 227, 113608.
- Zhang, Z., Zhang, D., and Qiu, R.C. (2020). Deep reinforcement learning for power system applications: An overview. *CSEE Journal of Power and Energy Systems*, 6(1), 213–225.
- Zhou, S., Hu, Z., Gu, W., Jiang, M., Chen, M., Hong, Q., and Booth, C. (2020). Combined heat and power system intelligent economic dispatch: A deep reinforcement learning approach. *International Journal of Electrical Power & Energy Systems*, 120, 106016.