Securing Legacy Communication Networks via Authenticated Cyclic Redundancy Integrity Check

Alessandro Lotto University of Padova, Italy alessandro.lotto@math.unipd.it Alessandro Brighente University of Padova, Italy alessandro.brighente@unipd.it Mauro Conti Univeristy of Padova, Italy mauro.conti@unipd.it

Abstract—Integrating modern communication technologies into legacy systems, such as Industrial Control Systems and in-vehicle networks, invalidates the assumptions of isolated and trusted operating environments. Security incidents like the 2015 Ukraine power grid attack and the 2021 compromise of a U.S. water treatment facility demonstrate how increased interconnectivity, paired with insufficient security measures, expose these critical systems to cyber threats, posing risks to national and public safety. These attacks were favored by the lack of proper message authentication, highlighting its importance as a primary countermeasure to enhance system security. Solutions proposed in the literature remain largely unadopted in practice due to challenges such as preserving backward compatibility, additional hardware requirements, and limited computational resources on legacy devices. Moreover, many solutions are protocol-specific, necessitating complex and costly multiple implementations in heterogeneous systems.

In this paper, we propose Authenticated Cyclic Redundancy Integrity Check (ACRIC), a novel security mechanism that overcomes these limitations by leveraging a cryptographic computation of the existing Cyclyic Redundancy Check (CRC) field to ensure message integrity protection and authentication. ACRIC preserves backward compatibility without requiring additional hardware and is protocol agnostic. This makes it applicable across various systems, suitable for diverse legacy network protocols including point-to-point and broadcast communications. Experimental results, supported by formal verification and real-world testing, demonstrate that ACRIC offers robust security with minimal transmission overhead (\ll 1 ms). This proves ACRIC's practicality, cost-effectiveness, and suitability for real-world adoption.

1. Introduction

Securing legacy systems and devices, including Industrial Control System (ICS), Supervisory Control And Data Acquisition (SCADA), transportation, air-traffic control systems, and in-vehicle networks, is a critical challenge in modern cybersecurity [1], [2]. While integrating contemporary communication technologies enhances the functionality and efficiency of these systems, it also removes the initial design assumption of operating in isolated and trusted environments, thereby expanding their vulnerability surface to cyber threats [2], [3], [4]. Many of these legacy systems rely on outdated network protocols and resource-constrained hardware lacking essential security features. This makes it challenging to integrate advanced security measures like robust encryption and authentication [5], [6], [7], [8]. This combination of outdated infrastructure and resource constraints makes legacy systems especially vulnerable to cyberattacks. High-profile incidents illustrate the severe risks these vulnerabilities pose if exploited, including economic damage and threats to national and public safety [6], [7], [9]. Examples include the 2010 Stuxnet attack, which sabotaged Iranian nuclear centrifuges [10]; the 2012 ADS-B spoofing attack demonstration, which exposed risks in aircraft tracking systems [11]; the 2015 attack on Ukraine's power grid, causing widespread outages [12]; the 2017 LogicLocker attack, which compromised water treatment controls [13]; the 2018 Jeep hacking demonstration exploiting vulnerabilities in the CAN bus protocol [14]; and the 2019 U.S. Post Rock Water District breach, which highlighted security gaps in water infrastructure [1]. These incidents emphasize the inadequacy of current security measures in deployed legacy systems, underscoring the need for urgent improvements. A major vulnerability in many of these systems is the lack of robust authentication and integrity mechanisms, which are essential to prevent unauthorized access and safeguard system integrity.

While secure variants of legacy protocols, such as Modbus with TLS [15], and new secure protocols like OPC UA [16] have been introduced, upgrading legacy infrastructure to use these protocols is often impractical. Constraints include the cost of hardware updates, the need for continuous system availability, and compatibility with existing systems [17], [18]. Consequently, much research has focused on retrofitting security into legacy protocols. However, despite broad recognition of this need, proposed protocollevel solutions have seen limited industrial adoption due to their narrow focus on specific protocols and limited deployability consideration [3], [9], [18], [19]. A universal, adaptable solution is, therefore, highly desirable. In light of this, we identify the main challenges to retrofitting security features in resource-constrained environments, which hinder the adoption of state-of-the-art solutions in real-world settings. Key challenges include ensuring interoperability, maintaining data throughput, and minimizing computational overhead to avoid latency in real-time systems. Protocols that rely on Message Authentication Codes (MACs) modify frame formats, impacting interoperability and data throughput. Lightweight cryptographic tools are needed to reduce computational demands, as solutions based on digital signatures, asymmetric encryption, or certificates typically introduce excessive latency. Additionally, minimizing deployment costs is crucial, a challenge that makes Bump-in-the-Wire (BITW) approaches, which require new hardware or changes to existing infrastructure, impractical. Finally, key distribution and system initialization are often overlooked in existing solutions, treated as external services rather than integral components.

Contributions. In this paper, we present Authenticated Cyclic Redundancy Integrity Check (ACRIC), a novel authentication and integrity protection mechanism designed to address the above identified limitations and challenges. ACRIC uses cryptographic Cyclic Redundancy Check (CRC) computation, a field already present in legacy protocols. To this aim, it leverages a secret CRC initialization vector and One-Time Pad (OTP) encryption to enhance security without altering message formats or introducing new fields. This approach maintains backward compatibility, preserves data throughput, and only requires software updates, allowing secure and non-secure devices to coexist on the same network and enabling a smooth transition to full security. Furthermore, ACRIC's abstraction from specific protocols makes it i) compatible with both Pointto-Point (P2P) and broadcast communication models, ii) applicable across various systems, and iii) cost-effective in deployment. To further facilitate implementation, ACRIC incorporates a tailored key distribution process for system initialization. Through formal verification and real-world testing, we demonstrate that ACRIC is a practical ($\ll 1$ ms latency), cost-effective solution for enhancing security in legacy systems.

Our contributions are as follows:

- We identify key challenges in designing security solutions for legacy systems that limit the adoption of current state-of-the-art approaches in the real-world.
- We develop ACRIC, an authentication mechanism tailored to secure legacy systems, addressing the identified challenges and suitable for both P2P and broadcast communications.
- We formally verify ACRIC's security properties using Scyther, a widely accepted tool for formal protocol verification.
- We evaluate ACRIC's transmission and computational performance in a real-world testbed. Results show that induced latency is minimal (≪ 1 ms), proving ACRIC preserves real-time system capabilities, making it suitable for practical deployment.

The paper is organized as follows: Section 2 outlines the identified challenges and the goals for designing ACRIC. Section 3 provides foundational background, and Section 4 defines the system and threat models. Section 5 details

ACRIC. In Section 6, we discuss hash chain management, essential for optimizing ACRIC. Section 7 assesses ACRIC's security and performance. Section 8 reviews the related works. Finally, Section 9 concludes the paper.

2. Design Challenges and Goals

This section discusses the key challenges involved in designing authentication mechanisms for legacy protocols. These challenges include traditional requirements - *interoperability, minimal overhead,* and *low deployment costs* - and newer demands - *preserving data throughput, security parameter distribution,* and *compatibility with mixed systems.* Together, these factors limit the adoption of state-of-the-art proposals in real-world applications. We then define specific security and operational design goals that stem from these challenges, along with the features that make ACRIC effective and practical. Figure 1 visually illustrates the connections between these challenges, the derived design goals, and the features ACRIC offers.

2.1. Challenges

In the past decade, substantial efforts have been dedicated to enhancing the security of legacy communication protocols, with a particular focus on industrial (ICS and SCADA) and in-vehicle networks. This focus derives from the rapid development of the Industrial Internet-of-Things (IIOT) and automated driving technologies, which have increased the need for secure data exchange in traditionally isolated, now interconnected, environments [2], [3], [20]. Much of this work concentrated on integrating security mechanisms such as Digital Signatures (DSs), MACs,



Figure 1: Relationship between (i) identified challenges in securing legacy systems and (ii) design goals to address them. From these goals, we derive key features for ACRIC.

encryption, and Intrusion Detection Systems (IDSs), into existing standard protocols and legacy devices [6], [21], [22], [23], [24]. However, despite theoretical progress, these solutions encounter significant challenges when applied in real-world, resource-constrained environments. To better understand these limitations, we conducted an in-depth review of related works and collaborated directly with CAREL, a leading multinational in the ICS sector for Heating, Ventilation, and Air Conditioning (HVAC) systems — a domain marked by strict resource limitations. This process enabled us to identify key challenges that must be addressed when designing authentication solutions for legacy systems in resource-constrained environments [5], [7], [22], [23], [24], [25], [26]:

- <u>Challenge 1 Interoperability</u>. Simultaneously upgrading all devices to a secure version is impractical and costly, especially in critical industrial settings. Security solutions must ensure backward compatibility by preserving the original message frame structure. This challenge limits the extent of possible protocol modifications but is essential for enabling secure and non-secure devices to coexist and communicate seamlessly.
- <u>Challenge 2 Maintain Data Throughput</u>. Legacy protocols were originally designed to maximize data transmission efficiency, given the limited bandwidth and need for timely data exchange in their operational contexts. Adding authentication data and associated security parameters within the message payload reduces space available for actual data, thereby decreasing data throughput. This challenge requires designing security measures that do not compromise the data transmission rates critical to these environments.
- <u>Challenge 3 Distribution of Security Parameters</u>. Secure communication typically relies on the distribution of cryptographic parameters. Most existing solutions treat key distribution as an external service, rather than integrating it into the protocol design. However, given the resource constraints and complexity of legacy environments, we argue that key distribution and initialization should be embedded within the protocol design process to ensure practicality in environments lacking external cryptographic service infrastructure.
- Challenge 4 Minimizing Deployment Costs. Implementing security solutions that require additional hardware or substantial infrastructure modifications is prohibitively expensive, especially in industrial settings where large-scale device replacements are unfeasible. To encourage widespread adoption, security implementations must minimize deployment costs.
- Challenge 5 Minimizing Computational Overhead. Real-time performance is crucial in industrial and other time-sensitive applications. Ensuring that the security solution is lightweight and computationally

efficient is essential to avoid negatively impacting the performance and reliability of critical systems.

• Challenge 6 - Compatibility with Mixed Systems. Existing solutions are tailored for specific communication protocols, requiring multiple implementations when different protocols are in use. This increases deployment costs and adds complexity. A single solution adaptable to diverse applications is highly preferable.

2.2. Security Goals

Legacy systems are known to be vulnerable to a range of attacks, including message spoofing, modification, replay, Man-In-The-Middle (MITM), and Denial-of-Service (DoS) attacks [5], [27], [28], [29]. Unlike conventional IT security, which is centered on the Confidentiality, Integrity, and Availability (CIA) triad, systems such as ICS and invehicle networks prioritize the Availability, Integrity, and Confidentiality (AIC) model [5], [30]. This focus reflects the importance of continuous availability and data integrity, as disruptions or alterations to data can significantly impact physical operations and safety [31]. Confidentiality, on the other hand, is often deprioritized for several reasons [32], [33], [34]: (i) the limited computational capacity of these devices constrains their ability to execute complex encryption operations; (ii) encryption introduces latency, which is problematic in real-time control systems where rapid response times are essential; (iii) communications are often predictable due to their ties to physical processes, allowing attackers to infer encrypted content without necessarily decrypting it. Consequently, the primary security objectives for these systems focus on ensuring [5], [6], [28]:

- <u>Authentication</u>: Ensures that all entities involved in communication are verified and legitimate.
- <u>Integrity Protection</u>: Prevents unauthorized modifications to messages, thereby preserving the accuracy and trustworthiness of the data.
- *Replay Protection*: Prevents the reuse of previously valid transmitted data, reducing the risk of unauthorized actions.

2.3. Operational Goals

Operational goals address the previously discussed challenges, making ACRIC practical and ready for real-world adoption. To this end, we aim to ensure:

• Backward compatibility (Addresses challenges 1 and $\overline{4}$). The solution must integrate with the existing infrastructure, allowing secure and non-secure devices to coexist on the same network. Maintaining the protocol's original frame format enables fitting into existing systems without modifications. Additionally, the solution must avoid extensive changes or the introduction of additional hardware. ACRIC meets this goal by leveraging the CRC field, present

in most legacy communication protocols. This approach is cost-effective, requiring only software updates without adding new hardware.

- <u>Preserve data payload size</u> (Challenge 2). The solution must maintain data throughput by utilizing existing protocol structures, avoiding the need for additional payload space. ACRIC achieves this using the existing CRC field, thereby preserving payload size and data throughput.
- *Efficient key agreement procedure* (Challenge 3). The solution must include a built-in, efficient initialization process for key agreements and updates. ACRIC includes an efficient key agreement and distribution procedure by design, ensuring the system remains secure and easy to maintain.
- <u>Real-Time Response</u> (Challenge 5). The solution must support real-time operations, a common requirement in legacy systems. ACRIC is optimized to minimize computational load and communication delays, avoiding resource-intensive cryptographic operations in real-time.
- *Protocol-Agnostic Solution* (Challenge 6). The solution must be suitable for a variety of communication protocols. ACRIC utilizes the CRC field, which is present in most legacy protocols, thus being applicable across various systems.

By achieving these design goals, ACRIC addresses the identified challenges, providing a robust security solution tailored to the specific needs and constraints of legacy communication environments.

3. Background

This section provides the essential background information to fully comprehend the ACRIC framework. Section 3.1 introduces the concept of CRC, emphasizing its main features and parameters; Section 3.2 discusses cryptographic hash functions and hash chains, key components of our authentication mechanism.

3.1. Cyclic Redundancy Check (CRC)

Cyclic Redundancy Check (CRC) is a widely used technique in digital communications for detecting data transmission errors. In CRC computation, data is represented as a binary polynomial and is divided by a generator polynomial of degree n using modulo two arithmetic [35]. This simplifies operations to XOR without carries. This n-bit remainder of this division forms the CRC value. During transmission, the receiver recalculates the CRC: a zero remainder indicates error-free data, while a non-zero remainder signals an error.

The choice of generator polynomial - an *n*-degree polynomial with binary coefficients - is critical to CRC's effectiveness. Irreducible polynomials ensure detection of any single error within a certain block length and maximize error-detection capabilities by maintaining a high minimum Hamming distance between valid codes [36]. Additionally,

a well-chosen generator can detect all burst errors up to a specific length and a high percentage of longer bursts, enhancing data reliability. Thus, generator polynomial selection balances computational efficiency with error-detection performance [35], [36]. Variations in Initialization Vector (*InitVec*) value, which sets the CRC's starting state, as well as input/output data reflection and final XOR values, can modify the CRC calculation but do not impact its errordetection capability, which depends primarily on the generator polynomial [36]. CRCs are valued for their strong error detection and computational efficiency. The simplicity of bitwise operations makes CRCs ideal for hardware implementation and real-time applications.

3.2. Cryptographic Hash Functions & Hash Chains

A hash function is a mathematical function $H(\cdot)$ that takes an input of arbitrary length and produces a fixedlength binary string h, known as the hash value or digest. Ideally, the output is unique to each input data and should be uniformly distributed across the output space [37]. Formally:

$$H := \mathcal{X} \to \mathcal{Y} = \mathbb{B}^n \to \mathbb{B}^m$$
, where $\mathbb{B} = \{0, 1\}$. (1)

Cryptographic hash functions are specialized hash functions that meet specific security properties, making them suitable for cryptographic applications [38]. They must satisfy the following properties [37], [39]:

- 1) <u>Pre-Image Resistance</u>: Given $y \in \mathcal{Y}$, it must be computationally infeasible to find any $x \in \mathcal{X}$ such that H(x) = y.
- 2) <u>Second Pre-image Resistance</u>: Given $x_1 \in \mathcal{X}$, it must be computationally infeasible to find $x_2 \in \mathcal{X}$, $x_2 \neq x_1$, such that $H(x_1) = H(x_2)$.
- 3) <u>Collision Resistance</u>: It must be computationally infeasible to find any two distinct inputs $(x_1, x_2) \in \mathcal{X}^2$, $x_1 \neq x_2$, such that $H(x_1) = H(x_2)$.
- 4) Avalanche Effect: A small change in the input should result in a significantly different hash value, reflecting a high sensitivity to input variations.

A hash chain \mathcal{H} is created by repeatedly applying a hash function, using each output as the input for the next step. This process creates a sequence of n hash values $\mathcal{H} = \{h_0, h_1, \ldots, h_n\}$ [40]. The relationship between these values is defined as follows:

$$\mathcal{H} = \begin{cases} h_0 = H(x) \\ h_i = H(h_{i-1}) \text{ for } i = 1, \dots, n. \end{cases}$$
(2)

This cryptographic tool is often used for authentication, relying on the pre-image resistance property of the adopted hash function.

Cryptographic mechanisms that provide integrity and authenticity using a cryptographic hash function in combination with a secret key are termed **Hash-based Message Authentication Codes (HMACs)** [38].

4. System and Threat Models

In this section, we define the context and assumptions for the system under consideration. Section 4.1 outlines the components and interactions within the system, while Section 4.2 identifies potential adversaries, their capabilities, and relevant attack types.

4.1. System Model

Our system model focuses on legacy systems with resource-constrained devices that use non-secure protocols incorporating a CRC field - an essential component, as ACRIC depends on its presence. Most legacy protocols include a CRC field to ensure transmission reliability, making it a standard feature in industrial and embedded systems [36], [41]. To keep the model general, we abstract away specific network layouts, focusing instead on essential functionalities. A central feature of our model is the coexistence of secure and non-secure devices within the network. In industrial settings, upgrading all devices to meet new security standards simultaneously is often impractical due to logistical constraints, costs, and the need for continuous operation. By allowing phased security upgrades, this design minimizes operational disruptions and downtime, ensuring that critical infrastructure remains functional.

Our model considers two primary communication types: P2P and broadcast, with multicast and unicast treated as specific cases of these primary types. For broadcast communications, we assume a group key model, where members of the same group share a common cryptographic key to authenticate messages within their group [22]. However, group key approaches require careful management to prevent security vulnerabilities [22]. To mitigate this, we assume that group memberships are strictly managed, with devices assigned only the permissions necessary for their roles to reduce unauthorized access and prevent masquerade attacks. Our approach supports various communication protocols, enabling authentication mechanisms in both P2P and broadcast scenarios. This flexibility allows ACRIC to be applied broadly across different network configurations, enhancing security while maintaining compatibility with existing system architectures.

4.2. Threat Model

Several studies have examined the security of legacy systems such as ICSs, SCADA, and in-vehicle networks, highlighting their vulnerabilities and attack vectors [21], [22], [27], [42], [43], [44]. Our threat model draws on frameworks used in prior works [8], [22], [25], [45], [46], [47] and aligns with the established *Dolev-Yao* model [48], which comprehensively defines attacker capabilities in both networked and cyber-physical environments. By leveraging these models, we adopt widely accepted assumptions and principles to outline potential communication threats.

Attacker's Capabilities. We assume a well-resourced attacker with substantial network access capabilities, balanced by some specific constraints:

- <u>Access to the Network</u>: The attacker has complete access to the communication network, enabling interception, modification, and injection of messages. However, the attacker cannot compromise hardware or internal cryptographic mechanisms, consistent with the Dolev-Yao model [48].
- Act as passive and active roles: The attacker can passively eavesdrop on sensitive information and actively inject, modify, or replay messages.
- <u>Knowledge of Protection Mechanisms</u>: The attacker is aware of the authentication mechanism in use. This aligns with Kerckhoff's principle, which states that system security should depend on the secrecy of the keys, not the protocol itself [49].

Attacker's Goals and Methods. In line with previous studies, the attacker may pursue the following objectives:

- <u>Spoofing</u>: Sending unauthorized messages impersonating legitimate devices.
- <u>*Tampering*</u>: Modifying legitimate messages during transmission.
- <u>*Replay Attacks*</u>: Retransmitting previous legitimate messages to induce unauthorized effects.

Attacks such as DoS, fingerprinting, and side-channel attacks fall outside the scope of this model, as cryptographic authentication mechanisms alone cannot prevent these threats. Addressing these types of attacks requires broader defense strategies, such as anomaly detection and network-wide monitoring [22].

5. Our Proposed Mechanism: ACRIC

This section details the design of ACRIC to enable authentication and integrity protection in legacy protocols. Section 5.1 introduces ACRIC's key principles Section 5.2 discusses system initialization and key agreement methods, examining their benefits and limitations. Section 5.3 focuses on the authentication and integrity protection process, while Section 5.3.1 covers specific considerations for authenticating broadcast messages in P2P communications.

5.1. Overview

ACRIC enhances the security of legacy protocols by providing message integrity protection and authentication. Legacy communication protocols typically include a CRC field to detect transmission errors, calculated using an Initialization Vector (*InitVec*), a generator polynomial, and the message content. While standard CRC serves as a basic integrity check, it does not offer integrity protection. Hence, because protocols often standardize the *InitVec* and generator polynomial, an attacker can alter the message payload, compute the corresponding CRC, and replace the original CRC to evade detection. ACRIC repurposes the CRC field to provide message integrity and authenticity. This is achieved by incorporating a secret *InitVec* and applying OTP encryption. The proposed methodology consists of three phases:

- <u>Initialization</u>: This is the procedure for setting up or refreshing cryptographic parameters for authenticated communications. Specifically, this phases enables the involved parties to establish a secret session key and a hash chain initialization value.
- <u>*CRC Calculation*</u>: Rather than using the standard CRC, we use a secret value known only to the transmitter and receiver(s). This secret *InitVec* verifies both the integrity and authenticity of the message. A matching between calculated and received CRC indicates the message is legitimate, as only authorized parties possess the correct *InitVec*.
- <u>CRC Encryption</u>: Although a correct CRC confirms message integrity and origin, knowledge of both the message content and its CRC could enable an attacker to deduce the *InitVec*, compromising security. To counter this risk, ACRIC encrypts the CRC before transmission using OTP encryption — applying an XOR operation between the CRC and a single-use secret key shared between communicating parties. This one-time use of the key prevents attackers from reverse-engineering the initialization sequence.

By introducing a secret *InitVec* and encrypting the CRC, ACRIC significantly strengthens the security of legacy communication systems, ensuring both integrity protection and authentication while maintaining compatibility with standard protocols and non-secured devices. Detailed discussions on key management and cryptographic considerations are provided in subsequent sections.

5.2. Initialization Procedure

To address deployment cost constraints and simplify implementation, our approach assumes that each device in the network is equipped with a long-term master key, K_m . This design choice reduces the complexity and expense of deploying the security mechanism, aiming to streamline the deployment phase. Adding static security parameters, such as counters, would increase deployment complexity by requiring precise synchronization across devices and groups. Instead, our approach generates supplementary security parameters dynamically at runtime, minimizing the need for pre-loaded, synchronized values and reducing human intervention. Nevertheless, for completeness, we also consider the option of pre-loading additional security parameters during installation, leaving the design choice to the manufacturers' convenience. Furthermore, ACRIC avoids relying on identity-based authentication, meaning that identity information is not used in computing security values. This design choice accommodates protocols that do not inherently use unique node identifiers, such as the CAN-bus protocol [50].

The initialization procedure distributes essential security parameters for secure communication, specifically establishing symmetric session keys K_s and shared hash chains \mathcal{H} among participants. This procedure occurs during system installation and periodically to refresh security parameters. We identify two main approaches for initializing the system and establishing secure session keys: *static computation* and *dynamic computation*, each with distinct advantages and limitations regarding security, complexity, and practicality.

In the **static approach**, entities compute the session key independently, without requiring message exchanges, deriving it directly from the master key. For unique session keys within each communication group or pair, a shared secret value C must be distributed exclusively among relevant entities. In P2P communications, C acts as a pair-based secret, while in broadcast scenarios, it serves as a group-based secret. A major advantage of this approach is that key agreement is achieved locally, eliminating the need for message exchanges and reducing runtime communication overhead. However, it adds complexity to deployment, as each device must be carefully pre-configured with the necessary secret values C_i . This manual configuration increases the risk of human error, which could compromise network security or cause initialization failures.

The dynamic approach, by contrast, involves active interactions between entities to establish the session key. Here, directly deriving the session key from the master key, as in the static approach, is impractical because a unique shared secret value C must be generated dynamically. Generating C dynamically introduces challenges: (i) if one node generates C and then distributes it, confidentiality must be ensured. Encrypting with the master key K_m is insecure, as all nodes have access to K_m and could decrypt it retrieving C. Additionally, (ii) pre-loading C would revert the system to the static model, negating the purpose of a dynamic approach. To overcome these challenges, we must employ a key agreement protocol, such as Diffie-Hellman [51], which securely establishes the session key through authenticated exchanges. The dynamic approach offers significant deployment simplicity by requiring only a common master key for initial configuration, with other parameters generated at runtime. This reduces the need for manually configuring individual secret values. However, dynamic initialization requires active communication among entities, which increases initialization time due to multiple protocol rounds for secure session key establishment.

Both static and dynamic approaches are viable, with the choice depending on network requirements, security constraints, and deployment context. Table 1 summarizes the advantages and disadvantages of each approach discussed above. Given the simplicity of static computation, we present a potential solution for dynamic initialization using an authenticated Diffie-Hellman protocol, balancing security with practical deployment considerations.

5.2.1. Dynamic Initialization in P2P Model. Secured network nodes are equipped with a shared master key K_m . For each intended receiver, the transmitter initiates an authenticated Diffie-Hellman exchange to securely establish a

session key K_s and a hash chain initialization value l. We define:

- *p*: a large public prime number;
- g: a public generator of the group $Z_p^* = \{0, \dots, p-1\};$
- H(K, P): HMAC function with key K and data P;
- *mod*: the arithmetic modulo operation;
- *Tx*: the device initiating the communication;
- *Rx*: the device receiving the communication.

The initialization procedure follows these steps:

- 1) Key Generation (a, A): *Tx* samples a random private key *a* and computes the corresponding public key $A = g^a \mod p$.
- 2) **DH_msg1:** Tx sends A to Rx, authenticated with $h_0^* = H(K_m, A)$.
 - The transmitted message is $DH_msg1 = [A || h_0^*]$.
- 3) Verification of (h_0^*) : Rx verifies the authenticity of the received message $\left(\left[\tilde{A}||\tilde{h}_0^*]\right]\right)$ by checking if $\hat{h}_0^* = H\left(K_m, \tilde{A}\right) \stackrel{?}{=} \tilde{h}_0^*$.
- 4) **Key Generation** (b, B): Upon successful verification, Rx samples a random private key b and computes its public key $B = g^b \mod p$.
- 5) **DH_msg2:** Rx sends B to Tx, authenticated with $h_1^* = H(K_m, B)$.
- The transmitted message is $DH_msg = [B || h_1^*]$. 6) Verification of (h_1^*) : Tx verifies the authentic-
- ity of the received message, confirming $\hat{h}_1^* = H\left(K_m, \tilde{B}\right) \stackrel{?}{=} \tilde{h}_1^*$.

Upon successful verification, Tx computes the shared session key $K_s = B^a \mod p = (g^b)^a \mod p$.

- 7) HC_msg1: Tx generates a random initialization value l for the hash chain H. Tx sends l, encrypted and authenticated as: HC_msg1 = [l ⊕ K_s || H (K_s, l)] = [L || h₂^{*}].
 8) Variant charter and the computer K.
- 8) Verification of (h_2^*) : Rx computes $K_s = A^b \mod p$ and retrieves $\hat{l} = \tilde{L} \oplus K_s = (l \oplus \tilde{K}_s) \oplus K_s$ It then verifies the message by checking if $\hat{h}_2^* = H(K_s, \hat{l}) \stackrel{?}{=} \tilde{h}_2^*$.
- 9) **HC_msg2:** If verification succeeds, Rx responds with $HC_msg2 = [H(K_s, l+1)] = [h_3^*]$, confirming the correct receipt of l.

TABLE 1	l: Com	parison	between	initialization	approaches.
---------	--------	---------	---------	----------------	-------------

Initialization Approach	Pros (✓) & Cons (✗)
Static	[✓] No message exchanges
	[X] Requires manual configuration
Dynamia	$[\checkmark]$ No manual configuration
Dynamic	[X] Requires a key agreement protocol

10) Verification (h_3^*) : *Tx* checks for the authenticity of the response. If successful, both *Tx* and *Rx* compute the hash chain \mathcal{H} . If unsuccessful, *Tx* notifies *Rx* of the error, requiring a reinitialization.

Upon successful initialization, Tx and Rx securely share the session key K_s and the hash chain initialization value l:

$$\mathcal{H} = \begin{cases} h_0 = H(K_s, l), \\ h_i = H(K_s, h_{i-1}) \text{ for } i = 1, \dots, N. \end{cases}$$
(3)

Elements from this hash chain will authenticate future messages. Figure 2 provides a visual representation of the steps of the described procedure.



Figure 2: ACRIC system initialization with authenticated Diffie-Hellman procedure to securely establish a session key K_s and a hash chain initialization value l.

5.2.2. Dynamic Initialization in Broadcast Model. To enable secure communication within a group of entities, we employ a Group Diffie-Hellman protocol to establish a shared session key among all group members. This protocol extends the traditional P2P Diffie-Hellman approach, allowing secure key agreement across multiple nodes and ensuring that each participating entity derives the same session key. In a Group Diffie-Hellman setup, each node generates its own public-private key pair and shares its public key with every other group member. This initial exchange ensures all nodes have the necessary public keys to collaboratively compute a shared session key. After the public key exchange, each node independently computes the session key using sequential multiplication and exponentiation. Specifically, each node collects the public keys of the other group members, multiplies these keys together, and raises the product to the power of its own private key. This process results in a single session key consistently derived by all nodes, ensuring secure and uniform key establishment across the group. Following this, a designated group member generates the initialization value l for the hash chain and securely shares it with the group, similar to the P2P case.

The Group Diffie-Hellman protocol provides a scalable and efficient solution for secure group communication, enabling synchronized key generation across multiple devices without requiring individual key agreements for each pairwise connection. This approach simplifies key management and enhances security by minimizing the number of key exchange interactions needed in large groups.

5.3. Message Authentication

Upon successful initialization, each node has the security parameters required to authenticate messages: (i) a master key K_m , (ii) one or more session keys K_s , and (iii) one or more hash chains \mathcal{H} . A primary objective of ACRIC is to minimize runtime computational and transmission overhead, particularly during message processing, while still providing robust authentication and integrity protection. To accomplish this, ACRIC adds only a single OTP encryption to the standard protocol's runtime operations, implemented as a lightweight XOR with minimal overhead. By repurposing the CRC field for message integrity protection and authentication, ACRIC ensures full backward compatibility with existing protocols and supports both broadcast and P2P communication models. The authentication process is consistent across these scenarios, with the only exception being P2P protocols allowing broadcast messaging. For instance, the client-server protocol Modicon Communication Bus (Mod-Bus) enables clients to send broadcast messages [52]. This case is addressed separately in Section 5.3.1.

A core concept in ACRIC is replacing the default *InitVec* in CRC computation with a secret value known only to the involved parties. We propose using a truncated version of K_s . Given $K_s = [k_0^s || k_1^s || \cdots || k_n^s]$, where each k_i^s is an 8bit binary sequence, we define $InitVec = [k_0^s || k_1^s]$. However, using a secret InitVec alone does not provide sufficient security. An attacker could potentially deduce the InitVec by analyzing the CRC and the associated message payload. By brute-forcing all possible binary sequences for the *InitVec*, an attacker will find a match, allowing them to compute the CRC of a forged message that the receiver would accept. To prevent this, ACRIC protects the CRC by encrypting it with OTP using a value from the hash chain \mathcal{H} as the encryption key. Thanks to the perfect secrecy property of OTP [53], this encryption prevents attackers from gaining any advantage through analysis of the encrypted CRC.

Let $F_{CRC}(I, M)$ represent the standard CRC algorithm, which uses the initialization vector I and message M as inputs. In ACRIC, the secure CRC computation for authentication and integrity, termed *SecCRC*, for a given message M_i , is calculated as follows:

$$SecCRC_{i}(M_{i}) = CRC_{i} \oplus h_{i} = F_{CRC}(InitVec, M_{i}) \oplus h_{i},$$
(4)

where *i* denotes the message index, and $h_i \in \mathcal{H}$ is the *i*-th hash value. Figure 3 illustrates the secure SecCRC computation process just described.



Figure 3: ACRIC's cryptographic CRC computation for authentication and integrity protection. Secret *InitVec* and message M_i are taken in input from the standard CRC algorithm F_{CRC} (). Obtained CRC is OTP encrypted using values from the hash chain as secret keys, ensuring confidentiality of *InitVec*.

5.3.1. Message Authentication in P2P Model with Possible Broadcast Messages. In P2P network models with broadcast capabilities (e.g., Modbus protocol [52]), the session key K_s cannot be used to authenticate broadcast messages, as it is unique to each pair of entities. Therefore, a shared secret across all nodes is needed to secure broadcast communications. One option is to introduce an additional secret key K_b specifically for broadcast messages. Alternatively, the existing master key K_m could be used, as it is already shared among all network nodes. This approach eliminates the need for a separate broadcast key, reducing storage overhead. If this second approach is adopted, each node must be equipped with a monotonic counter C_b during installation, which will be used to generate the OTP key for SecCRC computation. We highlight that adding this counter at installation does not conflict with the aim of simplified deployment (Section 5.2), as this counter can be easily pre-configured without additional design requirements since it is common to all devices. Moreover, a counter requires much less storage than additional secret keys, minimizing overhead.

Once the most suitable approach is selected, the SecCRC calculation ensures message integrity and authenticity with minimal computational overhead. Following, we present the steps for the second approach proposed, as the first one is a straightforward application of Eq. (4) where K_b is used instead of K_s . Hence, if using the second approach, given $K_m = [k_0^m, k_1^m, \dots, k_N^m]$ where each k_i^m is a bytelong binary sequence, the SecCRC computation procedure follows these steps:

1) The CRC value is computed as:

$$CRC = F_{CRC}([k_0^m || k_1^m], M),$$

where M is the broadcast message and $InitVec = [k_0^m || k_1^m]$.

2) SecCRC is then computed as:

$$SecCRC = CRC \oplus h^m \mid h^m = H(K_m, C_b).$$

where $h^m = H(K_m, C_b)$ is the encryption key derived using the master key K_m and counter C_b .

3) C_b is incremented, preventing replay attacks.

This approach leverages the existing master key K_m , thereby avoiding the need for additional secret keys and minimizing memory usage while maintaining robust security. Incorporating the monotonic counter C_b provides an added layer of protection, ensuring that each broadcast message is uniquely authenticated.

6. Hash-Chain Management

In the ACRIC framework, hash values - and by extension, hash chains - are fundamental to security. These values serve as secret keys for OTP encryption, securing communications by preventing attackers from recovering the *InitVec* needed to compute the CRC. Managing these chains can be challenging for memory-constrained devices, particularly in large networks where multiple chains must be maintained. Efficient hash chain management is therefore essential, as it impacts computational and memory resources, balancing security requirements with available resources.

This section explores strategies for managing hash chains, examining their constraints, requirements, benefits, and limitations. This analysis provides a basis for choosing the most appropriate strategy based on the application context, communication model, protocol requirements, and specific constraints. Tables 2 and 3 summarize the advantages and drawbacks of various approaches to hash chain consumption, storage, and computation.

6.1. Hash Chain Consumption

Hash chain consumption refers to the methods for utilizing individual hash values within a chain. Based on the hash chain defined in Eq. (2) we identify two primary consumption strategies.

The first strategy is **backward consumption**, where hash values are used in reverse order, starting from the tail h_n and progressing back to the root h_0 . Due to the pre-image resistance property of hash functions (see Section 3.2), even if a particular hash h_i is exposed, it remains computationally infeasible to derive any prior values h_j for j < i. However, this approach requires the entire chain to be precomputed before any values can be used, increasing memory requirements. The second strategy is forward consumption, where hash values are consumed sequentially from the root h_0 toward the tail h_n . This approach eliminates the need for pre-computing the entire chain, allowing each value to be calculated in real time, thus reducing memory usage. However, forward consumption requires the inclusion of a secret key to ensure forward secrecy; without it, an attacker with access to h_i could compute all subsequent values h_i , $\forall j > i + 1$, posing a security risk. By incorporating a secret key in the hashing process, this risk is mitigated, as an attacker would be unable to compute subsequent hash values without full access to the hash function input.

6.2. Hash Chain Storage

We identify two main storage strategies that define how hash chains are managed across communicating devices.

The first strategy is **entity-based hash chain storage**, where each device maintains its own chain for authenticating its transmitted messages. This approach presents two key limitations: (*i*) it may require defining device identities, which some protocols (e.g. CAN-bus protocol [50]) do not inherently support; and (*ii*) receiving devices must keep track of the index of each used hash value for accurate verification. To manage this, either all devices must monitor transmissions from the source, or an additional index parameter must be included in the payload to synchronize receivers with the sender's current hash value. However, the latter solution reduces data throughput as such index has to be added to the message payload.

Memory analysis. Let N be the number of network nodes or, in a broadcast scenario, the number of group members. Memory requirements for each device are as follows:

- Backward consumption: Each device must store a full hash chain for itself and N − 1 individual hash values for other nodes.
- Forward consumption: Each device stores a total of N hash values, one for its own chain and N-1 for other nodes.

The second strategy is **pair-based hash chain storage**, where each pair of nodes, is assigned a unique hash chain. For broadcast communications using group keys, this becomes **group-based hash chain storage**, where the group collectively uses a single shared chain. Unlike the entity-based approach, this method eliminates the need for synchronization between sender and receiver.

Memory analysis. With N representing the number of network nodes or groups a node belongs to, memory requirements are:

- Backward consumption: Each node stores N-1 full hash chains for P2P communication, or N full hash chains in a broadcast setup.
- Forward consumption: Each node stores N − 1 individual hash values for P2P communications, or N single hash values in a broadcast model.

Table 2 shows that the *forward-consume pair-based* approach requires the least storage overhead, making it particularly suitable for legacy and resource-constrained devices.

6.3. Hash Chain Computation

The hash chain computation strategy plays a crucial role in determining system performance and security. We identify three main strategies: runtime, offline, and hybrid.

TABLE 2: Comparison of storage overhead between hash chain consumption strategies and associated storage approaches. x is the number of bits of a single hash value; n_hash is the number of hash values in a hash chain; N is the number of network nodes (P2P model), or the number of groups a node is part of (Broadcast model).

	Hash Chain Consumption	Storage Annroach	Saved Values	Storage Overhead
Approach Constraints		Storage Approach	Saveu values	(bits)
Backward Forward		Entity-based	 1 full own hash chain 	m + (m h a a h + N - 1)
	Compute and store entire chain in advance		• N-1 receivers' single hash values	$x * (n_nasn + N - 1)$
		Pair / Group-based	• P2P: N-1 full hash chains	• P2P: $(N - 1) * n_hash * x$
			• Broadcast: N full hash chains	• Broadcast: $N * n_hash * x$
		Entite based	• 1 single own hash value	N
	Secret key as part of input required	Enny-based	• N-1 receivers' single hash values	1v * 12
	Secret key as part of input required	Pair / Group-based	• P2P: N-1 single hash values	• P2P: $(N-1) * x$
			• Broadcast: N single hash values	• Broadcast: $N * x$

TABLE 3: Comparison of pros, cons, and possible hash chain consumption strategies between hash chain computation approaches.

Computation Approach	Pros (✔) & Cons (✗)	Chain consumption
Runtima	[✓] Minimum memory overhead	[✔] Forward
Кипите	[X] Introduces transmission delay	[X] Backward
Office a	[✔] No transmission delay	[✔] Forward
Ojjune	[X] Lager memory overhead	[✔] Backward
	[✔] No transmission delay	[1] Formond
Hybrid	[✔] Smaller memory overhead w.r.t. offline	
	[X] Larger memory overhead w.r.t. runtime	

Table 3 compares the advantages and disadvantages of each strategy and indicates which chain consumption methods are compatible with each approach.

In the **runtime computation** strategy, hash values are generated as needed during operation, ensuring freshness and reducing susceptibility to pre-computation attacks. This approach minimizes memory requirements, as only the current hash needs to be stored. However, it increases computational demands and may introduce communication latency due to the real-time cryptographic calculations required. The offline computation strategy involves pre-computing the entire hash chain before deployment, which minimizes realtime processing demands but requires significant memory to store the full chain. Finally, the hybrid strategy combines elements of both runtime and offline computation by precomputing and storing part of the chain, with the remainder calculated as needed. This approach balances the reduced runtime demands of offline computation with lower memory requirements, achieving a compromise between system efficiency and security.

7. Evaluation

In this section, we evaluate ACRIC. Section 7.1 assesses ACRIC's security guarantees against the security goals previously defined. Section 7.2 evaluates ACRIC's performance in terms of computational and transmission overhead.

7.1. Security Assessment

We first theoretically discuss ACRIC's security guarantees, then we present formal verification and brute-force resistance assessment to sustain our findings.

7.1.1. Initialization Procedure. The proposed initialization procedure relies on three key elements: (i) cryptographic hash functions, (ii) the Diffie-Hellman protocol, and (iii) OTP encryption. The overall security of the procedure is therefore determined by the weakest of these elements. OTP encryption provides perfect secrecy as long as each encryption key is used only once [53]. The cryptographic hash function ensures that it is computationally infeasible to predict h = H(K, A) without knowing the key K, or to retrieve K from observing A and h (see Section 3.2). Consequently, as long as the master key K_m remains confidential, the hash values preserve their security, ensuring message authenticity. The security of the Diffie-Hellman protocol is based on the difficulty of solving the discrete logarithm problem in polynomial time [51]. However, it is well-known that it is susceptible to MITM attacks if carried out without authentication [54]. To address this vulnerability, we incorporate hash values to authenticate exchanged messages. Since we already established the security of the hash values, we conclude that the Diffie-Hellman key agreement defined as in Section 5.2 is secure, and that the session key K_s remains confidential. As a result, the confidentiality of l is assured through OTP encryption, benefiting from perfect secrecy. It is essential to note that the secrecy of l relies on K_s never being reused as OTP key in future communications, a condition that is strictly maintained.

We formally verified ACRIC's security properties using the Scyther tool¹, which is designed for the automated formal verification of security protocols. Scyther assesses the confidentiality and integrity of protocols by modeling adversarial capabilities and systematically verifying the protocol's resilience against potential attacks. Our verification focused on evaluating the confidentiality of security parameters associated with initialization against external attackers. The results confirm that ACRIC's design preserves the secrecy of

^{1.} https://people.cispa.io/cas.cremers/scyther/

underlying parameters (see Appendix A for further details). For transparency and reproducibility, the source code used in this formal verification is publicly available in a GitHub repository² (anonymized for submission).

7.1.2. Authentication Procedure. By using a secret *InitVec* for CRC computation, followed by OTP encryption with hash values derived from a secure hash chain, ACRIC provides message integrity protection and authentication. Ensuring the **authentication** property means that any message authenticated with an incorrect *InitVec* or hash value will be rejected. Thus, for a given message M, we calculate the collision probability of obtaining the correct *SecCRC* with incorrect security parameters. Three possible cases arise:

- <u>Case 1</u>: Correct InitVec and incorrect hash value. The probability of achieving a SecCRC collision is zero. With the correct InitVec, the correct CRC is computed. However, applying XOR with an incorrect hash value cannot yield the correct SecCRC.
- <u>Case 2</u>: Incorrect InitVec and correct hash value. Here, the probability of an incorrect InitVec producing the correct CRC depends on the specific CRC algorithm used. Assuming the CRC behaves as a random function, each incorrect InitVec has a probability of 2⁻ⁿ of generating the correct CRC. This is equivalent to a random guess of SecCRC.
- <u>Case 3</u>: Both InitVec and hash are incorrect. In this case, a collision would require a combination of an incorrect CRC and hash value that, together, produce the correct SecCRC. With 2^n possible CRC values and 2^n possible hash values, there are 2^{2n} possible combinations. For a fixed SecCRC, only 2^n combinations yield that value, resulting in a collision probability of 2^{-n} , which, again, is the same as a random guess.

For integrity protection, ACRIC aims to prevent an attacker from modifying the message payload while preserving a valid CRC (*SecCRC*), which reduces to the CRC collision probability as shown in *Case 2*. For replay attack protection, two scenarios are possible: (*i*) If the message is replayed within the same session, it falls under *Case 1*, which has zero collision probability; (*ii*) if the message is replayed in a different session, it falls under either *Case 2* or *Case 3*, where the success probability is equivalent to a random guess. This analysis demonstrates that ACRIC meets all identified security goals, as the collision probability for incorrect parameters is equivalent to random guessing.

Despite ACRIC's theoretical security due to OTP encryption, brute-force attacks remain a practical threat if an adversary attempts CRC collisions. For instance, an attacker might intercept and block legitimate communications, sending forged messages with different CRC values until one succeeds. We analyze the resistance of ACRIC against bruteforce attacks based on the number of attempts needed for success, which depends on the bit length of the CRC. We tested CRC bit lengths of 8 and 16, simulating two specific attack scenarios:

- Random Forgery: The adversary randomly forges messages, guessing the associated authenticated CRC (*SecCRC*) until success.
- Informed Forgery: We assume a hash value of a message authenticated with ACRIC has been exposed. Using this, the attacker retrieves the *InitVec*, forges a message, computes a new CRC with this *InitVec*, and guesses the necessary hash value for OTP encryption.

In both scenarios, we recorded the number of attempts required to achieve a SecCRC match, with each experiment repeated 1000 times for each CRC length to obtain statistically significant success probability data as a function of attempts. The source code of the attack simulation is available in our GitHub repository³. Figure 4a compares the Cumulative Density Functions (CDFs) of attack success probability for the random forgery and informed forgery attacks with a 16-bit CRC, showing that knowledge of a single hash value provides no advantage to an attacker, supporting our claims regarding authentication security. Figure 4b compares the CDFs of attack success probability for the random forgery case across different CRC lengths. These values enable practitioners to estimate the average number of attack attempts and corresponding success probability, and thus the expected time required for a brute-force attack based on the specifications of the protocol under consideration.

We highlight that ACRIC's security relies on maintaining the secrecy of both the *InitVec* and the OTP encryption key. Compromising either component significantly weakens the protocol's security, underscoring the importance of safeguarding both elements within the ACRIC framework.

Authentication of broadcast messages in P2P. In this particular scenario, the authentication mechanism described in Section 5.3.1 effectively protects against external attackers, as only nodes with access to K_m can compute $h_i = H(K_m, C_b)$. This setup prevents external attackers from forging or replaying broadcast messages. However, if a legitimate network node is compromised, the security assurances change. The attacker would gain access to the cryptographic material needed to authenticate any broadcast message accurately. This vulnerability highlights a limitation inherent to systems that rely on a shared key among multiple devices. When a node is compromised, the attacker essentially becomes an insider with full authentication privileges. While ACRIC provides robust protection against external adversaries, it is less effective against insider threats. Mitigating such risks would require additional mechanisms, such as device-level tamper resistance or intrusion and anomaly detection systems. Although these measures could reduce the impact of compromised nodes, they also introduce complexity and computational overhead, which may be impractical in resource-constrained environments.

^{2.} https://anonymous.4open.science/r/ACRIC-7B70/README.md

^{3.} https://anonymous.4open.science/r/ACRIC-7B70/README.md



(a) Comparison between random forgery and informed forgery (b) Comparison of CDF attack success probabilities in random forgery attack between different CRC lengths.

Figure 4: Brute-force attack Cumulative Density Function (CDF) of success probability against number of attempts.

7.2. Performance Evaluation

We evaluated the time overhead introduced by ACRIC in a real industrial setup to assess its impact on transmission efficiency and initialization. This evaluation focused on two key metrics: (i) transmission overhead, measured as the additional loop time when ACRIC is active, and (ii) the time required to complete a single initialization procedure.

Experimental Setup. To implement a proof of concept, we integrated ACRIC into Modbus, the de facto communication protocol for ICS and SCADA systems. Modbus is commonly used in legacy and resource-constrained environments, making it a relevant choice for evaluating ACRIC's efficiency under realistic industrial conditions. Our experimental setup, shown in Figure 5, includes two commercially available industrial devices from CAREL equipped with an STM32F4xx microcontroller and an additional 16 MB of external DRAM. We implemented ACRIC authentication methodology into proprietary software using the emCrypt library ⁴ for cryptographic operations. This setup enables us to measure ACRIC's performance in a real-world industrial environment with industrial-grade hardware, providing results that accurately reflect the impact of ACRIC when integrated into existing software systems in the industry.

<u>Transmission Overhead Analysis</u>. To assess transmission overhead, we measured the loop time difference between the standard Modbus protocol and a secured version using ACRIC. The results show that ACRIC adds negligible overhead, with a loop time difference $\ll 1$ ms. This minimal increase confirms that ACRIC maintains real-time properties, keeping protocol performance within acceptable limits for industrial applications.

<u>Initialization Procedure Overhead</u>. We also evaluated the time required to complete a single ACRIC initialization procedure, measuring the total time to establish a secure communication channel. Experimental results indicate that the initialization process completes in under 1 second.

4. https://www.segger.com/products/security-iot/emcrypt/



Figure 5: Test-bed for ACRIC performance evaluation with commercially available industrial devices communicating via a serial line using the Modbus protocol with ACRIC.

With minimal transmission overhead, this initialization time demonstrates that ACRIC is well-suited for applications requiring secure communication without compromising operational efficiency.

7.3. Discussion

In this section, we discuss how ACRIC addresses and meets the identified challenges and design goals, respectively, demonstrating its suitability for real-world adoption.

Regarding the security goals — authentication, integrity protection, and replay resistance — Section 7.1 demonstrates that ACRIC fully meets these objectives. Both theoretical analysis and formal verification confirm that all security parameters (K_m, K_s, l, \mathcal{H}) remain confidential, ensuring the desired security properties.

For the operational goals, ACRIC effectively overcomes the identified limitations and challenges (SectionSection 2). Specifically, we designed an efficient key agreement procedure compatible with both P2P and broadcast communication models, minimizing deployment complexity. Additionally, by repurposing the CRC field to provide security with only a software update, we preserved data throughput and backward compatibility, reducing deployment costs and enabling interoperability between secure and non-secure devices. Finally, experimental results from real-world tests show that ACRIC is lightweight and preserves the system's real-time responsiveness, ensuring that security enhancements do not compromise operational efficiency.

In conclusion, the proposed authentication mechanism meets all defined design goals, addressing security and operational requirements. It enhances the protection of legacy systems by ensuring authentication, integrity, and replay protection while maintaining real-time response and backward compatibility. This comprehensive approach makes ACRIC a practical and secure solution, ready for adoption in industrial settings.

8. Related Works

Designing authentication mechanisms for legacy systems in resource-constrained environments presents several challenges that hinder the effective adoption of contemporary security solutions in real-world applications. Legacy systems are often characterized by limited processing power, constrained memory resources, and adherence to predefined communication protocols that lack inherent security features. Implementing robust authentication without compromising system performance or interoperability is a significant challenge in such environments.

Several proposals in the literature involve using asymmetric encryption, digital signatures, digital certificates, or the integration of protocols like Transport Layer Security (TLS) to provide security and authenticity [15], [55], [56], [57], [58], [59], [60]. While these methods offer strong security guarantees, they are unsuitable for resource-constrained environments as they rely on computationally intensive cryptographic operations. This often results in considerable transmission delays and significant memory and computational overhead, which resource-constrained systems cannot support. To address these limitations, many researchers have turned to MACs, particularly HMACs [60], [61], [62], [63], [64], [65], [66], [67], [68], [69], [70]. Hash functions are less computation-intensive than asymmetric cryptographic algorithms and can be efficiently implemented even on devices with limited resources. However, solutions adopting this approach often face significant limitations. Typically, the MAC value is appended to the original message, altering the standard frame format defined by the legacy protocol. This disrupts backward compatibility and interoperability since non-secured may not recognize or properly handle the modified frames. Alternatively, if the MAC is included within the payload, it is often associated with security parameters such as counters, nonces, or timestamps. This reduces the amount of application data that can be transmitted, thereby decreasing data throughput. Since high data throughput is often a critical requirement that influenced the original design and adoption of legacy protocols, any reduction can adversely affect system performance and efficiency. Another prevalent strategy is the BITW solution, wherein cryptographic operations are offloaded to external devices placed in front of legacy systems [28], [32], [46], [70], [71], [72], [73], [74]. These devices act as security gateways, encrypting and authenticating communications on behalf of the legacy system. While BITW solutions mitigate the resource limitations of legacy devices, they introduce additional hardware into the system architecture. This increases deployment complexity, raises costs, and potentially introduces new points of failure. Using covert channels to carry authentication information represents another alternative [47], [75]. This approach avoids modifying the original packet format, facilitating interoperability and maintaining compatibility with unsecured devices. However, implementing covert channels often necessitates additional hardware or modifications to existing hardware to support the embedding and extracting of hidden data.

A recently emerging approach involves enhancing the CRC field, traditionally used for error detection, to provide authentication and integrity protection by computing it cryptographically. Solutions following this strategy aim to secure the CRC computation by making the generator polynomial secret [36], [41], [76], [77], [78], [79]. However, selecting an appropriate polynomial that maintains the error detection capabilities of the standard CRC while serving as a secure cryptographic function is non-trivial. Identifying such polynomials is computationally intensive and time-consuming, rendering this approach less suitable for resource-constrained devices. To overcome these limitations, we propose a novel approach that modifies the InitVec used in the CRC computation instead of employing a secret generator polynomial. By manipulating the IV, we avoid exhaustive searches for suitable polynomials and retain the standard generator, ensuring that the error detection capabilities remain intact. Furthermore, encrypting the CRC with an OTP provides unconditional security. This prevents attackers from deducing the original CRC value of the InitVec used, thereby safeguarding the authentication mechanism against potential cryptographic attacks.

In summary, our method addresses the key challenges associated with securing communications for legacy systems in resource-constrained environments. We provide a lightweight, secure, and compatible authentication mechanism that preserves system performance and data throughput. This approach enables the effective integration of robust security measures into legacy systems without necessitating significant hardware modifications or compromising the operational characteristics that define these environments.

9. Conclusions

In this paper, we identify key challenges that prevent existing authentication mechanisms designed to retrofit security in legacy protocols from being deployed in real-world settings. To address these limitations, we developed ACRIC, a cryptographic CRC computation methodology that ensures authentication and integrity protection for legacy protocols. By leveraging the CRC field, ACRIC preserves the original frame structure, maintaining full backward compatibility and data throughput for legacy protocols. Additionally, ACRIC's protocol-agnostic design allows for implementation across diverse application scenarios and communication models, including point-to-point and broadcast models. Through theoretical analysis and formal security verification, we demonstrated ACRIC's resilience against external attackers. Furthermore, performance evaluations on a real-world testbed showed that ACRIC introduces negligible transmission overhead (\ll 1 ms). These results indicate that ACRIC is ready for adoption in industrial and other critical legacy systems, providing enhanced security with minimal impact on operational performance.

References

- R. Grubbs, J. Stoddard, S. Freeman, and R. Fisher, "Evolution and trends of industrial control system cyber incidents since 2017," *Journal of Critical Infrastructure Policy*, vol. 2, no. 2, pp. 45–79, 2021.
- [2] M. Lezzi, M. Lazoi, and A. Corallo, "Cybersecurity for industry 4.0 in the current literature: A reference framework," *Computers in Industry*, vol. 103, pp. 97–110, 2018. [Online]. Available: https: //www.sciencedirect.com/science/article/pii/S0166361518303658
- [3] G. Culot, F. Fattori, M. Podrecca, and M. Sartor, "Addressing industry 4.0 cybersecurity challenges," *IEEE Engineering Management Review*, vol. 47, no. 3, pp. 79–86, 2019.
- [4] F. Meneghello, M. Calore, D. Zucchetto, M. Polese, and A. Zanella, "Iot: Internet of threats? a survey of practical security vulnerabilities in real iot devices," *IEEE Internet of Things Journal*, vol. 6, no. 5, pp. 8182–8201, 2019.
- [5] A. Volkova, M. Niedermeier, R. Basmadjian, and H. de Meer, "Security challenges in control network protocols: A survey," *IEEE Communications Surveys & Tutorials*, vol. 21, no. 1, pp. 619–639, 2019.
- [6] Z. Drias, A. Serhrouchni, and O. Vogel, "Analysis of cyber security for industrial control systems," in 2015 International Conference on Cyber Security of Smart Cities, Industrial Control System and Communications (SSIC), 2015, pp. 1–8.
- [7] W. Knowles, D. Prince, D. Hutchison, J. F. P. Disso, and K. Jones, "A survey of cyber security management in industrial control systems," *International Journal of Critical Infrastructure Protection*, vol. 9, pp. 52–80, 2015. [Online]. Available: https: //www.sciencedirect.com/science/article/pii/S1874548215000207
- [8] C.-W. Lin and A. Sangiovanni-Vincentelli, "Cyber-security for the controller area network (can) communication protocol," in 2012 International Conference on Cyber Security. IEEE, 2012, pp. 1–7.
- [9] M. Conti, D. Donadel, and F. Turrin, "A survey on industrial control system testbeds and datasets for security research," *IEEE Communications Surveys & Tutorials*, vol. 23, no. 4, pp. 2248–2294, 2021.
- [10] R. Langner, "Stuxnet: Dissecting a cyberwarfare weapon," *IEEE Security & Privacy*, vol. 9, no. 3, pp. 49–51, 2011.
- [11] A. Costin, A. Francillon *et al.*, "Ghost in the air (traffic): On insecurity of ads-b protocol and practical attacks on ads-b devices," *black hat* USA, vol. 1, pp. 1–12, 2012.
- [12] D. U. Case, "Analysis of the cyber attack on the ukrainian power grid," *Electricity information sharing and analysis center (E-ISAC)*, vol. 388, no. 1-29, p. 3, 2016.
- [13] D. Formby, S. Durbha, and R. Beyah, "Out of control: Ransomware for industrial control systems," in *RSA conference*, vol. 4, 2017, p. 8.
- [14] C. Miller and C. Valasek, "Remote exploitation of an unaltered passenger vehicle," vol. 2015, no. S 91, 2015.
- [15] Modbus.com, "Modbus/tcp security," July 2021. [Online]. Available: https://www.modbus.org/specs.php

- [16] S. Lehnhoff, S. Rohjans, M. Uslar, and W. Mahnke, "Opc unified architecture: A service-oriented architecture for smart grids," in 2012 First International Workshop on Software Engineering Challenges for the Smart Grid (SE-SmartGrids), 2012, pp. 1–7.
- [17] M. Serror, S. Hack, M. Henze, M. Schuba, and K. Wehrle, "Challenges and opportunities in securing the industrial internet of things," *IEEE Transactions on Industrial Informatics*, vol. 17, no. 5, pp. 2985– 2996, 2021.
- [18] E. Wagner, N. Rothaug, K. Wolsing, L. Bader, K. Wehrle, and M. Henze, "Retrofitting integrity protection into unused header fields of legacy industrial protocols," in 2023 IEEE 48th Conference on Local Computer Networks (LCN), 2023, pp. 1–9.
- [19] P. Carsten, T. R. Andel, M. Yampolskiy, and J. T. McDonald, "Invehicle networks: Attacks, vulnerabilities, and proposed solutions," in *Proceedings of the 10th Annual Cyber and Information Security Research Conference*, ser. CISR '15. New York, NY, USA: Association for Computing Machinery, 2015. [Online]. Available: https://doi.org/10.1145/2746266.2746267
- [20] D. Bhamare, M. Zolanvari, A. Erbad, R. Jain, K. Khan, and N. Meskin, "Cybersecurity for industrial control systems: A survey," *Computers & Security*, vol. 89, p. 101677, 2020. [Online]. Available: https://www.sciencedirect.com/science/article/ pii/S0167404819302172
- [21] E. Aliwa, O. Rana, C. Perera, and P. Burnap, "Cyberattacks and countermeasures for in-vehicle networks," ACM Comput. Surv., vol. 54, no. 1, mar 2021.
- [22] A. Lotto, F. Marchiori, A. Brighente, and M. Conti, "A survey and comparative analysis of security properties of can authentication protocols," *IEEE Communications Surveys & Tutorials*, 2024.
- [23] N. Nowdehi, A. Lautenbach, and T. Olovsson, "In-vehicle can message authentication: An evaluation based on industrial criteria," in 2017 IEEE 86th Vehicular Technology Conference (VTC-Fall). IEEE, 2017, pp. 1–7.
- [24] D. Dzung, M. Naedele, T. Von Hoff, and M. Crevatin, "Security for industrial communication systems," *Proceedings of the IEEE*, vol. 93, no. 6, pp. 1152–1177, 2005.
- [25] M. D. Pesé, J. W. Schauer, J. Li, and K. G. Shin, "S2-can: Sufficiently secure controller area network," in *Annual Computer Security Applications Conference*, 2021, pp. 425–438.
- [26] A. Van Herrewege, D. Singelee, and I. Verbauwhede, "Canauth-a simple, backward compatible broadcast authentication protocol for can bus," in *ECRYPT Workshop on Lightweight Cryptography*, vol. 2011, 2011, p. 20.
- [27] P. Huitsing, R. Chandia, M. Papa, and S. Shenoi, "Attack taxonomies for the modbus protocols," *International Journal* of Critical Infrastructure Protection, vol. 1, pp. 37–44, 2008. [Online]. Available: https://www.sciencedirect.com/science/article/ pii/S187454820800005X
- [28] I. N. Fovino, A. Carcano, M. Masera, and A. Trombetta, "Design and implementation of a secure modbus protocol," in *Critical Infrastructure Protection III*, C. Palmer and S. Shenoi, Eds. Berlin, Heidelberg: Springer Berlin Heidelberg, 2009, pp. 83–96.
- [29] R. Buttigieg, M. Farrugia, and C. Meli, "Security issues in controller area networks in automobiles," in 2017 18th International Conference on Sciences and Techniques of Automatic Control and Computer Engineering (STA). IEEE, 2017, pp. 93–98.
- [30] K. Stouffer, J. Falco, K. Scarfone *et al.*, "Guide to industrial control systems (ics) security," *NIST special publication*, vol. 800, no. 82, pp. 16–16, 2011.
- [31] R. L. Krutz, Securing SCADA systems. John Wiley & Sons, 2015.
- [32] A. K. Wright, J. A. Kinast, and J. McCarty, "Low-latency cryptographic protection for scada communications," in *Applied Cryptography and Network Security*, M. Jakobsson, M. Yung, and J. Zhou, Eds. Berlin, Heidelberg: Springer Berlin Heidelberg, 2004, pp. 263–277.

- [33] J. H. Castellanos, D. Antonioli, N. O. Tippenhauer, and M. Ochoa, "Legacy-compliant data authentication for industrial control system traffic," in *Applied Cryptography and Network Security*, D. Gollmann, A. Miyaji, and H. Kikuchi, Eds. Cham: Springer International Publishing, 2017, pp. 665–685.
- [34] T. Cherifi, W. Cherifi, K. Challal, L. Abbad, M. Bouterfas, and A. Gramez, "Mubus: A new secure industrial communication protocol based on modbus and ubus protocols," in 2021 International Conference on Artificial Intelligence for Cyber Security Systems and Privacy (AI-CSP), 2021, pp. 1–6.
- [35] T. Ramabadran and S. Gaitonde, "A tutorial on crc computations," *IEEE Micro*, vol. 8, no. 4, pp. 62–75, 1988.
- [36] P. Koopman and T. Chakravarty, "Cyclic redundancy code (crc) polynomial selection for embedded networks," in *International Conference on Dependable Systems and Networks*, 2004, 2004, pp. 145– 154.
- [37] R. Sobti and G. Geetha, "Cryptographic hash functions: a review," *International Journal of Computer Science Issues (IJCSI)*, vol. 9, no. 2, p. 461, 2012.
- [38] J. M. Turner, "The keyed-hash message authentication code (hmac)," *Federal Information Processing Standards Publication*, vol. 198, no. 1, pp. 1–13, 2008.
- [39] W. Penard and T. van Werkhoven, "On the secure hash algorithm family," *Cryptography in context*, pp. 1–18, 2008.
- [40] Y.-C. Hu, M. Jakobsson, and A. Perrig, "Efficient constructions for one-way hash chains," in *Applied Cryptography and Network Security*, J. Ioannidis, A. Keromytis, and M. Yung, Eds. Berlin, Heidelberg: Springer Berlin Heidelberg, 2005, pp. 423–441.
- [41] E. Dubrova, M. Näslund, G. Selander, and F. Lindqvist, "Lightweight message authentication for constrained devices," in *Proceedings of the 11th ACM Conference on Security & Privacy in Wireless and Mobile Networks*, ser. WiSec '18. New York, NY, USA: Association for Computing Machinery, 2018, p. 196–201. [Online]. Available: https://doi.org/10.1145/3212480.3212482
- [42] J. Luswata, P. Zavarsky, B. Swar, and D. Zvabva, "Analysis of scada security using penetration testing: A case study on modbus tcp protocol," in 2018 29th Biennial Symposium on Communications (BSC), 2018, pp. 1–5.
- [43] C. Wang, L. Fang, and Y. Dai, "A simulation environment for scada security analysis and assessment," in 2010 International Conference on Measuring Technology and Mechatronics Automation, vol. 1, 2010, pp. 342–347.
- [44] D. Upadhyay and S. Sampalli, "Scada (supervisory control and data acquisition) systems: Vulnerability assessment and security recommendations," *Computers & Security*, vol. 89, p. 101666, 2020. [Online]. Available: https://www.sciencedirect.com/science/ article/pii/S0167404819302068
- [45] E. Wagner, N. Rothaug, K. Wolsing, L. Bader, K. Wehrle, and M. Henze, "Retrofitting integrity protection into unused header fields of legacy industrial protocols," in 2023 IEEE 48th Conference on Local Computer Networks (LCN), 2023, pp. 1–9.
- [46] F. Katulić, D. Sumina, S. Groš, and I. Erceg, "Protecting modbus/tcpbased industrial automation and control systems using message authentication codes," *IEEE Access*, vol. 11, pp. 47 007–47 023, 2023.
- [47] G. Bernieri, S. Cecconello, M. Conti, and G. Lain, "Tambus: A novel authentication method through covert channels for securing industrial networks," *Computer Networks*, vol. 183, p. 107583, 2020. [Online]. Available: https://www.sciencedirect.com/science/ article/pii/S1389128620312214
- [48] D. Dolev and A. Yao, "On the security of public key protocols," *IEEE Transactions on Information Theory*, vol. 29, no. 2, pp. 198–208, 1983.
- [49] F. A. Petitcolas, "Kerckhoffs' principle," in *Encyclopedia of Cryptography, Security and Privacy*. Springer, 2023, pp. 1–2.

- [50] J. Cook and J. Freudenberg, "Controller area network (can)," in *EECS*, vol. 461, 2007, pp. 1–5.
- [51] W. Diffie and M. E. Hellman, New Directions in Cryptography, 1st ed. New York, NY, USA: Association for Computing Machinery, 2022, p. 365–390. [Online]. Available: https://doi.org/10. 1145/3549993.3550007
- [52] Modbus.com, "Modbus application protocol specification v1.1b3," April 2012. [Online]. Available: https://www.modbus.org/specs.php
- [53] C. E. Shannon, "Communication theory of secrecy systems," *The Bell System Technical Journal*, vol. 28, no. 4, pp. 656–715, 1949.
- [54] A. J. Menezes, P. C. Van Oorschot, and S. A. Vanstone, *Handbook of applied cryptography*. CRC press, 2018.
- [55] M. K. Ferst, H. F. M. de Figueiredo, G. Denardin, and J. Lopes, "Implementation of secure communication with modbus and transport layer security protocols," in 2018 13th IEEE International Conference on Industry Applications (INDUSCON), 2018, pp. 155–162.
- [56] V. M. Rao, R. Kalluri, and G. G. Prasad, "Hardening of the modbus protocol," *Power Research-A Journal of CPRI*, pp. 423–432, 2017.
- [57] A. Shahzad, M. Lee, Y.-K. Lee, S. Kim, N. Xiong, J.-Y. Choi, and Y. Cho, "Real time modbus transmissions and cryptography security designs and enhancements of protocol sensitive information," *Symmetry*, vol. 7, no. 3, pp. 1176–1210, 2015. [Online]. Available: https://www.mdpi.com/2073-8994/7/3/1176
- [58] E. O. Marasco and F. Quaglia, "Authentican: a protocol for improved security over can," in 2020 Fourth World Conference on Smart Trends in Systems, Security and Sustainability (WorldS4). IEEE, 2020, pp. 533–538.
- [59] A. Yang, X. Tan, J. Baek, and D. S. Wong, "A new ads-b authentication framework based on efficient hierarchical identity-based signature with batch verification," *IEEE Transactions on Services Computing*, vol. 10, no. 2, pp. 165–175, 2017.
- [60] W.-J. Pan, Z.-L. Feng, and Y. Wang, "Ads-b data authentication based on ecc and x. 509 certificate," *Journal of Electronic Science and Technology*, vol. 10, no. 1, pp. 51–55, 2012.
- [61] G. Hayes and K. El-Khatib, "Securing modbus transactions using hash-based message authentication codes and stream transmission control protocol," in 2013 Third International Conference on Communications and Information Technology (ICCIT), 2013, pp. 179–184.
- [62] Z. Liu, T. Liang, W. Wang, R. Sun, and S. Li, "Design and implementation of a lightweight security-enhanced scheme for modbus tcp protocol," *Security and Communication Networks*, vol. 2023, no. 1, p. 5486566, 2023. [Online]. Available: https: //onlinelibrary.wiley.com/doi/abs/10.1155/2023/5486566
- [63] E. Pricop, J. Fattahi, N. Parashiv, F. Zamfir, and E. Ghayoula, "Method for authentication of sensors connected on modbus tcp," in 2017 4th International Conference on Control, Decision and Information Technologies (CoDIT), 2017, pp. 0679–0683.
- [64] F. A. Stancu, R. V. Rughiniş, C. D. Trancă, and I. L. Popescu, "Trusted industrial modbus firewall for critical infrastructure systems," in 2020 19th RoEduNet Conference: Networking in Education and Research (RoEduNet), 2020, pp. 1–5.
- [65] L. Xuan and L. Yongzhong, "Research and implementation of modbus tcp security enhancement protocol," *Journal of Physics: Conference Series*, vol. 1213, no. 5, p. 052058, jun 2019. [Online]. Available: https://dx.doi.org/10.1088/1742-6596/1213/5/052058
- [66] F. Yi, L. Zhang, S. Yang, and D. Zhao, "A security-enhanced modbus tcp protocol and authorized access mechanism," in 2021 IEEE Sixth International Conference on Data Science in Cyberspace (DSC), 2021, pp. 61–67.
- [67] S. Nürnberger and C. Rossow, "- vatican- vetted, authenticated can bus," in *Cryptographic Hardware and Embedded Systems - CHES* 2016, B. Gierlichs and A. Y. Poschmann, Eds. Springer Berlin Heidelberg, 2016, pp. 106–124.

- [68] B. Groza, S. Murvay, A. V. Herrewege, and I. Verbauwhede, "Libracan: Lightweight broadcast authentication for controller area networks," vol. 16, no. 3. Association for Computing Machinery, apr 2017.
- [69] J. Van Bulck, J. T. Mühlberg, and F. Piessens, "Vulcan: Efficient component authentication and software isolation for automotive control networks," in *Proceedings of the 33rd Annual Computer Security Applications Conference*, ser. ACSAC '17. Association for Computing Machinery, 2017, p. 225–237.
- [70] A. Esfahani, G. Mantas, R. Matischek, F. B. Saghezchi, J. Rodriguez, A. Bicaku, S. Maksuti, M. G. Tauber, C. Schmittner, and J. Bastos, "A lightweight authentication mechanism for m2m communications in industrial iot environment," *IEEE Internet of Things Journal*, vol. 6, no. 1, pp. 288–296, 2019.
- [71] Y.-C. Lin, C.-F. Lin, and K.-H. Chen, "Security enhancement of industrial modbus message transmission with proxy approach," in 2021 IEEE 3rd Eurasia Conference on IOT, Communication and Engineering (ECICE), 2021, pp. 90–95.
- [72] L. Rajesh and P. Satyanarayana, "Design and development of secure data transfer modules in industrial control systems," *Wireless Personal Communications*, vol. 132, no. 4, pp. 2667–2692, 2023.
- [73] A. Tidrea, A. Korodi, and I. Silea, "Cryptographic considerations for automation and scada systems using trusted platform modules," *Sensors*, vol. 19, no. 19, 2019. [Online]. Available: https: //www.mdpi.com/1424-8220/19/19/4191
- [74] P. P. Tsang and S. W. Smith, "Yasir: A low-latency, high-integrity security retrofit for legacy scada systems," in *Proceedings of The Ifip Tc 11 23rd International Information Security Conference*, S. Jajodia, P. Samarati, and S. Cimato, Eds. Boston, MA: Springer US, 2008, pp. 445–459.
- [75] X. Ying, G. Bernieri, M. Conti, and R. Poovendran, "Tacan: transmitter authentication through covert channels in controller area networks," in *Proceedings of the 10th ACM/IEEE International Conference on Cyber-Physical Systems*, ser. ICCPS '19. New York, NY, USA: Association for Computing Machinery, 2019, p. 23–34. [Online]. Available: https://doi.org/10.1145/3302509.3313783
- [76] N. Naher, Asaduzzaman, and M. M. Haque, "Authentication of diffiehellman protocol against man-in-the-middle attack using cryptographically secure crc," in *Proceedings of International Ethical Hacking Conference 2018*, M. Chakraborty, S. Chakrabarti, V. E. Balas, and J. K. Mandal, Eds. Singapore: Springer Singapore, 2019, pp. 139– 150.
- [77] S. Wang, K. Huang, K. Ma, X. Xu, and X. Hu, "A lightweight encryption and message authentication framework for wireless communication," *IET Communications*, vol. 17, no. 3, pp. 265–278, 2023.
- [78] E. Dubrova, M. Näslund, and G. Selander, "Crc-based message authentication for 5g mobile technology," in 2015 IEEE Trustcom/BigDataSE/ISPA, vol. 1, 2015, pp. 1186–1191.
- [79] E. Dubrova, M. Näslund, G. Selander, and F. Lindqvist, "Message authentication based on cryptographically secure crc without polynomial irreducibility test," *Cryptography and communications*, vol. 10, pp. 383–399, 2018.

Appendix A. ACRIC Formal Verification

To assess ACRIC security properties formally, we tested with Scyther tool the confidentiality of the cryptographic parameters involved during the initialization and authentication procedures when implementing ACRIC framework. The mapping between the security parameters and the terms used in Scyther is detailed in Table 4.

Figure 6 shows the results of formal verification for the initialization procedure at both transmitter (TX) and receiver

TABLE 4: Explanation of	of Scyther	variables	meaning.
-------------------------	------------	-----------	----------

Scyther variable	Meaning
Р	Large prime number p
G	Generator g for \mathcal{Z}_p^*
Km	Pre-shared master key K_m
a	Transmitter's private key for Diffie-Hellman
b	Receiver's private key for Diffie-Hellman
A = EXP(a, G, P)	Transmitter's public key for Diffie-Hellman
B = EXP(b, G, P)	Receiver's Public key for Diffie-Hellman
EXP(B, a, P)	
EXP(A, b, P)	Shared session key K_s
Ks	
1	Random value l for hash chain initialization
L	Encrypted value L of l with K_s
RESP(XOR(L, EXP(A, b, P)))	Receiver's response value $l + 1$
InitVec(Ks)	Initialization vector InitVec
SHA1(l, Ks)	First element h_0 of hash chain \mathcal{H}
SHA1(SHA1(l, Ks))	Hash value h_i of the hash chain \mathcal{H}

(RX) side. Figure 7 shows the results for the verification for the authentication procedure at transmitter (TX) side.

			Scyther results : verify		- ×
Claim				Status	Comments
SecModbus	тх	SecModbus,TX1	Secret Ks	Ok	No attacks within bound
		SecModbus,TX2	Secret l	Ok	No attacks within bound
		SecModbus,TX3	Secret InitVec(Ks)	Ok	No attacks within bound
		SecModbus,TX4	Secret SHA1(l,Ks)	Ok	No attacks within bound
		SecModbus,TX5	Secret SHA1(SHA1(l,Ks))	Ok	No attacks within bound
		SecModbus,TX6	Secret SHA1(SHA1(SHA1(l,Ks)))	Ok	No attacks within bound
		SecModbus,TX7	Secret SHA1(SHA1(SHA1(SHA1(I,Ks))))	Ok	No attacks within bound
Done.		SecModbus.TX8	Secret Fcrc(InitVec(Ks).Rea1)	Ok	No attacks within bound

Figure 6: Results of formal verification of CRAC's initialization procedure with Scyther tool. Results show that all the security parameters involved during initialization remain confidential.

		Scyther results : verify				- ×
	Claim				Status	Comments
	InitProcedure	тх	InitProcedure,TX1	Secret Km	Ok	No attacks within bound
			InitProcedure,TX2	Secret a	Ok	No attacks within bound
			InitProcedure,TX3	Secret EXP(B,a,P)	Ok	No attacks within bound
			InitProcedure,TX4	Secret l	Ok	No attacks within bound
		RX	InitProcedure,RX1	Secret Km	Ok	No attacks within bound
			InitProcedure,RX2	Secret b	Ok	No attacks within bound
			InitProcedure,RX3	Secret EXP(A,b,P)	Ok	No attacks within bound
Deer		InitProcedure.RX4	Secret RESP(XOR(L.EXP(A.b.P)))	Ok	No attacks within bound	
	Done.					

Figure 7: Results of formal verification of CRAC's authentication procedure with Scyther tool. Results show that all the security parameters involved during authentication remain confidential.

Appendix B. ACRIC's Performance Evaluation

We evaluated ACRIC's performance in a real-life testbed, focusing on assessing the computational overhead of *SecCRC* computation and the latency introduced by system initialization. Figures 8 and 9 display console output during a debug session, showing print timestamps that allow us to estimate overhead by examining the time differences between correlated prints. The system's time resolution is on the order of milliseconds.

Figure 8 shows debug output when the experiment is run without ACRIC's security enabled, while Figure 9 shows output with ACRIC active. Comparing the timestamps before and after the CRC computation (red box) reveals no significant difference, indicating that ACRIC's authentication procedure introduces an overhead of less than 1 ms. In Figure 9, we also highlight the time required for a single initialization setup (blue box), which completes in under 1 second.

00>	[1.032]	VM	Kernel 1: running
00>	[1.155]	ISAI	XML <ixml:isai> unhandled section/tag <cfield>, skipping</cfield></ixml:isai>
00>	[1.242]	MODBUS	ModbCliRTU_2: Device address 1 (idx 0) enabled
00>	Ĩ.	1.242]	MODBUS	ModbCliRTU_2: ************ MODBUS STANDARD VERSION *********
00>	ĺ.	1.243]	ISAI	No logs found
00>	[1.243]	ISAI	No alarms found
00>	[1.243]	ALMMNG	Not running
00>	[1.243]	TERA	Failed to register alarm callback
00>	[1.243]	ISAI	Supervision started (2 items)
00>	[1.243]	VM	NOTE: 0xa:0x0 Resource Start Report.
00>	[]	1,2631	EASYE	Starting UI
00>	[1.342]	MODBUS	ModbCliRTU_2: BEGIN CRC COMPUTATION
00>	[1.342]	MODBUS	ModbCliRTU_2: END CRC COMPUTATION
00>	[]	1.357]	MODBUS	ModbCliRTU_2: BEGIN CRC check
<u> 00></u>	[1.357]	MODBUS	ModbCliRTU_2: END CRC check
00>	[1.357]	MODBUS	ModbCliRTU_2: Device address 1 online
00>	[2.025]	MODBUS	ModbCliRTU_2: BEGIN CRC COMPUTATION
00>	[2.025]	MODBUS	ModbCliRTU_2: END CRC COMPUTATION
00>	[2.040]	MODBUS	ModbCliRTU_2: BEGIN CRC check
00>	[2.040]	MODBUS	ModbCliRTU_2: END CRC check
00>	[2.057]	MODBUS	ModbCliRTU_2: BEGIN CRC COMPUTATION
00>	[2.057]	MODBUS	ModbCliRTU_2: END CRC COMPUTATION
00>	[2.072]	MODBUS	ModbCliRTU_2: BEGIN CRC check
00>	[2.072]	MODBUS	ModbCliRTU_2: END CRC check
00>	[2.089]	MODBUS	ModbCliRTU_2: BEGIN CRC COMPUTATION
00>	[2.089]	MODBUS	ModbCliRTU_2: END CRC COMPUTATION
00>	[2.104]	MODBUS	ModbCliRTU_2: BEGIN CRC check
00>	[2.104]	MODBUS	ModbCliRTU_2: END CRC check
00>	[2.121]	MODBUS	ModbCliRTU_2: BEGIN CRC COMPUTATION
00>	[2.121]	MODBUS	ModbCliRTU_2: END CRC COMPUTATION
00>	[2.136]	MODBUS	ModbCliRTU_2: BEGIN CRC check
00>	[2.136]	MODBUS	ModbCliRTU_2: END CRC check
00>	[2.153]	MODBUS	ModbCliRTU_2: BEGIN CRC COMPUTATION
00>	[2.153]	MODBUS	ModbCliRTU_2: END CRC COMPUTATION
00>	[2.168]	MODBUS	ModbCliRTU_2: BEGIN CRC check
00>	[2.168]	MODBUS	ModbCliRTU_2: END CRC check
00>	[2.185]	MODBUS	ModbCliRTU_2: BEGIN CRC COMPUTATION
00>	[2.185]	MODBUS	ModbCliRTU_2: END CRC COMPUTATION

1.032] VM Kernel 1: running
1.155] ISAI VM (cisualisatic unhandled section/tag cefields, skipping
1.242] MOBBUS ModbCliRTU_2: Device address 1 (idx 0) enabled
1.242] MOBBUS ModbCliRTU_2: WITH COMPUS SECURE VERSION WITH CHYPTOGRAPHIC CRC
1.242] MOBBUS ModbCliRTU_2: WITH Computed SecURE VERSION WITH CHYPTOGRAPHIC CRC
1.244] ISAI No clarms found
1.244] ISAI No clarms found
1.244] ISAI Supervision started (2 items)
1.244] ISAI Supervision started (2 items)
1.244] ISAI Supervision started (2 items)
1.244] VMC NOT: 0xai0x0 Resource Start Report.
1.243] AUMONE ModbCliRTU_2: BEGIN CRC COMPUTATION
1.343 MOBBUS ModbCliRTU_2: BEGIN CRC COMPUTATION
1.343 MOBBUS ModbCliRTU_2: BEGIN CRC COMPUTATION
1.3571 MOBBUS ModbCliRTU_2: BEGIN CRC COMPUTATION
1.371 MOBBUS ModbCliRTU_2: BEGIN CRC COMPUTATION
2.0691 MOBBUS ModbCliRTU_2: BEGIN CRC COMPUTATION
2.061 MOBBUS ModbCliRTU_2: BEGIN CRC COMPUTATION
2.0621 MOBBUS ModbCliRTU_2: BEGIN CRC COMPUTATION
2.0631 MOBBUS ModbCliRTU_2: BEGIN CRC COMPUTATION
2.0641 MOBBUS ModbCliRTU_2: BEGIN CRC COMPUTATION
2.0651 MOBBUS ModbClIRTU_2: BEGIN CRC COMPUTATION
2.0671 MOBBUS ModbClIRTU_2: BEGIN CRC COMPUTATION
2.0621 MOBBUS ModbClIRTU_2: BEGIN CRC COMPUTATION
2.0631 MOBBUS ModbCLIRTU_2: BEGIN CRC C

Figure 9: Caption

Figure 8: Caption