arXiv:quant-ph/0204005v1 1 Apr 2002

Adaptive homodyne measurement of optical phase

Michael A. Armen, John K. Au, John K. Stockton, Andrew C. Doherty, and Hideo Mabuchi

Norman Bridge Laboratory of Physics 12-33, California Institute of Technology, Pasadena, CA 91125

(Dated: March 31, 2002)

We present an experimental demonstration of the power of real-time feedback in quantum metrology, confirming a theoretical prediction by Wiseman [1] regarding the superior performance of an adaptive homodyne technique for single-shot measurement of optical phase. For phase measurements performed on weak coherent states with no prior knowledge of the signal phase, we show that the variance of adaptive homodyne estimation approaches closer to the fundamental quantum uncertainty limit than any previously demonstrated technique. Our results underscore the importance of real-time feedback for reaching quantum performance limits in coherent telecommunication, precision measurement and information processing.

Quantum mechanics complicates metrology in two complementary ways. First it forces us to accept the existence of intrinsic uncertainty in the value of observables such as the position, momentum, and phase of an oscillator. Such quantum uncertainty exists even when the state of the system being measured has been prepared in a technically flawless way. Even the vacuum state of a single-mode optical field, for example, exhibits 'zeropoint' fluctuations in the amplitudes of its electric and magnetic components. The same is true of the optical coherent states representative of the output of an ideal laser. These uncertainties limit the sensitivity of ubiquitous measurement techniques such as laser interferometry. Squeezed states of light are challenging to produce but have reduced uncertainties that can in principal be exploited for improved sensitivity in optical metrology [2]. To date, however, the achievable performance gains have not been sufficient to motivate their use in practical applications.

Quantum mechanics presents a second major obstacle to precision measurement by making it generally quite difficult to realize ideal measurement procedures, whose inherent inaccuracy is small enough to reveal the intrinsic uncertainty limits associated with quantum states. Let us refer to such ideal measurements as being Uncertainty-Limited (UL). Clearly, the implementation of UL measurement procedures is essential for any application that seeks to take advantage of exotic quantum states with reduced intrinsic uncertainties. In connection with squeezed states of light, measurements of optical quadrature amplitudes do constitute an important class of UL measurements that actually can be implemented in practice (via homodyne detection). But this is an unusual case as UL measurement schemes have not previously been demonstrated even for closely related observables such as optical phase, despite intense historical interest in their quantum properties [3, 4]. This shortcoming is not merely one of achievable signal-to-noise ratio in realistic experiments – there has yet to be any demonstration of a measurement procedure that is capable even in principle of achieving UL estimation of true optical phase (as opposed to phase-quadrature amplitude), for

coherent or any other pure states of an optical field.

In this article we present an experimental demonstration of the surprising efficacy of *real-time feedback* in the development of UL measurement procedures. We do this in the context of measuring the optical phases of weak pulses of light, following a theoretical proposal by Wiseman [1]. This metrological task can be motivated by a coherent optical communication scenario in which information is encoded in the phase of laser pulses that must travel long distances between the sender and receiver. In such a context the receiver is likely to be faced with decoding information carried by optical wave-packets whose quantum states correspond to coherent states with low mean photon number (as a result of optical attenuation). If the sender is encoding information in an efficient manner, the variation of phase from one optical wave-packet to the next should be uniformly distributed over the entire interval from zero to 2π . Hence, the receiver would ideally like to implement a *single-shot* UL measurement procedure for estimating the phase of each individual pulse [5]. The variance of such optimal phase estimates should be limited only by the intrinsic quantum uncertainty associated with optical coherent states of the given mean photon number.

There is no known experimental procedure to accomplish this goal exactly. Prior to Wiseman's proposal [1] it had been widely believed [6] that the best feasible strategy for single-shot phase decoding should be heterodyne detection, which for coherent signal states can in principle achieve a measurement variance that is only a factor of two greater than the intrinsic uncertainty limit [7]. In what follows we will thus consider heterodyne phase estimation as the benchmark we need to surpass. It is important to compare the current measurement scenario with what arises in applications such as the implementation of optical frequency standards (optical clocks), where optical phases must also be measured optimally but where there is a guarantee that the phases vary only over a range much less than $\pi/2$. In such cases, as mentioned above, essentially UL measurement can be achieved by employing fixed-quadrature homodyne detection with a local oscillator whose phase is held at an offset of $\pi/2$

radians from the expected signal phase. Real-time feedback can thus be seen as a key ingredient in formulating an UL scheme for measurement scenarios in which we have no prior knowledge of the signal phase – feedback enables protocols in which the local oscillator phase is adapted, in real time, to the phase of each individual signal pulse [8]. As each optical pulse has some spatiotemporal extent, the measurement signal generated by the leading edge of a given pulse can be used to form a preliminary estimate of its phase, which is used promptly to adjust the local oscillator settings to be optimal for that pulse. (Note that this essentially amounts to the implementation of a quantum-noise limited phase-lock loop; the scheme relies on lock acquisition from the first one or two photons of signal in each pulse.) Detailed theoretical analyses of such schemes by Wiseman and coworkers have led to the striking realization that, despite extremely low signal-to-noise ratio in the feedback loop, adaptive homodyne measurement can be essentially UL for optical pulses with mean photon number of order ten (or greater), and benefits of real-time adaptation should still be evident for mean photon numbers ~ 1 . We turn now to our experimental test of these predictions.

The data plotted in Fig. 1A demonstrate the superiority of an adaptive homodyne measurement procedure ('adaptive') to the benchmark heterodyne measurement procedure ('heterodyne') for making single-shot estimates of optical phase. As described in detail below, we perform these measurements on optical pulses of 50 μ s duration derived from an intensity-stabilized cw laser. We have also plotted the theoretical prediction for the variance of ideal heterodyne measurement, both with (thin solid line) and without (dotted line) correction for a small amount of excess electronic noise in the balanced photocurrent. The excellent agreement between the heterodyne data and theory indicates that we have no excess phase noise (technically-ideal preparation of coherent signal states) and validates electronic calibrations involved in our data analysis [9]. In the range of $\sim 10 - 300$ photons per pulse, most of the adaptive data lies below the absolute theoretical limit for heterodyne measurement (dotted line), and all of it lies below the curve that has been corrected for excess electronic noise (which also has a detrimental effect on the adaptive data). Quantitatively, we note that for ≈ 50 photons per pulse the adaptive data point sits 6.5 standard deviations below the absolute heterodyne limit (note logarithmic scale).

For intermediate values of the photon number the adaptive variances should ideally be even lower, but the performance of our experiment is limited by finite feedback bandwidth. For signals with large mean photon number, the adaptive scheme is inferior to heterodyne because of excess technical noise in the feedback loop. As the intrinsic phase uncertainty of coherent states becomes large for very low photon numbers, the relative differences among the expected variances for adaptive, heterodyne, and ideal estimation become small. Accordingly, we have been unable to beat the heterodyne limit for phase-estimation variances with adaptive homodyne measurement for mean photon numbers $N \leq 8$. (Note that all theoretical curves in Fig. 1A correspond to asymptotic expressions valid for large mean photon numbers; corrections are small for $N \gtrsim 10$.) However, we are able to show that the estimator *distribution* for adaptive homodyne remains narrower than that for heterodyne detection even for pulses with mean photon number down to $N \approx 0.8$. In Fig. 1B we display the adaptive and heterodyne phase-estimator distributions for a signal size corresponding to ≈ 2.5 photons. Note that we have plotted the distributions on a logarithmic scale, and that the mean phase has been subtracted off so that the distributions are centered at zero. The horizontal axis can thus be identified with estimation error. The adaptive phase distribution has a smaller 'Gaussian width' than the heterodyne distribution, but exhibits rather high tails. The observed shape of the adaptive distribution agrees qualitatively with predictions [10] based on quantum estimation theory. Theoretical analysis suggests that the high tails are a consequence of changes in the sign of the photocurrent caused by vacuum fluctuations of the optical field, which become comparable to the coherent optical signal for $N \sim 1$. The feedback algorithm responds to these photocurrent inversions by locking to incorrect phase values with an error that tends towards π .

Accurately assessing the performance of a single-shot measurement requires many repetitions of the measurement under controlled conditions. Fig. 2A shows a schematic of our apparatus. Light from a single-mode cw Nd:YAG laser is first stripped of excess intensity noise by passage through a high-finesse Fabry-Perot cavity (not pictured) with ringdown time $\approx 16 \ \mu s$; the transmitted beam is shot-noise limited above ~ 50 kHz. This light enters the Mach-Zehnder interferometer (MZI) at beamsplitter 1 (BS1), creating two beams with well-defined relative phase. The local oscillator (LO) is generated using an acousto-optic modulator (AOM) driven by an RF synthesizer RF1 at 84.6 MHz, yielding $\sim 230 \ \mu W$ of frequency-shifted light. The signal beam corresponds to a frequency sideband created by an electro-optic modulator (EOM) driven by an RF synthesizer (RF2) that is phase locked to RF1. The power (5 fW to 5 pW) and pulse length (50 μ s) of the signal beam are controlled by changing the amplitude of RF2 and by switching it on/off. A pair of photodetectors collect the light emerging from the two output ports of the final 50/50 beamsplitter (BS2); the difference of their photocurrents (balanced photocurrent) provides the basic signal used for either heterodyne or adaptive phase estimation. At our typical LO power, the photodetectors supply 6 dB of shot noise (over electronic noise) in the difference photocurrent from to ~ 1 kHz to 10 MHz. We perform adaptive homodyne measurement by feedback to the phase of RF2,

which sets the (instantaneous) relative phase between signal and LO [11]. Our feedback bandwidth ~ 1.5 MHz is limited by the maximum slew rate of RF2. Real-time electronic signal processing for the feedback algorithm is performed by a Field Programmable Gate Array (FPGA) that can execute complex computations with very low latency [12]. Our feedback and phase estimation procedures correspond to the 'Mark II' scheme of Wiseman and co-workers [10], in which the photocurrent is integrated with time-dependent gain to determine the instantaneous feedback signal. The final phase estimate depends on the full history of the photocurrent and feedback signal. For heterodyne measurements we turn off the feedback to RF2 and detune it from RF1 by 1.8MHz; phase estimates are made by the standard method of I/Q demodulating the photocurrent beat note. For both types of measurement we store the photocurrent I(t) and feedback signal $\Phi(t)$ on a computer for post-processing.

In Fig. 2B we show the photocurrent and feedback signal of three consecutive adaptive phase measurements for $N \approx 8$. At the beginning of each measurement, feedback of the photocurrent shot noise causes the relative phase between the signal and LO to vary randomly. As more of the pulse is detected, the information gained is used to drive the signal-LO phase towards an optimal value. Phase estimation variances are established using ensembles of ≈ 150 consecutive single-shot measurements. Although each optical pulse is the subject of an *independent* single-shot measurement, we fix the signal phase over the length of each ensemble in order to accurately determine the estimation variance. It is important to note that each data point in Fig. 1A corresponds to an average of variance estimates from many ensembles, each with a different (random) signal phase.

Ideally, the performance of a single-shot phase measurement procedure should be independent of the signal phase. In our experiment, this implies that the measurement variances should be independent of the initial relative phase between signal and local oscillator. In Fig. 1C we display a polar plot of the adaptive variance (radial) versus initial signal phase (azimuth). The data were taken using signals with mean photon number ≈ 50 . Each data point corresponds to the variance of an ensemble of phase measurements taken at a fixed phase. The double solid lines indicate the (one sigma) performance of our heterodyne measurements. It is clear from this data that the performance of the adaptive homodyne scheme is essentially independent of initial phase, and is consistently superior to heterodyne measurement.

The photon number per pulse, N, is determined by extracting optical amplitude information from the balanced photocurrent in heterodyne mode. The typical experimental procedure is to fix the signal amplitude, take an ensemble of heterodyne measurements (which yields both heterodyne phase estimates and an estimate of N), and then take an ensemble of adaptive homodyne measurements. The photon number assigned to the subsequent ensemble of adaptive measurements is 0.95N, where the relative calibration factor arises from the measured response of the EOM.

In conclusion, we have presented an experimental demonstration of adaptive homodyne phase measurement. For pulses with mean photon number $\sim 10 - 300$ our measured variances approach closer to the intrinsic phase-uncertainty limit of coherent states than any previously demonstrated technique, including *ideal* hetero-dyne detection. These results establish the technical feasibility of broadband quantum-noise-limited feedback for adaptive quantum measurement [13], quantum feedback control [14], quantum error correction [15], and studies of conditional quantum dynamics [16, 17].

This work was supported by the NSF (PHY-9987541, EIA-0086038) and ONR (N00014-00-1-0479). JKS ac-knowledges the support of a Hertz Fellowship.

- [1] H. M. Wiseman, Phys. Rev. Lett. 75, 4587 (1995).
- [2] K. Schneider et al., Opt. Express 2, 59 (1998).
- [3] See special issue of Phys. Scr., **T48** (1993).
- [4] U. Leonhardt et al., Phys. Rev. A 51, 84 (1995).
- [5] Note that this precludes the use of techniques such as homodyne tomography, which rely on multiple measurements on an ensemble of identically-prepared systems.
- [6] C. M. Caves, P. D. Drummond, Rev. Mod. Phys. 66, 481 (1994).
- [7] This factor of two derives from the fact that heterodyne detection samples both the amplitude and phase quadrature amplitudes, which are complementary observables.
- [8] Y. Yamamoto *et al.*, in *Progress in Optics*, ed. E. Wolf (North-Holland, Amsterdam, 1990), Vol. 28, p. 150.
- [9] Our absolute calibration of the horizontal axis has been adjusted for overall photodetection efficiency η , which has no bearing on the relative comparison of adaptive and heterodyne measurement *procedures* but does affect our placement of the fundamental uncertainty limit associated with coherent states. We have independently measured $\eta \approx 0.56$, including detector quantum efficiency and homodyne fringe visibility, and have indicated the fundamental limit for phase estimation given this value of η . For phase measurements performed on squeezed states η would need to be optimized, but its value and the corresponding correction to the photon-number calibration are not of direct concern in our current investigation involving coherent states.
- [10] H. M. Wiseman and R. B. Killip, Phys. Rev. A 57, 2169 (1998).
- [11] In principle one can modulate either the signal phase or the LO phase; we do the former to avoid interference between the adaptive homodyne feedback loop and an auxiliary feedback loop used to stabilize the MZI.
- [12] J. K. Stockton, M. Armen, and H. Mabuchi, in preparation (quant-ph/0203143 at http://www.arXiv.org).
- [13] D. W. Berry, H. M. Wiseman, Phys. Rev. A 6301, 013813 (2001).
- [14] A. C. Doherty et al., Phys. Rev. A 6201, 012105 (2000).

- [15] C. Ahn, A. C. Doherty, and A. Landahl, Phys. Rev. A, 65, 042301 (2002).
- [16] W. P. Smith et al., in preparation (quant-ph/0202063 at http://www.arXiv.org).
- [17] H. Mabuchi and H. M. Wiseman, Phys. Rev. Lett. 81, 4620 (1998).

FIG. 1: Experimental results from the adaptive and heterodyne measurements. (a) Adaptive (blue circles) and Heterodyne (red crosses) phase estimate variance vs. pulse photon number. The blue dashed-dotted line is a second order fit to the adaptive data. The thin lines are the theoretical curves for heterodyne detection with (solid) and without (dotted) corrections for detector electronic noise. The thick solid line denotes the fundamental quantum uncertainty limit, given our overall photodetection efficiency. (b) Phase-estimator distributions for adaptive (blue circles) and heterodyne (red crosses) measurements, for pulses with mean photon number ≈ 2.5 . (c) Polar plot showing the variance of adaptive phase estimates (blue dots) for different signal phases (mean photon number ≈ 50). The solid blue line is a linear fit to the data. The double red lines indicate the one sigma range for heterodyne measurements averaged over initial phase.

FIG. 2: (a) Apparatus used to perform both adaptive homodyne and heterodyne measurements (see text). Solid lines denote optical paths, and dashed lines denote electrical paths. (b) Photocurrent I(t) (red above), and feedback signal $\Phi(t)$ (green below), for three consecutive adaptive homodyne measurements with $N \approx 8$. The x-axis represents time for both signals. The y-axis scale indicates the absolute phase shifts made by the feedback signal. The photocurrent is plotted on an arbitrary scale.